



Report to Utility Committee

Agenda Item: Discussion and Possible Action: Installing Ductless Split Heat Pump for Well #1 and #2 Well Rooms for \$9,560.00

Meeting Date: April 7, 2026

Referring Body: Utility Committee

Committee Contact:

Staff Contact: Greg Ulman

Report Prepared by: Greg Ulman

AGENDA ITEM: Discussion and Possible Action: Installing Ductless Split Heat Pump for Well #1 and #2 Well Rooms for \$9,560.00

OBJECTIVE(S): To have Malbrit Mechanical, Inc. install a ductless split pump in both well rooms.

HISTORY/BACKGROUND: During the hot days of the summer the well rooms get very warm and humid, when the rooms are that warm, the wells pump cold water from the earth and it creates condensation on many items in the well rooms including our electronics. To prevent equipment breakdowns with excess condensation we put in extra money in the budget this year to install ductless split units in each well room.

RECOMMENDED ACTION: To purchase the ductless split unit for the well rooms for \$9,560.00

FINANCIAL

FUNDING SOURCE:

Account Number/Title:	#601-53610-625-001
Current Adopted Budget:	\$ 17,000.00
Spent to Date:	\$ 0.00
Remaining Budget:	\$ 17,000.00
Requested Amount:	\$ 9,560.00
Remainder of Budgeted Amount, if approved:	\$7,440.00

ATTACHMENTS: Quote