



Report to Utility Committee

Agenda Item: Discussion and Possible Action: Completion of Water Filtration Plant Items

Meeting Date: July 1, 2025

Referring Body: Utility Committee

Committee Contact:

Staff Contact: Greg Ulman

Report Prepared by: Greg Ulman

AGENDA ITEM: Discussion and Possible Action: Completion of Water Filtration Plant Items

OBJECTIVE(S): To approve the change order for the water filtration plant.

HISTORY/BACKGROUND: There have been warning alarms when we do the backwash sequence since the plant came online, we've been reaching out to Becher-Hoppe as well as Kurita for an explanation. After many site visits Kurita determined the piping for the air release valve needed to be upsized on the horizontal filter tank. This also requires 1-inch taps to be installed at the bottom of each pipe on the vertical detention tanks. Fixing this problem will allow the air to move properly in the backwash sequence and eliminate the alarms as well.

RECOMMENDED ACTION: UC take action as it sees fit.

ATTACHMENTS: Change Order paperwork