

MEETING DATE

CITY OF LAKE CITY

Report to Council

COUNCIL AGENDA	
SECTION	
ITEM NO.	

SUBJECT: Branford Site Effluent Disposal Analysis

DEPT / OFFICE: Utilities – Wastewater

Originator: Cody Pridgeon, Wastewater Director		
City Manager Don Rosenthal	Department Director Cody Pridgeon	Date 1/24/25
Recommended Action: Accept Proposal from Mittauer & Associates		
Summary Explanation & Background: Due to the current and projected growth rate of Lake City it is necessary to expand the wastewater effluent disposal site. The existing 380 acre effluent disposal site is permitted for only 3.0 million gallons per day while both treatment plants have a combined permitted capacity of 6.0 million gallons per day. The current annual average daily flow sent to the site is 2.47 million gallons per day. The City currently owns 454 acres near Branford highway and 242 intersection that is suitable for effluent disposal. The purpose of the analysis will be to determine the cost, efficiency and best method for effluent disposal.		
Alternatives: Not Approve		
Source of Funds: 410.74.536-030.31		
Financial Impact: \$90,600		
Exhibits Attached: 1) Proposal		