Return to: City of Lake Worth Beach Attn: City Clerk's Office 7 N. Dixie Highway Lake Worth Beach, FL 33460

BILL OF SALE

REMAINDER OF THIS PAGE INTENTIONALLY LEFT BLANK


| City of Lake Worth Beach shall be effective | |
|--|--|
| WITNESSES: | SELLER: Milas Rich |
| Witness Signature Romon Williams Ja Print Name of Witness above Witness Signature | [Corporate Seal] |
| TAKE SChulman Print Name of Witness above STATE OF FLORIDA | JAKE SCHULMAN MY COMMISSION #HH077875 EXPIRES: JAN 06, 2025 Bonded through 1st State Insurance |
| The foregoing instrument was acknowledged before me this 5 day of May, 20 21, by Miles Rich, as owned of of Sim Belmoda LLC., who is personally known to me or who produced and as identification. My commission expires: 0/06/2025 Motary Signature | |
| The City of Lake Worth Beach accepted the | |
| ATTEST: | City of Lake Worth Beach Betty Resch, Mayor Approved as to formand legal sufficiency: |
| Deborah M Andrea, City Clerk | Glen J. Torcivia, City Attorney |

*** ·-A

EXHIBIT "A"


RECORD OF ASSETS

58 LF, 6" DIP watermain, 1 dual water service, 1 single water service, 1 multiple sanitary sewer service, `6" gate valve



RECORD AS-BUILT DRAWING

<u>LEGEND</u>



EASEMENT LINE

EXISTING WATER MAIN, GATE
VALVE (G.V.), TEE, F.H. AND PLUG

EXISTING SANITARY SEWER MAIN,
MANHOLE AND DIRECTION OF FLOW.

PROPOSED WATER MAIN, GATE VALVE
(G.V.), BEND AND TEE WITH FIRE
HYDRANT ASSEMBLY.

PROPOSED SANITARY SEWER MAIN, SINGLE & DOUBLE SEWER SERVICE CLEAN OUT (C.O.), MANHOLE AND SEWER LATERAL w/CLEANOUT

MILL & RESURFACE EXIST. PAVEMENT ASPHALT PAVEMENT

UTILITY CONFLICT

UTILITY EASEMENT

CONCRETE

<u>NOTES:</u>

- ALL WATER & SEWER FACILITIES SHALL BE CONSTRUCTED AND TESTED IN ACCORDANCE WITH CITY OF LAKE WORTH UTILITIES DEPARTMENT STANDARDS, LATEST EDITION.
- 2. UTILITY LOCATIONS SHOWN BASED ON INFORMATION PROVIDED BY CLW PUBLIC SERVICES & UTILITIES DEPARTMENTS. CONTRACTOR TO FIELD VERIFY LOCATION OF ALL EXISTING UTILITIES, AND MUST CALL 811 AT LEAST 48 HRS PRIOR TO EXCAVATION.
- 3. ALL UN-LANDSCAPED/UNPAVED AREAS SHALL BE SODDED UNLESS OTHERWISE NOTED.
- 4. ANY WATER SYSTEMS SHUT-DOWN AND CORRESPONDING BOIL WATER NOTICE NEEDED TO INSTALL THE NEW 6" WATERMAIN SHALL BE COORDINATED WITH THE CITY OF LAKE WORTH UTILITIES DEPARTMENT A MINIMUM OF 1 WEEK IN ADVANCE



McLeod • McCarthy & Associates, P.A.

The Forum III

1655 Palm Beach, Lakes Blvd, Ste. 901

West Palm Beach, FL 33401

P: 561.689.9500

E: 561.689.8080 www.mcleodmccarthy.com

| COD, P.E. | FL CA NO. 30535

TODD—seal—sig.pr 10/19/2020 TODD N. MCLEOD, FL LICENSE NO. 69188 | FL CA

DRAWN: PAS
DESIGNED: TNM
APPROVED: TNM
PROJECT #:16-027
DRAWING #:

WATER & WASTEWATER PLAN
BERMUDA CAY
301 S. FEDERAL HIGHWAY

SCALE: AS SHOWN DATE: 1/7/19

C4.1

OF 11