



IFB#26-100 Medium Voltage EPR, 25kV and 28kV Feeder Cable

Bid Tabulation

				Irby Utilities		Bell Electrical Supply Co., Inc.		American Wire Group, LLC		Wesco Distribution (Offer 1)		Wesco Distribution (Offer 2)		Gresco (Offer 1)		Gresco (Offer 2)	
ITEM #	DESCRIPTION	QUANTITY	UNIT	UNIT PRICE	TOTAL OFFER	UNIT PRICE	TOTAL OFFER	UNIT PRICE	TOTAL OFFER	UNIT PRICE	TOTAL OFFER	UNIT PRICE	TOTAL OFFER	UNIT PRICE	TOTAL OFFER	UNIT PRICE	TOTAL OFFER
1	Medium Voltage EPR, Feeder Cable	108,000	Ft.	\$14.96	\$1,615,680.00	\$1.78	\$192,240.00	\$20.73	\$2,238,840.00	\$15.26	\$1,648,080.00	\$16.83	\$1,817,640.00	\$16.70	\$1,803,600.00	\$17.00	\$1,836,000.00
Delivery (max 210 calendary days):				91		120		180		140		140		154		140	
kV Offered:				25kV		not specified		not specified		25kV		28kV		25kV		28kV	
Manufacturer Offered:				Okonite		Apollo Wire		Centelsa by Nexans		Marmon Utility LLC		Marmon Utility LLC		Prysmian		Prysmian	
Insulation Type:				EPR Okoguard		Extruded unfiled EPB		EPR		EPR		EPR		EPR		EPR	
Insulation Thickness:				0.26		0.305 inch minimum		260mils		260 mils		280 mils		0.26" (dia min 1.645" max 1.740")		0.280" (dia min 1.685" max 1.785")	
Bid Package Cover Sheet (B1)				Submitted		Submitted		Submitted		Submitted		Submitted		Submitted		Submitted	
Minimum Qualifications (B2)				Submitted		Submitted		Submitted		Submitted		Submitted		Submitted		Submitted	
Bid (B3)				Submitted		Submitted		Submitted		Submitted		Submitted		Submitted		Submitted	
Used Required Revised Schedule of Unit Prices & Delivery (B4)				Submitted		No		No		Submitted		Submitted		Submitted		Submitted	
Substitution (B5)				N/A		Sustitution Offered		Sustitution Offered		Additional alternate product offered		Additional alternate product offered		Additional alternate product offered		Additional alternate product offered	
Manufacturer Verification Form (B6)				Submitted		Submitted		Submitted		Submitted		Submitted		Submitted		Submitted	
Reference List (B7)				Submitted		Submitted		Submitted		Submitted		Submitted		Submitted		Submitted	
Affidavit Of Prime Bidder re Non-collusion (B8)				Submitted		Submitted		Submitted		Submitted		Submitted		Submitted		Submitted	
Drug Free Certification (B9)				Submitted		Submitted		Submitted		Submitted		Submitted		Submitted		Submitted	
Campaign Contribution Statement (B10)				Submitted		Submitted		Submitted		Submitted		Submitted		Submitted		Submitted	
Scrutinized Companies Certification (B11)				Submitted		Not signed or notarized		Submitted		Submitted		Submitted		Submitted		Submitted	
Veteran Business Enterprise, Small Business and/or Local Business Preference Form (B12)				N/A		Applied for Small Business Preference - Vendor does not qualify per the City's Ordinance - did not provide documentation		N/A		N/A		N/A		N/A		N/A	
Manufacturer Data Sheet/Technical Specs/Drawings				Yes		Yes		Yes		Yes		Yes		Yes		Yes	
Comments				Voltage did not meet 27.7kV continuous on spec sheets		No Voltage Ratings on Data sheet/specs		No explicit mention of 27.7kV Continuous capability		No explicit mention of 27.7kV Continuous capability				No explicit mention of 27.7kV Continuous capability			
Compliance to technical specifications				No		No		No		No		Yes		No		Yes	

Appears to be unbalanced Bid