

STAFF REPORT REGULAR MEETING

AGENDA DATE: February 4, 2025

DEPARTMENT: Public Works

TITLE:

Change Order #1 with Homestead Concrete

SUMMARY:

Homestead Concrete is requesting a 35-day extension for the ADA Sidewalk & Curb Installation Project.

BACKGROUND AND JUSTIFICATION:

During demolition it was discovered that that some curbs throughout the city that appeared to be “D” curb were in fact “F” curb with valley gutters placed deeper than the FDOT standard. This took additional time and effort to remove which in turn impacted the work schedule. The change order is only for additional time, there will not be any additional funds expended.

MOTION:

Move to approve/disapprove Change Order #1 with Homestead Concrete

ATTACHMENT(S):

Fiscal Impact Analysis -N/A
Change Order #1