



**City of Lake Worth Beach**

**BID TABULATION - IFB #24-108 500MCM Cable (REVISED)**

ITEM #	DESCRIPTION	QUANTITY	UNIT	MP Predictive Technologies Inc.				Wesco (Offer #1)				Wesco (Offer #2)				MVA Power, Inc.			
				Manuf Offered	DELIVERY (Calendar Days)	UNIT PRICE	TOTAL OFFER	Manuf Offered	DELIVERY (Calendar Days)	UNIT PRICE	TOTAL OFFER	Manuf Offered	DELIVERY (Calendar Days)	UNIT PRICE	TOTAL OFFER	Manuf Offered	DELIVERY (Calendar Days)	UNIT PRICE	TOTAL OFFER
1	500MCM, CU, LLDPE, 28kV, 280 mils, 1/3 10AWG CCN, 100% Insulation	4	Reels	Okonite	364	\$68,784.88	\$275,139.52	American Wire Group	112-126	see notes	\$335,232.00	CME	308	\$80,408.00	\$321,632.00	MVA Power, Inc.	85	\$104,447.20	\$417,788.80
2	400 feet of Cable, MV, 1/C, 500MCM, CU, LLDPE, 28kV, 280 mils, 1/3 10AWG CCN, 100% Insulation	2	Reels	Okonite	364	\$52,276.50	\$104,553.00	American Wire Group	112-126	see notes	\$83,808.00	CME	308	\$8,464.00	\$16,928.00	MVA Power, Inc.	85	\$10,994.40	\$21,988.80
<b>TOTAL BID:</b>				<b>\$379,692.52</b>				<b>\$419,040.00</b>				<b>\$338,560.00</b>				<b>\$439,777.60</b>			
Bid Package Cover Sheet (B1)				submitted				submitted				submitted				submitted			
Minimum Qualifications (B2)				submitted				submitted				submitted				submitted			
Bid (B3)				submitted				submitted				submitted				submitted			
Schedule of Unit Prices & Delivery (B4)				submitted				submitted				submitted				submitted			
Substitution Sheet (B5)				N/A				N/A				N/A				N/A			
Manufacturer Verification Form (B6)				submitted				submitted				submitted				submitted			
Reference List (B7)				submitted				submitted				submitted				submitted			
Affidavit Of Prime Bidder re Non-collusion (B8)				submitted				submitted				submitted				submitted			
Drug Free Certification (B9)				submitted				submitted				submitted				submitted			
Campaign Contribution Statement (B10)				submitted				submitted				submitted				submitted			
Scrutinized Companies Certification (B11)				submitted				submitted				submitted				submitted			
Veteran Business Enterprise, Small Business and/or Local Business Preference Form (B12)				N/A				N/A				N/A				N/A			
Addendum Acknowledgment				Yes				Yes				Yes				Yes			
Manufacturer Data Sheet/Technical Specs/Drawings				Yes				Yes				Yes				Yes			
Compliance				No - Vendor withdrew offer				No				No				Yes			
N/A								The provided cable lengths did not meet the required amounts.				Bidder provided cable specification that stated that cable pulling tension was for most popular sizes and configuration and did not clearly specify if this tension was applicable to cable that was bid. The pulling tension was not included in the specification sheet, but in a separate document with general guidelines for handling and installing of underground cables. Based on the provided information City cannot determine compliance with the requirement.							