

Fire Department

Phone: (248) 391-0304, ext. 2000 Fax: (248) 309-6993

To: Darwin McClary, Village Manager

From: Jeff Williams, Fire Marshal Re: Snug Harbor Site Plan Review

www.oriontownship.org

Date: 4/15/2023

The Orion Township Fire Department has completed its review of the Snug Harbor Application for the limited purpose of compliance with the Village of Lake Orion's Ordinance's, Michigan Building Code, and all applicable Fire Codes.

Based upon the application and documentation provided, the Fire Department has the following recommendation:

X Approved

Approved with Comments (See below)

Not approved

Comments: None at this time

This approval is limited to the application and materials reviewed which at this time do not raise a specific concern with regard to location and/or impact on health and safety. However, the approval is conditioned upon the applicant providing sufficient additional information at time of building permit application that includes data or documents, confirming full compliance with all applicable building codes, fire codes and Township Ordinances.

If there are any questions, the Fire Department may be reached at 248-391-0304 ext. 2004.

Sincerely,

Jeff Williams, Fire Marshal

Jeffrey Williams

Orion Township Fire Department