



Landis Multifamily Review Comments & Responses

Project: Lanids Multifamily

Planning Comments:

1. Show USPS Cluster Mailbox
 - a. Added to Sheet C-3.0
2. Show FDC Connections
 - a. Shown from MEP drawings onto C-3.0, C-5.0
3. Change "Setback" Label to "Build-To-Line" Label
 - a. Changed on C-3.0 & Set
4. Call out open space on C-3.0 per LDO 21.2-1 (D) – 7500 SF
 - a. Open space called out and shown C-3.0 and C-6.0
5. Call out open space improvements per 21.2-4 & 21.2-7(C)
 - a. Shown & Called out on C-3.0 & C-6.0 as follows (4) Minimum
 - i. Landscaping
 - ii. Walks
 - iii. Fences
 - iv. Playground equipment