

Good Morning,

Looking ahead in the future, if Landis applies for the PARTF grant to help fund the new DC & Francis Linn Park, are there any requirements on the percentage of ADA walking spaces that would affect funding? For example, we have several sidewalks throughout the park, but our plans also reflect a veteran's memorial where the traffic pattern is a brick circle. The committee is concerned that if the circle remains brick instead of a concrete sidewalk it could limit funding due to ADA compliance. Any information regarding this you can provide will be helpful in the decision making.

Thank you,

Jessica St. Martin | Director of Parks & Recreation

Hi Jessica,

Thanks for your patience as I work through email after being out last week. Generally speaking, brick may be considered ADA compliant as long as it is maintained to surface and slope standards. Bricks need to be flush and tightly laid. There is not a percentage of sidewalks that need to be ADA compliant. However, you do need to meet state and local code. Generally, this means that all amenities in the park need to be accessible by at least one pathway.

As y'all are visioning the new park, know that I'm happy to come over to meet with you and/or others to talk about PARTF and other state grant opportunities.

Thanks,
Trey