



Item Cover Page

MEETING TYPE: Board of Alderman

DATE: February 12, 2024

SUBMITTED BY: Michael D. Ambrose, Town Manager

ITEM TYPE: Consideration

AGENDA SECTION: Considerations

SUBJECT: **Consider Update on South Upright Street Lift Station**

DETAILS:

There has been two inflow and infiltration issues with the South Upright Street Lift Station within the past month. This was caused by excess rainwater getting into the lift station and causing it to overflow into the creek. The Town currently has an outstanding grant project which is expected to begin this summer. Part of this project is designed to replace the old clay pipes which are currently feeding the Upright Lift Station. This replacement should reduce the amount of rainwater that is entering the station. The Engineer on the project has assured staff this issue will diminish once the project is complete.