



Item Cover Page

MEETING TYPE: Board of Alderman

DATE: January 13, 2025

SUBMITTED BY: Michael D. Ambrose, Town Manager

ITEM TYPE: Consideration

AGENDA SECTION: Consent Agenda

SUBJECT: **Consider Approval of the Engineering Bid for the South Upright Pump Station Upgrade**

DETAILS:

The Town advertised Request For Qualifications (RFQ) from engineering firms for upgrading an existing Lift Station located on South Upright Street. The qualifications were sought to assist the town in increasing lift station capacity from 427 Gallons Per Minute Station to a 600 Gallons Per Minute Station, due to the influx of wastewater needs impacting our basins.

The services sought after included engineering design, bidding, construction administration, construction observation and project certification. The Town received RFQ's from LKC Engineering, Allen Williams Carmen & King, Inc. and Municipal Engineering, Inc. I make the recommendation, based on experience, capability, and qualifications, to award LKC Engineering the project. LKC Engineering is currently conducting the Wastewater Feasibility Study for a proposed Wastewater Treatment Plant to be located in the Town. LKC also performed the SCADA upfit at the South Chapel Street Booster Station, and the Water Tower. If awarded the project, LKC will be able to integrate our current SCADA system into the upgraded lift station.