

Pond A question clarifications:

Does drywell drain to outlet structure?

Is there an outlet control structure here? Plans differ from approved 1/31/2017 set. Verify as-built locations, elevations and orifice sizes.

Conflicting data. Please clarify throughout drawing.

Based on the spot elevations shown it appears the spillway is higher than top of berm. Verify and determine if correction is required.

Pond B question Clarifications:

Was there a SWPPP amendment to change from 100-yr overflow weir to 12" piped outlet? If so, provide copy for record.

Was the level spreader ever installed per design? Label and show location

Clarify direction of flow as it leaves the swale. Does it go back into pond A?

spillway 974?

Is this showing as-built conditions? Verify location of parking/swale. Swale is shown through the parking

