



1831 Austin Drive Troy MI 48083 Ph: 248-669-4338 Email: [service@dennysonline.com](mailto:service@dennysonline.com)

July 24, 2025

Mr. Michael Green  
**City of Lathrup Village**  
24700 Southfield Rd  
Lathrup Village, MI 48076

Phone: (248) 577-2600 x 227  
Email: [mgreene@lathrupvillage.org](mailto:mgreene@lathrupvillage.org)

Reference: RTU-2 Carrier S/N: 0710U02904

Subject: Replace 1<sup>st</sup> Stage Compressor

We are pleased to submit the following quotation for your review and consideration. We found the compressor has open windings and needs to be replaced. We will recover refrigerant from the circuit, remove and replace the compressor, replace liquid line filter drier, evacuate system, charge with refrigerant. Start up and ensure proper operation.

**PRICE INCLUDES:**

- |                                     |               |
|-------------------------------------|---------------|
| 1. Contactor                        | 6. Evacuation |
| 2. 1 <sup>st</sup> Stage Compressor | 7. Brazing    |
| 3. Filter Drier                     | 8. Recovery   |
| 4. Refrigerant                      | 9. Labor      |
| 5. Copper                           |               |

**EXCLUSIONS:**

1. Overtime

**Total Cost:** ..... **\$7,556.00**

**\*Terms: Balance Net 30 upon completion**

**\*\*Quote is valid for 30 days. If approved after 30 days, price may fluctuate based on supplier cost.**

This quote is valid for 30 days.

**Please allow 7 to 10 business days to receive parts and schedule.**

Thank you for this opportunity to serve your needs. If you have any questions, please do not hesitate to contact me. (248) 669-4338

Respectfully,

Dakota Osborn  
Customer Service Representative

Approved and accepted by \_\_\_\_\_

Title \_\_\_\_\_ Date \_\_\_\_\_ PO \_\_\_\_\_