

Consider Agreement
San Antonio Water System(SAWS)
City of Leon Valley
Emergency Water Interconnect

David Dimaline
Public Works Assistant Director
City Council Meeting
August 5, 2025

Summary

- Question: Should the City Council enter into an agreement with SAWS for an emergency interconnection?
- Options
 - Approve
 - Deny
 - Other
- Declaration
 - Recommend entering into agreement with SAWS for an emergency interconnection

Purpose

- To consider authorizing the City Manager to enter into an Agreement between SAWS and the City of Leon Valley for the Emergency Interconnect and Providing an Emergency Water Supply

Background

- Emergency interconnect was constructed as part of the Leon Valley Municipal Water Well Project
- 30" SAWS water main along Bandera Rd. was tapped with a 6" connection running along Grass Hill into the Grass Hill Well site
- Connects directly into the 750,000-gallon ground storage tank
- Activation is to be temporary & limited to conditions necessitated by mechanical failure

Background

- Original 10-year Agreement (signed on October 20, 2015) set to terminate
- New Agreement will begin October 20, 2025 & terminate on October 20, 2035

Fiscal Impact

- Monthly fee for 6" meter is \$386.18 per month
- Funding for this is included annually in the Water Utility budget
- Any usage is billed the current SAWS water service rate in accordance with City of San Antonio Ordinance #101684
- Only used once (briefly) during Winter Storm Uri when tanks went low

Recommendation

- Staff recommends approval of the Agreement