



FIRE PLAN NOTES:
 1. All Fire Hydrants to be spaced no more than 500' apart, measured as the hose lays.
 2. All inside corner radii of internal fire lanes nto be no less than 25'.

