



where people matter

City of Loganville

Public Utilities
Brandon Phillips
Director

P.O. Box 39
Loganville, GA 30052

Tel: 770-466-3240

Staff Report Department of Public Utilities

To: Honorable Mayor Whitfield, and Members of the City Council

Through: Danny Roberts, City Manager

From: Brandon Phillips, Director of Utilities

Date: October 8, 2026

Subject: Submersible Pump Rebuild (Emergency Repair)

RECOMMENDATION:

The Utilities Department recommends the City Council approves Goforth Williamson for the emergency repair of the return activated sludge pump at the wastewater treatment facility.

FISCAL IMPLICATION:

Total costs to rebuild the submersible pump, and to purchase a new impeller is \$25,350.00

Line item 505-4300-522203

BACKGROUND:

There are two return activated sludge (RAS) Grundfos pumps, and we are currently operating on the secondary back-up pump. These pumps are in continuous operation recycling solids back to the head of the treatment plant. The impeller is pitted and needs replaced as recommended by Goforth Williamson, Inc.

Goforth Williamson (GWI) is our rep for Grundfos equipment. They currently have the pump at their facility ready to do the repair.