



TOWN OF LOS GATOS
COMMUNITY DEVELOPMENT DEPARTMENT
PLANNING DIVISION
(408) 354-6872 Fax (408) 354-7593

CIVIC CENTER
110 E. MAIN STREET
LOS GATOS, CA 95030

January 17, 2024

Meleah Guillard
15995 Lancaster Rd.
Monte Sereno, CA 95030
Via Email

RE: 212 Thurston Street
Architecture and Site Application S-23-009

Requesting Approval for Demolition of an Existing Single-Family Residence and Construction of a New Single-Family Residence with Reduced Setbacks on Property Zoned R-1D. APN 410-15-039.
PROPERTY OWNER/APPLICANT: Meleah Guillard
PROJECT PLANNER: Maria Chavarin

At its meeting of January 10, 2024, the Town of Los Gatos Planning Commission approved the above referenced application subject to the attached draft conditions of approval.

The attached conditions of approval will not be final until the Planning Commission has approved the January 10, 2024 meeting minutes at their next meeting, confirming any additional or modified conditions of approval for the project in the underlined font. You will be notified in writing once the Planning Commission has approved the minutes.

PLEASE NOTE: Pursuant to Section 29.20.275 of the Town Code, this approval may be appealed to the Town Council within 10 days of the date the approval is granted. Therefore, this action for approval should not be considered final, and no permits by the Town will be issued until the appeal period has passed.

If you have any questions, I can be contacted by mchavarin@losgatosca.gov.

Sincerely,

Maria Chavarin
Maria Chavarin
Assistant Planner

Cc: Chris Spaulding

N:\DEV\PC\PC ACTION Letters\2024\01-10-24 [212 Thurston St. - Item #3; approved].docx

PLANNING COMMISSION – January 10, 2024
CONDITIONS OF APPROVAL

212 Thurston Street
Architecture and Site Application S-23-009

Requesting Approval for Demolition of an Existing Single-Family Residence and Construction of a New Single-Family Residence with Reduced Setbacks on Property Zoned R-1D. Located at 212 Thurston Street. APN 410-15-039.

PROPERTY OWNER/APPLICANT: Meleah Guillard
PROJECT PLANNER: Maria Chavarin

TO THE SATISFACTION OF THE DIRECTOR OF COMMUNITY DEVELOPMENT:

Planning Division

1. APPROVAL: This application shall be completed in accordance with all of the conditions of approval and in substantial compliance with the approved plans. Any changes or modifications to the approved plans and/or business operation shall be approved by the Community Development Director, DRC, or the Planning Commission depending on the scope of the changes.
2. EXPIRATION: The approval will expire two years from the approval date pursuant to Section 29.20.320 of the Town Code, unless the approval has been vested.
3. STORY POLES: The story poles on the project site shall be removed within 30 days of approval of the Architecture & Site application.
4. SCREENING: Plant a row of evergreen shrubs along the rear (north) and side (east) of the lot to form a hedge and serve as screening from the east wall of the garage to the eastern most corner of the proposed house, as shown in Exhibit 11 to the January 10, 2024 Planning Commission Staff Report.
5. GARAGE: Repair the detached garage concurrently with the construction of the residence prior to certificate of occupancy for the house.
6. WINDOWS: Bathroom windows that are located on the second floor facing the rear of the lot shall be raised five (5) feet above the floor and use an obscure glass, as shown in Exhibit 11 to the January 10, 2024 Planning Commission Staff Report.
7. OUTDOOR LIGHTING: Exterior lighting shall be kept to a minimum, and shall be down directed fixtures that will not reflect or encroach onto adjacent properties. No flood lights shall be used unless it can be demonstrated that they are needed for safety or security.
8. EXISTING TREES: All existing trees shown on the plan and trees required to remain or to be planted are specific subjects of approval of this plan, and must remain on the site.
9. TREE FENCING: Protective tree fencing and other protection measures shall be placed at the drip line of existing trees prior to issuance of demolition and building permits and shall remain through all phases of construction. Include a tree protection plan with the construction plans.
10. TREE STAKING: All newly planted trees shall be double-staked using rubber tree ties.

11. FRONT YARD LANDSCAPE: Prior to issuance of a Certificate of Occupancy the front yard must be landscaped.
12. WATER EFFICIENCY LANDSCAPE ORDINANCE: The final landscape plan shall meet the Town of Los Gatos Water Conservation Ordinance or the State Water Efficient Landscape Ordinance, whichever is more restrictive. A review fee based on the current fee schedule adopted by the Town Council is required when working landscape and irrigation plans are submitted for review.
13. TOWN INDEMNITY: Applicants are notified that Town Code Section 1.10.115 requires that any applicant who receives a permit or entitlement ("the Project") from the Town shall defend (with counsel approved by Town), indemnify, and hold harmless the Town, its agents, officers, and employees from and against any claim, action, or proceeding (including without limitation any appeal or petition for review thereof) against the Town or its agents, officers or employees related to an approval of the Project, including without limitation any related application, permit, certification, condition, environmental determination, other approval, compliance or failure to comply with applicable laws and regulations, and/or processing methods ("Challenge"). Town may (but is not obligated to) defend such Challenge as Town, in its sole discretion, determines appropriate, all at applicant's sole cost and expense.

Applicant shall bear any and all losses, damages, injuries, liabilities, costs and expenses (including, without limitation, staff time and in-house attorney's fees on a fully-loaded basis, attorney's fees for outside legal counsel, expert witness fees, court costs, and other litigation expenses) arising out of or related to any Challenge ("Costs"), whether incurred by Applicant, Town, or awarded to any third party, and shall pay to the Town upon demand any Costs incurred by the Town. No modification of the Project, any application, permit certification, condition, environmental determination, other approval, change in applicable laws and regulations, or change in such Challenge as Town, in its sole discretion, determines appropriate, all the applicant's sole cost and expense. No modification of the Project, any application, permit certification, condition, environmental determination, other approval, change in applicable laws and regulations, or change in processing methods shall alter the applicant's indemnity obligation.

14. COMPLIANCE MEMORANDUM: A memorandum shall be prepared and submitted with the building plans detailing how the Conditions of Approval will be addressed.

Building Division

15. PERMITS REQUIRED: A Demolition Permit is required for the demolition of the existing single-family residence. A separate Building Permit is required for the construction of the new single-family residence. An additional Building Permit will be required for the PV System if the system is required by the California Energy Code.
16. APPLICABLE CODES: The current codes, as amended and adopted by the Town of Los Gatos as of January 1, 2023, are the 2022 California Building Standards Code, California Code of Regulations Title 24, Parts 1-12, including locally adopted Reach Codes.
17. CONDITIONS OF APPROVAL: The Conditions of Approval must be blue lined in full on the cover sheet of the construction plans. A Compliance Memorandum shall be prepared and

submitted with the building permit application detailing how the Conditions of Approval will be addressed.

18. SIZE OF PLANS: Minimum size 24" x 36", maximum size 30" x 42".
19. REQUIREMENTS FOR COMPLETE DEMOLITION OF STRUCTURE: Obtain a Building Department Demolition Application and a Bay Area Air Quality Management District Application from the Building Department Service Counter. Once the demolition form has been completed, all signatures obtained, and written verification from PG&E that all utilities have been disconnected, return the completed form to the Building Department Service Counter with the Air District's J# Certificate, PG&E verification, and three (3) sets of site plans showing all existing structures, existing utility service lines such as water, sewer, and PG&E. No demolition work shall be done without first obtaining a permit from the Town.
20. SOILS REPORT: A Soils Report, prepared to the satisfaction of the Building Official, containing foundation, and retaining wall design recommendations, shall be submitted with the Building Permit Application. This report shall be prepared by a licensed Civil Engineer specializing in soils mechanics.
21. SHORING: Shoring plans and calculations will be required for all excavations which exceed five (5) feet in depth, or which remove lateral support from any existing building, adjacent property, or the public right-of-way. Shoring plans and calculations shall be prepared by a California licensed engineer and shall confirm to the Cal/OSHA regulations.
22. FOUNDATION INSPECTIONS: A pad certificate prepared by a licensed civil engineer or land surveyor shall be submitted to the project Building Inspector at foundation inspection. This certificate shall certify compliance with the recommendations as specified in the Soils Report, and that the building pad elevations and on-site retaining wall locations and elevations have been prepared according to the approved plans. Horizontal and vertical controls shall be set and certified by a licensed surveyor or registered Civil Engineer for the following items:
 - a. Building pad elevation
 - b. Finish floor elevation
 - c. Foundation corner locations
 - d. Retaining wall(s) locations and elevations
23. TITLE 24 ENERGY COMPLIANCE: All required California Title 24 Energy Compliance Forms must be blue-lined (sticky-backed), i.e., directly printed, onto a plan sheet.
24. TOWN RESIDENTIAL ACCESSIBILITY STANDARDS: New residential units shall be designed with adaptability features for single-family residences per Town Resolution 1994-61:
 - a. Wood backing (2" x 8" minimum) shall be provided in all bathroom walls, at water closets, showers, and bathtubs, located 34 inches from the floor to the center of the backing, suitable for the installation of grab bars if needed in the future.
 - b. All passage doors shall be at least 32-inch-wide doors on the accessible floor level.
 - c. The primary entrance door shall be a 36-inch-wide door including a 5'x 5' level landing, no more than 1 inch out of plane with the immediate interior floor level and with an 18-inch clearance at interior strike edge.
 - d. A door buzzer, bell or chime shall be hard wired at primary entrance.

25. BACKWATER VALVE: The scope of this project may require the installation of a sanitary sewer backwater valve per Town Ordinance 6.50.025. Please provide information on the plans if a backwater valve is required and the location of the installation. The Town of Los Gatos Ordinance and West Valley Sanitation District (WVSD) requires backwater valves on drainage piping serving fixtures that have flood level rims less than 12 inches above the elevation of the next upstream manhole.
26. HAZARDOUS FIRE ZONE: All projects in the Town of Los Gatos require Class A roof assemblies.
27. SPECIAL INSPECTIONS: When a special inspection is required by CBC Section 1704, the Architect or Engineer of Record shall prepare an inspection program that shall be submitted to the Building Official for approval prior to issuance of the Building Permit. The Town Special Inspection form must be completely filled-out and signed by all requested parties prior to permit issuance. Special Inspection forms are available online at www.losgatosca.gov/building.
28. BLUEPRINT FOR A CLEAN BAY SHEET: The Town standard Santa Clara Valley Nonpoint Source Pollution Control Program Sheet (page size same as submitted drawings) shall be part of the plan submittal as the second page. The specification sheet is available online at www.losgatosca.gov/building.
29. APPROVALS REQUIRED: The project requires the following departments and agencies approval before issuing a building permit:
 - a. Community Development – Planning Division: (408) 354-6874
 - b. Engineering/Parks & Public Works Department: (408) 399-5771
 - c. Santa Clara County Fire Department: (408) 378-4010
 - d. West Valley Sanitation District: (408) 378-2407
 - e. Local School District: The Town will forward the paperwork to the appropriate school district(s) for processing. A copy of the paid receipt is required prior to permit issuance.

TO THE SATISFACTION OF THE DIRECTOR OF PARKS & PUBLIC WORKS:

Engineering Division

30. GENERAL: All public improvements shall be made according to the latest adopted Town Standard Plans, Standard Specifications and Engineering Design Standards. All work shall conform to the applicable Town ordinances. The adjacent public right-of-way shall be kept clear of all job-related mud, silt, concrete, dirt and other construction debris at the end of the day. Dirt and debris shall not be washed into storm drainage facilities. The storing of goods and materials on the sidewalk and/or the street will not be allowed unless an encroachment permit is issued by the Engineering Division of the Parks and Public Works Department. The Owner's representative in charge shall be at the job site during all working hours. Failure to maintain the public right-of-way according to this condition may result in the issuance of correction notices, citations, or stop work orders and the Town performing the required maintenance at the Owner's expense.
31. APPROVAL: This application shall be completed in accordance with all the conditions of approval listed below and in substantial compliance with the latest reviewed and

approved development plans. Any changes or modifications to the approved plans or conditions of approvals shall be approved by the Town Engineer.

32. CONSTRUCTION PLAN REQUIREMENTS: Construction drawings shall comply with Section 1 (Construction Plan Requirements) of the Town's Engineering Design Standards, which are [available for download from the Town's website](#).
33. PRIOR APPROVALS: All conditions per prior approvals shall be deemed in full force and affect for this approval.
34. CHANGE OF OCCUPANCY: Prior to initial occupancy and any subsequent change in use or occupancy of any non-residential condominium space, the buyer or the new or existing occupant shall apply to the Community Development Department and obtain approval for use determination and building permit and obtain inspection approval for any necessary work to establish the use and/or occupancy consistent with that intended.
35. ENCROACHMENT PERMIT: All work in the public right-of-way will require a Construction Encroachment Permit. All work over \$5,000 will require construction security. It is the responsibility of the Owner to obtain any necessary encroachment permits from affected agencies and private parties, including but not limited to, Pacific Gas and Electric (PG&E), AT&T, Comcast, Santa Clara Valley Water District, California Department of Transportation (Caltrans). Copies of any approvals or permits must be submitted to the Town Engineering Division of the Parks and Public Works Department prior to releasing any permit.
36. FOR PLANTERS: The Owner, Applicant and/or Developer shall apply for an encroachment permit for the proposed planters within the public sidewalk and/or Town's right-of-way. The Owner, Applicant and/or Developer shall work with Parks and Public Works Department staff to arrive at a mutually agreeable solution that addresses safety and aesthetic issues. If no solution is reached, the vegetative screening requirement shall be waived. A Private Improvements in the Public Right-of-Way (formerly Indemnity) Agreement will be required if planters are proposed to be located within the Town's right-of-way. A copy of the recorded agreement shall be submitted to the Engineering Division of the Parks and Public Works Department prior to the issuance of any grading or building permits.
37. PRIVATE IMPROVEMENTS IN THE PUBLIC RIGHT-OF-WAY (INDEMNITY AGREEMENT): The property owner shall enter into an agreement with the Town for all existing and proposed private improvements within the Town's right-of-way. The Owner shall be solely responsible for maintaining the improvements in a good and safe condition at all times and shall indemnify the Town of Los Gatos. The agreement must be completed and accepted by the Director of Parks and Public Works, and subsequently recorded by the Town Clerk at the Santa Clara County Office of the Clerk-Recorder, prior to the issuance of any grading or building permits. Please note that this process may take approximately six to eight (6-8) weeks.
38. GENERAL LIABILITY INSURANCE: The property owner shall provide proof of insurance to the Town on a yearly basis. In addition to general coverage, the policy must cover all elements encroaching into the Town's right-of-way.
39. PUBLIC WORKS INSPECTIONS: The Owner, Applicant and/or Developer or their representative shall notify the Engineering Inspector at least twenty-four (24) hours

before starting any work pertaining to on-site drainage facilities, grading or paving, and all work in the Town's right-of-way. Failure to do so will result in penalties and rejection of any work that occurred without inspection.

40. **RESTORATION OF PUBLIC IMPROVEMENTS:** The Owner, Applicant and/or Developer or their representative shall repair or replace all existing improvements not designated for removal that are damaged or removed because of the Owner, Applicant and/or Developer or their representative's operations. Improvements such as, but not limited to: curbs, gutters, sidewalks, driveways, signs, pavements, raised pavement markers, thermoplastic pavement markings, etc., shall be repaired and replaced to a condition equal to or better than the original condition. Any new concrete shall be free of stamps, logos, names, graffiti, etc. Any concrete identified that is displaying a stamp or equal shall be removed and replaced at the Contractor's sole expense and no additional compensation shall be allowed therefore. Existing improvement to be repaired or replaced shall be at the direction of the Engineering Construction Inspector and shall comply with all Title 24 Disabled Access provisions. The restoration of all improvements identified by the Engineering Construction Inspector shall be completed before the issuance of a certificate of occupancy. The Owner, Applicant and/or Developer or their representative shall request a walk-through with the Engineering Construction Inspector before the start of construction to verify existing conditions.
41. **SITE SUPERVISION:** The General Contractor shall provide qualified supervision on the job site at all times during construction.
42. **STREET/SIDEWALK CLOSURE:** Any proposed blockage or partial closure of the street and/or sidewalk requires an encroachment permit. Special provisions such as limitations on works hours, protective enclosures, or other means to facilitate public access in a safe manner may be required.
43. **PLAN CHECK FEES:** Plan check fees associated with the Grading Permit shall be deposited with the Engineering Division of the Parks and Public Works Department prior to the commencement of plan check review.
44. **INSPECTION FEES:** Inspection fees shall be deposited with the Town prior to the issuance of any grading or building permits or recordation of the Parcel / Final Map.
45. **DESIGN CHANGES:** Any proposed changes to the approved plans shall be subject to the approval of the Town prior to the commencement of any and all altered work. The Owner's project engineer shall notify, in writing, the Town Engineer at least seventy-two (72) hours in advance of all the proposed changes. Any approved changes shall be incorporated into the final "as-built" plans.
46. **PLANS AND STUDIES:** All required plans and studies shall be prepared by a Registered Professional Engineer in the State of California and submitted to the Town Engineer for review and approval. Additionally, any post-project traffic or parking counts, or other studies imposed by the Planning Commission or Town Council shall be funded by the Owner, Applicant and/or Developer.
47. **GRADING PERMIT:** A grading permit is required for all site grading and drainage work except for exemptions listed in Section 12.20.015 of The Code of the Town of Los Gatos (Grading Ordinance). Grading work taking place simultaneously, on-site is considered eligible for the grading permit process and could be counted toward quantities,

depending on permit status. After the preceding Architecture and Site Application has been approved by the respective deciding body and the appeal period has passed, the grading permit application with grading plans and associated required materials shall be submitted via email to the PPW engineer assigned to the A&S review. Plan check fees (determined after initial submittal) shall be sent to the Engineering Division of the Parks and Public Works Department located at 41 Miles Avenue. The grading plans shall include topographic map/existing conditions, final grading, drainage, retaining wall location(s), driveway, utility sheet and erosion control. Grading plans shall list earthwork quantities and a table of existing and proposed impervious areas. Unless specifically allowed by the Director of Parks and Public Works, the grading permit will be issued concurrently with the building permit. The grading permit is for work outside the building footprint(s). Prior to Engineering signing off and closing out on the issued grading permit, the Owner's soils engineer shall verify, with a stamped and signed letter, that the grading activities were completed per plans and per the requirements as noted in the soils report. A separate building permit, issued by the Building Department, located at 110 E. Main Street, is needed for grading within the building footprint.

48. **GRADING PERMIT DETERMINATION DURING CONSTRUCTION DRAWINGS:** In the event that, during the production of construction drawings and/or during construction of the plans approved with this application by the Town of Los Gatos, it is determined that a grading permit would be required as described in Chapter 12, Article II (Grading Permit) of the Town Code of the Town of Los Gatos, an Architecture and Site Application would need to be submitted by the Owner for review and approval by the Development Review Committee prior to applying for a grading permit.
49. **ILLEGAL GRADING:** Per the Town's Comprehensive Fee Schedule, applications for work unlawfully completed shall be charged double the current fee. As a result, the required grading permit fees associated with an application for grading will be charged accordingly.
50. **CONSTRUCTION EASEMENT:** Prior to the issuance of a grading or building permit, it shall be the sole responsibility of the Owner, Applicant and/or Developer to obtain any and all proposed or required easements and/or permissions necessary to perform the grading herein proposed. Proof of agreement/approval is required prior to the issuance of any Permit.
51. **DRAINAGE IMPROVEMENT:** Prior to the recordation of a subdivision map (except maps for financing and conveyance purposes only) or prior to the issuance of any grading/improvement permits, whichever comes first, the Owner, Applicant and/or Developer shall: a) design provisions for surface drainage; and b) design all necessary storm drain facilities extending to a satisfactory point of disposal for the proper control and disposal of storm runoff; and c) provide a recorded copy of any required easements to the Town.
52. **TREE REMOVAL:** Copies of all necessary tree removal permits shall be provided prior to the issuance of a building permit. An arborist report may be necessary.
53. **PRECONSTRUCTION MEETING:** Prior to issuance of any grading or building permits or the commencement of any site work, the general contractor shall:

- a) Along with the Owner, Applicant and/or Developer, attend a pre-construction meeting with the Town Engineer to discuss the project conditions of approval, working hours, site maintenance and other construction matters;
 - b) Acknowledge in writing that they have read and understand the project conditions of approval and will make certain that all project sub-contractors have read and understand them as well prior to commencing any work, and that a copy of the project conditions of approval will be posted on-site at all times during construction.
54. DELAYED/DEFERRED REPORTS AND REVIEWS: TLGPPW strongly recommend that reports requiring a peer review be submitted and completed prior to committee approval/building permit stage. Note that these reviews may require a design change by the applicant and/or additional studies. Applicants who chose to defer assume risk that required changes may send project back to planning stage.
55. WATER METER: The existing water meter, currently located within the Town of Los Gatos right-of-way, shall be relocated within the property in question, directly behind the public right-of-way line. The Owner, Applicant and/or Developer shall repair and replace to existing Town standards any portion of concrete flatwork within said right-of-way that is damaged during this activity prior to issuance of a certificate of occupancy.
56. SANITARY SEWER CLEANOUT: The existing sanitary sewer cleanout, currently located within the Town of Los Gatos right-of-way, shall be relocated within the property in question, within one (1) foot of the property line per West Valley Sanitation District Standard Drawing 3, or at a location specified by the Town. The Owner, Applicant and/or Developer shall repair and replace to existing Town standards any portion of concrete flatwork within said right-of-way that is damaged during this activity prior to issuance of a certificate of occupancy.
57. CERTIFICATE OF OCCUPANCY: The Engineering Division of the Parks and Public Works Department will not sign off on a Temporary Certificate of Occupancy or a Final Certificate of Occupancy until all required improvements within the Town's right-of-way have been completed and approved by the Town.
58. UTILITIES: The Owner, Applicant and/or Developer shall install all new, relocated, or temporarily removed utility services, including telephone, electric power and all other communications lines underground, as required by Town Code Section 27.50.015(b). All new utility services shall be placed underground. Underground conduit shall be provided for cable television service. The Owner, Applicant and/or Developer is required to obtain approval of all proposed utility alignments from any and all utility service providers before a Certificate of Occupancy for any new building can be issued. The Town of Los Gatos does not approve or imply approval for final alignment or design of these facilities.
59. UTILITY SETBACKS: House foundations shall be set back from utility lines a sufficient distance to allow excavation of the utility without undermining the house foundation. The Town Engineer shall determine the appropriate setback based on the depth of the utility, input from the project soils engineer, and the type of foundation.
60. UTILITY EASEMENTS: Deed restrictions shall be placed on lots containing utility easements. The deed restrictions shall specify that no trees, fences, structures or hardscape are allowed within the easement boundaries, and that maintenance access must be provided. The Town will prepare the deed language and the Owner's surveyor

shall prepare the legal description and plat. The Owner, Applicant and/or Developer shall pay any recordation costs. The documents shall be recorded before any grading or permits are issued.

61. **SIDEWALK REPAIR:** The Owner, Applicant and/or Developer shall repair and replace to existing Town standards any sidewalk damaged now or during construction of this project. All new and existing adjacent infrastructure must meet current ADA standards. Sidewalk repair shall match existing color, texture and design, and shall be constructed per Town Standard Details. New concrete shall be free of stamps, logos, names, graffiti, etc. Any concrete identified that is displaying a stamp or equal shall be removed and replaced at the Contractor's sole expense and no additional compensation shall be allowed therefore. The limits of sidewalk repair will be determined by the Engineering Construction Inspector during the construction phase of the project. The improvements must be completed and accepted by the Town before a Certificate of Occupancy for any new building can be issued.
62. **CURB AND GUTTER REPAIR:** The Owner, Applicant and/or Developer shall repair and replace to existing Town standards any curb and gutter damaged now or during construction of this project. All new and existing adjacent infrastructure must meet Town standards. New curb and gutter shall be constructed per Town Standard Details. New concrete shall be free of stamps, logos, names, graffiti, etc. Any concrete identified that is displaying a stamp or equal shall be removed and replaced at the Contractor's sole expense and no additional compensation shall be allowed therefore. The limits of curb and gutter repair will be determined by the Engineering Construction Inspector during the construction phase of the project. The improvements must be completed and accepted by the Town before a Certificate of Occupancy for any new building can be issued.
63. **VALLEY GUTTER REPAIR:** The Owner/Applicant shall repair and replace to existing Town standards any valley gutter damaged now or during construction of this project. All new and existing adjacent infrastructure must meet Town standards. New valley gutter shall be constructed per Town Standard Details. New concrete shall be free of stamps, logos, names, graffiti, etc. Any concrete identified that is displaying a stamp or equal shall be removed and replaced at the Contractor's sole expense and no additional compensation shall be allowed therefore. The limits of valley gutter repair will be determined by the Engineering Construction Inspector during the construction phase of the project. The improvements must be completed and accepted by the Town before a Certificate of Occupancy for any new building can be issued.
64. **FENCING:** Any fencing proposed within two hundred (200) feet of an intersection shall comply with Town Code Section §23.10.080.
65. **FENCES:** Fences between all adjacent parcels will need to be located on the property lines/boundary lines. Any existing fences that encroach into the neighbor's property will need to be removed and replaced to the correct location of the boundary lines before a Certificate of Occupancy for any new building can be issued. Waiver of this condition will require signed and notarized letters from all affected neighbors.
66. **CONSTRUCTION VEHICLE PARKING:** Construction vehicle parking within the public right-of-way will only be allowed if it does not cause access or safety problems as determined by the Town.

67. CONSTRUCTION VEHICLE PARKING: No construction vehicles, trucks, equipment and worker vehicles shall be allowed to park on the portion of any public (Town) streets without written approval from the Town Engineer.
68. ADVANCE NOTIFICATION: Advance notification of all affected residents and emergency services shall be made regarding parking restriction, lane closure or road closure, with specification of dates and hours of operation.
69. HAULING OF SOIL: Hauling of soil on- or off-site shall not occur during the morning or evening peak periods (between 7:00 a.m. and 9:00 a.m. and between 4:00 p.m. and 6:00 p.m.), and at other times as specified by the Director of Parks and Public Works. Prior to the issuance of a grading or building permit, the Owner and/or Applicant or their representative shall work with the Town Building Department and Engineering Division Inspectors to devise a traffic control plan to ensure safe and efficient traffic flow under periods when soil is hauled on or off the project site. This may include, but is not limited to provisions for the Owner and/or Applicant to place construction notification signs noting the dates and time of construction and hauling activities, or providing additional traffic control. Coordination with other significant projects in the area may also be required. Cover all trucks hauling soil, sand and other loose debris.
70. CONSTRUCTION HOURS: All subdivision improvements and site improvements construction activities, including the delivery of construction materials, labors, heavy equipment, supplies, etc., shall be limited to the hours of 8:00 a.m. to 6:00 p.m., weekdays and 9:00 a.m. to 4:00 p.m. Saturdays. The Town may authorize, on a case-by-case basis, alternate construction hours. The Owner, Applicant and/or Developer shall provide written notice twenty-four (24) hours in advance of modified construction hours. Approval of this request is at discretion of the Town.
71. CONSTRUCTION NOISE: Between the hours of 8:00 a.m. to 6:00 p.m., weekdays and 9:00 a.m. to 4:00 p.m. Saturdays, construction, alteration or repair activities shall be allowed. No individual piece of equipment shall produce a noise level exceeding eighty-five (85) dBA at twenty-five (25) feet from the source. If the device is located within a structure on the property, the measurement shall be made at distances as close to twenty-five (25) feet from the device as possible. The noise level at any point outside of the property plane shall not exceed eighty-five (85) dBA.
72. CONSTRUCTION MANAGEMENT PLAN SHEET: Prior to the issuance of any grading or building permits, the Owner and/or Applicant's design consultant shall submit a construction management plan sheet (full-size) within the plan set that shall incorporate at a minimum the Earth Movement Plan, Traffic Control Plan, Project Schedule, site security fencing, employee parking, construction staging area, materials storage area(s), construction trailer(s), concrete washout(s) and proposed outhouse locations. Please refer to the Town's [Construction Management Plan Guidelines](#) document for additional information.
73. NPDES STORMWATER COMPLIANCE: In the event that, during the production of construction drawings for the plans approved with this application by the Town of Los Gatos, it is determined that the project will create and/or replace more than 2,500 square feet of impervious area, completion of the NPDES Stormwater Compliance Small Projects Worksheet and implementation of at least one of the six low impact development site

design measures it specifies shall be completed and submitted to the Engineering Division before issuance of a grading/building permit.

74. SITE DESIGN MEASURES: All projects shall incorporate at least one of the following measures:
 - a) Protect sensitive areas and minimize changes to the natural topography.
 - b) Minimize impervious surface areas.
 - c) Direct roof downspouts to vegetated areas.
 - d) Use porous or pervious pavement surfaces on the driveway, at a minimum.
 - e) Use landscaping to treat stormwater.
75. LANDSCAPING: In finalizing the landscape plan for the biotreatment area(s), it is recommended that the landscape architect ensure that the characteristics of the selected plants are similar to those of the plants listed for use in bioretention areas in Appendix D of the Santa Clara Valley Urban Runoff Pollution Prevention Program (SCVURPPP) C.3 Stormwater Handbook.
76. LANDSCAPE MAINTENANCE AGREEMENT: The Owner and/or Applicant shall enter into a Landscape Maintenance Agreement with the Town of Los Gatos in which the Owner and/or Applicant agrees to maintain the vegetated areas along the project's Street Name frontage located within the public right-of-way. The agreement must be completed and accepted by the Town Attorney prior to the issuance of any grading or building permits.
77. DUST CONTROL: Blowing dust shall be reduced by timing construction activities so that paving and building construction begin as soon as possible after completion of grading, and by landscaping disturbed soils as soon as possible. Further, water trucks shall be present and in use at the construction site. All portions of the site subject to blowing dust shall be watered as often as deemed necessary by the Town, or a minimum of three (3) times daily, or apply (non-toxic) soil stabilizers on all unpaved access roads, parking areas, and staging areas at construction sites in order to insure proper control of blowing dust for the duration of the project. Watering on public streets shall not occur. Streets shall be cleaned by street sweepers or by hand as often as deemed necessary by the Town Engineer, or at least once a day. Watering associated with on-site construction activity shall take place between the hours of 8 a.m. and 5 p.m. and shall include at least one (1) late-afternoon watering to minimize the effects of blowing dust. All public streets soiled or littered due to this construction activity shall be cleaned and swept on a daily basis during the workweek to the satisfaction of the Town. Demolition or earthwork activities shall be halted when wind speeds (instantaneous gusts) exceed twenty (20) miles per hour (MPH). All trucks hauling soil, sand, or other loose debris shall be covered.
78. DETAILING OF STORMWATER MANAGEMENT FACILITIES: Prior to the issuance of any grading or building permits, all pertinent details of any and all proposed stormwater management facilities, including, but not limited to, ditches, swales, pipes, bubble-ups, dry wells, outfalls, infiltration trenches, detention basins and energy dissipaters, shall be provided on submitted plans, reviewed by the Engineering Division of the Parks and Public Works Department, and approved for implementation.
79. OFF-SITE DRAINAGE: The Owner, Applicant and/or Developer shall construct and install a private on-site storm drain system that is adequately sized to collect and convey adjacent off-site tributary drainage. Hydraulic calculations for a 100-year storm event shall provide

documentation that the proposed storm drain system can convey said off-site drainage as well as on-site drainage during this event over, within, through and off the site, and ultimately into the Town's storm drain system.

80. MAINTENANCE OF PRIVATE STREETS: It is the responsibility of the property owner(s)/homeowners association to implement a plan for street sweeping of paved private roads and cleaning of all storm drain inlets.
81. SILT AND MUD IN PUBLIC RIGHT-OF-WAY: It is the responsibility of Contractor and homeowner to make sure that all dirt tracked into the public right-of-way is cleaned up on a daily basis. Mud, silt, concrete and other construction debris SHALL NOT be washed into the Town's storm drains.
82. PERMIT ISSUANCE: Permits for each phase; reclamation, landscape, and grading, shall be issued simultaneously.
83. COVERED TRUCKS: All trucks transporting materials to and from the site shall be covered.

TO THE SATISFACTION OF THE SANTA CLARA COUNTY FIRE DEPARTMENT:

84. FIRE SPRINKLERS REQUIRED: *(As Noted on Sheet A1)* Approved automatic sprinkler systems in new and existing buildings and structures shall be provided in the locations described in this Section or in Sections 903.2.1 through 903.2.12 whichever is the more restrictive and Sections 903.2.14 through 903.2.21. For the purposes of this section, firewalls and fire barriers used to separate building areas shall be constructed in accordance with the California Building Code and shall be without openings or penetrations. 1. An automatic sprinkler system shall be provided throughout all new buildings and structures, other than Group R occupancies, except as follows: a. Buildings and structures not located in any Wildland-Urban Interface and not exceeding 1,200 square feet of fire area. b. Buildings and structures located in any Wildland-Urban Interface Fire Area and not exceeding 500 square feet of fire area. c. Group S-2 or U occupancies, including photovoltaic support structures, used exclusively for vehicle parking which meet all of the following: i. Noncombustible construction. ii. Maximum 5,000 square feet in building area. iii. Structure is open on not less than three (3) sides nor 75% of structure perimeter. iv. Minimum of 10 feet separation from existing buildings, or similar structures, unless area is separated by fire walls complying with California Building Code 706. d. Canopies, constructed in accordance with CBC 406.7.2, used exclusively for weather protection of vehicle fueling pads per CBC 406.7.1 and not exceeding 5,000 square feet of fire area. 2. An automatic sprinkler system shall be installed throughout all new buildings with a Group R fire area. Exception: Accessory Dwelling Unit, provided that all of the following are met: a. The unit meets the definition of an Accessory Dwelling Unit as defined in the Government Code Section 65852.2. b. The existing primary residence does not have automatic fire sprinklers. c. The accessory dwelling unit does not exceed 1,200 square feet in size. d. The unit is on the same lot as the primary residence. e. The unit meets all apparatus access and water supply requirements of Chapter 5 and Appendix B of the 2022 California Fire Code. 3. An approved automatic fire sprinkler system shall be installed in new manufactured homes (as defined in California Health and Safety Code Sections 18007 and 18009) and multifamily manufactured homes with two dwelling units (as defined in California Health and Safety Code Section 18008.7) in accordance with Title

25 of the California Code of Regulations. 4. An automatic sprinkler system shall be installed throughout existing buildings with a Group R fire area when additions are made causing the fire area to exceed 3,600 square feet. Exception: Additions where all of the following are met: a. Building addition does not exceed 500 square feet. b. The resultant structure meets all water supply requirements of Chapter 5 and Appendix B of the 2022 California Fire Code. 5. An automatic sprinkler system shall be provided throughout existing Group A, B, E, F, L, M, S and U buildings and structures, when additions are made that increase the fire area to more than 3,600 square feet or that create conditions described in Sections 903.2.1 through 903.2.18. 6. Any change in the character of occupancy or in use of any building with a fire area equal to or greater than 3,600 square feet which, in the opinion of the fire code official or building official, would place the building into a more hazardous division of the same occupancy group or into a different group of occupancies and constitutes a greater degree of life safety 1 or increased fire risk 2, shall require the installation of an approved fire automatic fire sprinkler system. *Sprinklers require for new house.*

85. REQUIRED FIRE FLOW: *(Letter received)* The minimum required fireflow for this project is 500 Gallons Per Minute (GPM) at 20 psi residual pressure. This fireflow assumes installation of automatic fire sprinklers per CFC [903.3.1.3]
86. WATER SUPPLY REQUIREMENT: *(As Noted on Sheet A1)* Potable water supplies shall be protected from contamination caused by fire protection water supplies. It is the responsibility of the applicant and any contractors and subcontractors to contact the water purveyor supplying the site of such project, and to comply with the requirements of that purveyor. Such requirements shall be incorporated into the design of any water-based fire protection systems, and/or fire suppression water supply systems or storage containers that may be physically connected in any manner to an appliance capable of causing contamination of the potable water supply of the purveyor of record. Final approval of the system(s) under consideration will not be granted by this office until compliance with the requirements of the water purveyor of record are documented by that purveyor as having been met by the applicant(s). 2019 CFC Sec. 903.3.5 and Health and Safety Code 13114.7.
87. ADDRESS IDENTIFICATION: *(As Noted on Sheet A1)* New and existing buildings shall have approved address numbers, building numbers or approved building identification placed in a position that is plainly legible and visible from the street or road fronting the property. These numbers shall contrast with their background. Where required by the fire code official, address numbers shall be provided in additional approved locations to facilitate emergency response. Address numbers shall be Arabic numbers or alphabetical letters. Numbers shall be a minimum of 4 inches (101.6 mm) high with a minimum stroke width of 0.5 inch (12.7 mm). Where access is by means of a private road and the building cannot be viewed from the public way, a monument, pole or other sign or means shall be used to identify the structure. Address numbers shall be maintained. CFC Sec. 505.1.
88. CONSTRUCTION SITE FIRE SAFETY: *(As Noted on Sheet A1)* All construction sites must comply with applicable provisions of the CFC Chapter 33 and our Standard Detail and Specification S1-7. Provide appropriate notations on subsequent plan submittals, as appropriate to the project. CFC Chp. 33.