



**TOWN OF LOS GATOS**  
COMMUNITY DEVELOPMENT DEPARTMENT  
PLANNING DIVISION  
(408) 354-6872 Fax (408) 354-7593

CIVIC CENTER  
110 E. MAIN STREET  
LOS GATOS, CA 95030

July 12, 2022

Edick Lazari  
6154 Royal Acorn Place  
San Jose, CA 95120  
Via Email

**RE: 17291 Wedgewood Avenue**  
**Architecture and Site Application S-21-027**

**Requesting Approval for Construction of a New Single-Family Residence and Site Improvements  
Requiring a Grading Permit on Property Zoned R-1:8. APN 409-14-013.**

**PROPERTY OWNER: Young Kim**  
**APPLICANT: Edick Lazari**

At its meeting of July 12, 2022, the Town of Los Gatos Development Review Committee approved the above referenced application subject to the enclosed amended draft conditions.

PLEASE NOTE: Pursuant to Section 29.20.257 of the Town Code, this approval may be appealed to the Planning Commission within 10 days of the date the approval is granted. Therefore, this decision should not be considered final and no permits by the Town will be issued until the appeal period has passed.

All approvals will expire two years from the date of approval (July 12, 2024), unless the approval has been vested. Section 29.20.335 of the Town Code defines what constitutes vesting an approval. Reasonable extensions of the time not exceeding one year may be granted upon application to and approval by the Development Review Committee. Extensions can be granted only if approved by the Committee prior to the expiration of the approval. Therefore, it is recommended that applications for a time extension be filed with the Community Development Department at least 60 days prior to the expiration of the approval.

If you have any questions, please contact Sean Mullin at [SMullin@losgatosca.gov](mailto:SMullin@losgatosca.gov).

Sincerely,

Sean Mullin, AICP  
Senior Planner

cc: Young Kim, via email

**DEVELOPMENT REVIEW COMMITTEE – July 12, 2022**  
**CONDITIONS OF APPROVAL**

**17291 Wedgewood Avenue**  
**Architecture and Site Application S-21-027**

**Requesting Approval for Construction of a New Single-Family Residence and Site Improvements Requiring a Grading Permit on Property Zoned R-1:8.**  
**APN 409-14-013.**

**PROPERTY OWNER: Young Kim**  
**APPLICANT: Edick Lazari**  
**PROJECT PLANNER: Sean Mullin**

TO THE SATISFACTION OF THE DIRECTOR OF COMMUNITY DEVELOPMENT:

*Planning Division*

1. **APPROVAL:** This application shall be completed in accordance with all of the conditions of approval and in substantial compliance with the approved plans. Any changes or modifications to the approved plans and/or business operation shall be approved by the Community Development Director, DRC or the Planning Commission depending on the scope of the changes.
2. **EXPIRATION:** The approval will expire two years from the approval date pursuant to Section 29.20.320 of the Town Code, unless the approval has been vested.
3. **STORY POLES:** The story poles on the project site shall be removed within 30 days of approval of the Architecture & Site application.
4. **ACCESSORY DWELLING UNIT PERMIT:** An approved accessory dwelling unit (ADU) permit shall be obtained to reclassify the existing residence as an ADU prior to issuance of Building and/or Grading Permits.
5. **OUTDOOR LIGHTING:** Exterior lighting shall be kept to a minimum, and shall be down directed fixtures that will not reflect or encroach onto adjacent properties. No flood lights shall be used unless it can be demonstrated that they are needed for safety or security.
6. **TREE REMOVAL PERMIT:** A Tree Removal Permit shall be obtained for any trees to be removed, prior to the issuance of a building or grading permit.
7. **EXISTING TREES:** All existing trees shown on the plan and trees required to remain or to be planted are specific subjects of approval of this plan, and must remain on the site.
8. **ARBORIST REQUIREMENTS:** The developer shall implement, at their cost, all recommendations identified in the Arborist's report for the project, on file in the Community Development Department. These recommendations must be incorporated in the building permit plans and completed prior to issuance of a building permit where applicable.
9. **TREE FENCING:** Protective tree fencing and other protection measures shall be placed at the drip line of existing trees prior to issuance of demolition and building permits and shall

- remain through all phases of construction. Include a tree protection plan with the construction plans.
10. TREE STAKING: All newly planted trees shall be double-staked using rubber tree ties.
  11. FRONT YARD LANDSCAPE: Prior to issuance of a Certificate of Occupancy the front yard must be landscaped.
  12. WATER EFFICIENCY LANDSCAPE ORDINANCE: The final landscape plan shall meet the Town of Los Gatos Water Conservation Ordinance or the State Water Efficient Landscape Ordinance, whichever is more restrictive. A review fee based on the current fee schedule adopted by the Town Council is required when working landscape and irrigation plans are submitted for review.
  13. UNPERMITTED WORK: Prior to issuance of a Building or Grading Permit, the property owner or authorized agent shall obtain all permits required for any work found to be completed without the benefit of permits and shall pay all associated fees and penalties.
  14. WINDOWS: The windows on the west elevation of the upper story shall not exceed two-feet, six-inches by two-feet, six-inches and the glass in these windows be obscured or frosted.
  15. BATHROOM WINDOWS: The second-floor bathroom window on the left (west) side elevations shall be use obscured or frosted glass.
  16. PRIVACY SCREEN: Provide mature tree planting for privacy screening along the shared property line with 14344 La Rinconada Drive.
  17. TOWN INDEMNITY: Applicants are notified that Town Code Section 1.10.115 requires that any applicant who receives a permit or entitlement from the Town shall defend, indemnify, and hold harmless the Town and its officials in any action brought by a third party to overturn, set aside, or void the permit or entitlement. This requirement is a condition of approval of all such permits and entitlements whether or not expressly set forth in the approval, and may be secured to the satisfaction of the Town Attorney.
  18. COMPLIANCE MEMORANDUM: A memorandum shall be prepared and submitted with the building plans detailing how the Conditions of Approval will be addressed.

#### *Building Division*

19. PERMITS REQUIRED: A Building Permit is required for the construction of the new single-family residence and attached garage. An additional Building Permit will be required for the PV System if the system is required by the California Energy Code.
20. APPLICABLE CODES: The current codes, as amended and adopted by the Town of Los Gatos as of January 1, 2020, are the 2019 California Building Standards Code, California Code of Regulations Title 24, Parts 1-12, including locally adopted Energy Reach Codes.
21. CONDITIONS OF APPROVAL: The Conditions of Approval must be blue lined in full on the cover sheet of the construction plans. A Compliance Memorandum shall be prepared and submitted with the building permit application detailing how the Conditions of Approval will be addressed.
22. BUILDING & SUITE NUMBERS: Submit requests for new building addresses to the Building Division prior to submitting for the building permit application process.
23. SIZE OF PLANS: Minimum size 24" x 36", maximum size 30" x 42".

24. **SOILS REPORT:** A Soils Report, prepared to the satisfaction of the Building Official, containing foundation and retaining wall design recommendations, shall be submitted with the Building Permit Application. This report shall be prepared by a licensed Civil Engineer specializing in soils mechanics.
25. **SHORING:** Shoring plans and calculations will be required for all excavations which exceed five (5) feet in depth or which remove lateral support from any existing building, adjacent property, or the public right-of-way. Shoring plans and calculations shall be prepared by a California licensed engineer and shall confirm to the Cal/OSHA regulations.
26. **FOUNDATION INSPECTIONS:** A pad certificate prepared by a licensed civil engineer or land surveyor shall be submitted to the project Building Inspector at foundation inspection. This certificate shall certify compliance with the recommendations as specified in the Soils Report, and that the building pad elevations and on-site retaining wall locations and elevations have been prepared according to the approved plans. Horizontal and vertical controls shall be set and certified by a licensed surveyor or registered Civil Engineer for the following items:
  - a. Building pad elevation
  - b. Finish floor elevation
  - c. Foundation corner locations
  - d. Retaining wall(s) locations and elevations
27. **TITLE 24 ENERGY COMPLIANCE:** All required California Title 24 Energy Compliance Forms must be blue-lined (sticky-backed), i.e. directly printed, onto a plan sheet.
28. **TOWN RESIDENTIAL ACCESSIBILITY STANDARDS:** New residential units shall be designed with adaptability features for single-family residences per Town Resolution 1994-61:
  - a. Wood backing (2" x 8" minimum) shall be provided in all bathroom walls, at water closets, showers, and bathtubs, located 34 inches from the floor to the center of the backing, suitable for the installation of grab bars if needed in the future.
  - b. All passage doors shall be at least 32-inch wide doors on the accessible floor level.
  - c. The primary entrance door shall be a 36-inch-wide door including a 5'x 5' level landing, no more than 1 inch out of plane with the immediate interior floor level and with an 18-inch clearance at interior strike edge.
  - d. A door buzzer, bell or chime shall be hard wired at primary entrance.
29. **BACKWATER VALVE:** The scope of this project may require the installation of a sanitary sewer backwater valve per Town Ordinance 6.50.025. Please provide information on the plans if a backwater valve is required and the location of the installation. The Town of Los Gatos Ordinance and West Valley Sanitation District (WVSD) requires backwater valves on drainage piping serving fixtures that have flood level rims less than 12 inches above the elevation of the next upstream manhole.
30. **HAZARDOUS FIRE ZONE:** All projects in the Town of Los Gatos require Class A roof assemblies.
31. **SPECIAL INSPECTIONS:** When a special inspection is required by CBC Section 1704, the Architect or Engineer of Record shall prepare an inspection program that shall be submitted to the Building Official for approval prior to issuance of the Building Permit. The Town Special Inspection form must be completely filled-out and signed by all requested

parties prior to permit issuance. Special Inspection forms are available from the Building Division Service Counter or online at [www.losgatosca.gov/building](http://www.losgatosca.gov/building).

32. BLUEPRINT FOR A CLEAN BAY SHEET: The Town standard Santa Clara Valley Nonpoint Source Pollution Control Program Sheet (page size same as submitted drawings) shall be part of the plan submittal as the second page. The specification sheet is available at the Building Division Service Counter for a fee of \$2 or at ARC Blueprint for a fee or online at [www.losgatosca.gov/building](http://www.losgatosca.gov/building).
33. APPROVALS REQUIRED: The project requires the following departments and agencies approval before issuing a building permit:
  - a. Community Development – Planning Division: (408) 354-6874
  - b. Engineering/Parks & Public Works Department: (408) 399-5771
  - c. Santa Clara County Fire Department: (408) 378-4010
  - d. West Valley Sanitation District: (408) 378-2407
  - e. Local School District: The Town will forward the paperwork to the appropriate school district(s) for processing. A copy of the paid receipt is required prior to permit issuance.

TO THE SATISFACTION OF THE DIRECTOR OF PARKS & PUBLIC WORKS:

*Engineering Division*

34. GENERAL: All public improvements shall be made according to the latest adopted Town Standard Plans, Standard Specifications and Engineering Design Standards. All work shall conform to the applicable Town ordinances. The adjacent public right-of-way shall be kept clear of all job-related mud, silt, concrete, dirt and other construction debris at the end of the day. Dirt and debris shall not be washed into storm drainage facilities. The storing of goods and materials on the sidewalk and/or the street will not be allowed unless an encroachment permit is issued by the Engineering Division of the Parks and Public Works Department. The Owner and/or Applicant's representative in charge shall be at the job site during all working hours. Failure to maintain the public right-of-way according to this condition may result in the issuance of correction notices, citations, or stop work orders and the Town performing the required maintenance at the Owner and/or Applicant's expense.
35. APPROVAL: This application shall be completed in accordance with all the conditions of approval listed below and in substantial compliance with the latest reviewed and approved development plans. Any changes or modifications to the approved plans or conditions of approvals shall be approved by the Town Engineer.
36. CONSTRUCTION PLAN REQUIREMENTS: Construction drawings shall comply with Section 1 (Construction Plan Requirements) of the Town's Engineering Design Standards, which are available for download from the Town's website.
37. ENCROACHMENT PERMIT: All work in the public right-of-way will require a Construction Encroachment Permit. All work over \$5,000 will require construction security. It is the responsibility of the Owner/Applicant to obtain any necessary encroachment permits from affected agencies and private parties, including but not limited to, Pacific Gas and Electric (PG&E), AT&T, Comcast, Santa Clara Valley Water District, California Department of

Transportation (Caltrans). Copies of any approvals or permits must be submitted to the Town Engineering Division of the Parks and Public Works Department prior to releasing any permit.

38. **RESTORATION OF PUBLIC IMPROVEMENTS:** The Owner and/or Applicant or their representative shall repair or replace all existing improvements not designated for removal that are damaged or removed because of the Owner and/or Applicant or their representative's operations. Improvements such as, but not limited to: curbs, gutters, sidewalks, driveways, signs, pavements, raised pavement markers, thermoplastic pavement markings, etc., shall be repaired and replaced to a condition equal to or better than the original condition. Any new concrete shall be free of stamps, logos, names, graffiti, etc. Any concrete identified that is displaying a stamp or equal shall be removed and replaced at the Contractor's sole expense and no additional compensation shall be allowed therefore. Existing improvement to be repaired or replaced shall be at the direction of the Engineering Construction Inspector and shall comply with all Title 24 Disabled Access provisions. The restoration of all improvements identified by the Engineering Construction Inspector shall be completed before the issuance of a certificate of occupancy. The Owner and/or Applicant or their representative shall request a walk-through with the Engineering Construction Inspector before the start of construction to verify existing conditions.
39. **STREET CLOSURE:** Any proposed blockage or partial closure of the street requires an encroachment permit. Special provisions such as limitations on works hours, protective enclosures, or other means to facilitate public access in a safe manner may be required.
40. **DRIVEWAY:** The driveway conform to existing pavement on Wedgewood Avenue shall be constructed in a manner such that the existing drainage patterns will not be obstructed.
41. **PUBLIC IMPROVEMENTS:** The following improvements shall be installed by the Owner and/or Applicant. Plans for those improvements shall be prepared by a California registered civil engineer, reviewed and approved by the Town, before the issuance of any grading or building permits. The improvements must be completed and accepted by the Town before a Certificate of Occupancy for any new building can be issued.
  - a. Wedgewood Avenue: signing, striping, and sanitary sewers, as required.
  - b. Wedgewood Avenue: 2" overlay from the centerline to the northern edge of pavement, or alternative pavement restoration measure as approved by the Town Engineer.
42. **SITE SUPERVISION:** The General Contractor shall provide qualified supervision on the job site at all times during construction.
43. **PLAN CHECK FEES:** Plan check fees associated with the Grading Permit shall be deposited with the Engineering Division of the Parks and Public Works Department prior to the commencement of plan check review.
44. **GRADING PERMIT FEES:** All fees associated with the grading permit shall be deposited with the Engineering Division of the Parks and Public Works Department prior to the issuance of a grading permit.
45. **GRADING PERMIT:** A grading permit is required for all site grading and drainage work except for exemptions listed in Section 12.20.015 of The Code of the Town of Los Gatos (Grading Ordinance). After the preceding Architecture and Site Application has been

approved by the respective deciding body, the grading permit application (with grading plans and associated required materials and plan check fees) shall be made to the Engineering Division of the Parks and Public Works Department located at 41 Miles Avenue. The grading plans shall include final grading, drainage, retaining wall location(s), driveway, utilities and interim erosion control. Grading plans shall list earthwork quantities and a table of existing and proposed impervious areas. Unless specifically allowed by the Director of Parks and Public Works, the grading permit will be issued concurrently with the building permit. The grading permit is for work outside the building footprint(s). Prior to Engineering signing off and closing out on the issued grading permit, the Owner/Applicant's soils engineer shall verify, with a stamped and signed letter, that the grading activities were completed per plans and per the requirements as noted in the soils report. A separate building permit, issued by the Building Department, located at 110 E. Main Street, is needed for grading within the building footprint.

46. DESIGN CHANGES: Any proposed changes to the approved plans shall be subject to the approval of the Town prior to the commencement of any and all altered work. The Owner and/or Applicant's project engineer shall notify, in writing, the Town Engineer at least seventy-two (72) hours in advance of all the proposed changes. Any approved changes shall be incorporated into the final "as-built" plans.
47. PLANS AND STUDIES: Any studies imposed by the Planning Commission or Town Council shall be funded by the Owner and/or Applicant.
48. DRAINAGE IMPROVEMENT: Prior to the issuance of any grading/improvement permits, whichever comes first, the Owner and/or Applicant shall: a) design provisions for surface drainage; and b) design all necessary storm drain facilities extending to a satisfactory point of disposal for the proper control and disposal of storm runoff; and c) provide a recorded copy of any required easements to the Town.
49. PRECONSTRUCTION MEETING: Prior to the commencement of any site work, the general contractor shall:
  - a. Along with the Owner and/or Applicant, attend a pre-construction meeting with the Town Engineer to discuss the project conditions of approval, working hours, site maintenance and other construction matters;
  - b. Acknowledge in writing that they have read and understand the project conditions of approval and will make certain that all project sub-contractors have read and understand them as well prior to commencing any work, and that a copy of the project conditions of approval will be posted on-site at all times during construction.
50. DEDICATIONS: The following shall be dedicated by separate instrument. The dedication shall be recorded before any grading or building permits are issued:
  - a. Wedgewood Avenue: Thirty (30) feet of property frontage immediately adjacent to the current Wedgewood Avenue right-of-way (which currently extends to the centerline) shall be dedicated in fee.
51. SOILS REPORT: One electronic copy (PDF) of the soils and geologic report shall be submitted with the application. The soils report shall include specific criteria and standards governing site grading, drainage, pavement design, retaining wall design, and erosion control. The reports shall be signed and "wet stamped" by the engineer or

geologist, in conformance with Section 6735 of the California Business and Professions Code.

52. **SOILS ENGINEER CONSTRUCTION OBSERVATION:** During construction, all excavations and grading shall be inspected by the Owner and/or Applicant's soils engineer prior to placement of concrete and/or backfill so they can verify that the actual conditions are as anticipated in the design-level geotechnical report and recommend appropriate changes in the recommendations contained in the report, if necessary. The results of the construction observation and testing shall be documented in an "as-built" letter/report prepared by the Owner and/or Applicant's soils engineer and submitted to the Town before a certificate of occupancy is granted.
53. **SOIL RECOMMENDATIONS:** The project shall incorporate the geotechnical/geological recommendations contained in the project's design-level geotechnical/geological investigation as prepared by the Owner and/or Applicant's engineer(s), and any subsequently required report or addendum. Subsequent reports or addendum are subject to peer review by the Town's consultant and costs shall be borne by the Owner and/or Applicant.
54. **WATER METER:** The existing water meter, currently located within the Wedgewood Avenue right-of-way, shall be relocated within the property in question, directly behind the public right-of-way line after the dedication required as part of this application. The Owner and/or Applicant shall repair and replace to existing Town standards any portion of concrete flatwork within said right-of-way that is damaged during this activity prior to issuance of a certificate of occupancy.
55. **SANITARY SEWER CLEANOUT:** The existing sanitary sewer cleanout, currently located within the Wedgewood Avenue right-of-way, shall be relocated within the property in question, within one (1) foot of the property line per West Valley Sanitation District Standard Drawing 3, or at a location specified by the Town. The Owner and/or Applicant shall repair and replace to existing Town standards any portion of concrete flatwork within said right-of-way that is damaged during this activity prior to issuance of a certificate of occupancy.
56. **CERTIFICATE OF OCCUPANCY:** The Engineering Division of the Parks and Public Works Department will not sign off on a Temporary Certificate of Occupancy or a Final Certificate of Occupancy until all required improvements within the Town's right-of-way have been completed and approved by the Town.
57. **FRONTAGE IMPROVEMENTS:** The Owner and/or Applicant shall be required to improve the project's public frontage (right-of-way line to centerline and/or to limits per the direction of the Town Engineer) to current Town Standards. These improvements may include but not limited to curb, gutter, sidewalk, driveway approach(es), curb ramp(s), signs, pavement, raised pavement markers, thermoplastic pavement markings, storm drain facilities, traffic signal(s), street lighting (upgrade and/or repaint) etc. The improvements must be completed and accepted by the Town before a Certificate of Occupancy for any new building can be issued.
58. **UTILITIES:** The Owner and/or Applicant shall install all new, relocated, or temporarily removed utility services, including telephone, electric power and all other communications lines underground, as required by Town Code Section 27.50.015(b). All new utility services

shall be placed underground. Underground conduit shall be provided for cable television service. The Owner and/or Applicant is required to obtain approval of all proposed utility alignments from any and all utility service providers before a Certificate of Occupancy for any new building can be issued. The Town of Los Gatos does not approve or imply approval for final alignment or design of these facilities.

59. SIDEWALK/CURB IN-LIEU FEE: A curb and sidewalk in-lieu fee of \$12,880.00 shall be paid prior to issuance of a grading or building permit. This fee is based on 92 linear feet of curb at \$68.00 per linear foot and 414 square feet of 4.5-foot wide sidewalk at \$16.00 per square foot in accordance with Town policy and the Town's Comprehensive Fee Schedule. The final curb and sidewalk in-lieu fee for this project shall be calculated using the current fee schedule and rate schedule in effect at the time the fee is paid.
60. TRAFFIC IMPACT MITIGATION FEE: Prior to the issuance of any building/grading permit(s), the Owner/Applicant shall pay the project's proportional share of transportation improvements needed to serve cumulative development within the Town of Los Gatos. The fee shall be paid before issuance of any grading or building permit. The final traffic impact mitigation fee for this project shall be calculated from the final plans using the current fee schedule and rate schedule in effect at the time, using a comparison between the existing and proposed uses.
61. CONSTRUCTION VEHICLE PARKING: Construction vehicle parking within the public right-of-way will only be allowed if it does not cause access or safety problems as determined by the Town.
62. CONSTRUCTION TRAFFIC CONTROL: All construction traffic and related vehicular routes, traffic control plan, and applicable pedestrian or traffic detour plans shall be submitted for review and approval by the Town Engineer prior to the issuance of an encroachment, grading or building permit.
63. HAULING OF SOIL: Hauling of soil on- or off-site shall not occur during the morning or evening peak periods (between 7:00 a.m. and 9:00 a.m. and between 4:00 p.m. and 6:00 p.m.), and at other times as specified by the Director of Parks and Public Works. Cover all trucks hauling soil, sand and other loose debris.
64. CONSTRUCTION HOURS: All construction activities, including the delivery of construction materials, labors, heavy equipment, supplies, etc., shall be limited to the hours of 8:00 a.m. to 6:00 p.m., weekdays and 9:00 a.m. to 4:00 p.m. Saturdays, holidays excluded. The Town may authorize, on a case-by-case basis, alternate construction hours. The Owner and/or Applicant shall provide written notice twenty-four (24) hours in advance of modified construction hours. Approval of this request is at discretion of the Town.
65. CONSTRUCTION NOISE: Between the hours of 8:00 a.m. to 8:00 p.m., weekdays and 9:00 a.m. to 7:00 p.m. weekends and holidays, construction, alteration or repair activities shall be allowed. No individual piece of equipment shall produce a noise level exceeding eighty-five (85) dBA at twenty-five (25) feet from the source. If the device is located within a structure on the property, the measurement shall be made at distances as close to twenty-five (25) feet from the device as possible. The noise level at any point outside of the property plane shall not exceed eighty-five (85) dBA.
66. CONSTRUCTION MANAGEMENT PLAN SHEET: Prior to the issuance of any grading or building permits, the Owner and/or Applicant's design consultant shall submit a

construction management plan sheet (full-size) within the plan set that shall incorporate at a minimum the Earth Movement Plan, Project Schedule, employee parking, construction staging area, materials storage area(s), concrete washout(s) and proposed outhouse location(s). Please refer to the Town's Construction Management Plan Guidelines document for additional information.

67. **SANITARY SEWER BACKWATER VALVE:** Drainage piping serving fixtures which have flood level rims less than twelve (12) inches (304.8 mm) above the elevation of the next upstream manhole and/or flushing inlet cover at the public or private sewer system serving such drainage piping shall be protected from backflow of sewage by installing an approved type backwater valve. Fixtures above such elevation shall not discharge through the backwater valve, unless first approved by the Building Official. The Town shall not incur any liability or responsibility for damage resulting from a sewer overflow where the property owner or other person has failed to install a backwater valve as defined in the Uniform Plumbing Code adopted by the Town and maintain such device in a functional operation condition. Evidence of West Sanitation District's decision on whether a backwater device is needed shall be provided prior to the issuance of a building permit.
68. **BEST MANAGEMENT PRACTICES (BMPs):** The Owner and/or Applicant is responsible for ensuring that all contractors are aware of all storm water quality measures and that such measures are implemented. Best Management Practices (BMPs) shall be maintained and be placed for all areas that have been graded or disturbed and for all material, equipment and/or operations that need protection. Removal of BMPs (temporary removal during construction activities) shall be replaced at the end of each working day. Failure to comply with the construction BMP will result in the issuance of correction notices, citations, or stop work orders.
69. **SITE DESIGN MEASURES:** All projects shall incorporate at least one of the following measures:
  - a. Protect sensitive areas and minimize changes to the natural topography.
  - b. Minimize impervious surface areas.
  - c. Direct roof downspouts to vegetated areas.
  - d. Use porous or pervious pavement surfaces on the driveway, at a minimum.
  - e. Use landscaping to treat stormwater.
70. **EROSION CONTROL:** Interim and final erosion control plans shall be prepared and submitted to the Engineering Division of the Parks and Public Works Department. A maximum of two (2) weeks is allowed between clearing of an area and stabilizing/building on an area if grading is allowed during the rainy season. Interim erosion control measures, to be carried out during construction and before installation of the final landscaping, shall be included. Interim erosion control method shall include, but are not limited to: silt fences, fiber rolls (with locations and details), erosion control blankets, Town standard seeding specification, filter berms, check dams, retention basins, etc. Provide erosion control measures as needed to protect downstream water quality during winter months. The Town of Los Gatos Engineering Division of the Parks and Public Works Department and the Building Department will conduct periodic NPDES inspections of the site throughout the recognized storm season to verify compliance with the Construction General Permit and Stormwater ordinances and regulations.

71. **DUST CONTROL:** Blowing dust shall be reduced by timing construction activities so that paving and building construction begin as soon as possible after completion of grading, and by landscaping disturbed soils as soon as possible. Further, water trucks shall be present and in use at the construction site. All portions of the site subject to blowing dust shall be watered as often as deemed necessary by the Town, or a minimum of three (3) times daily, or apply (non-toxic) soil stabilizers on all unpaved access roads, parking areas, and staging areas at construction sites in order to insure proper control of blowing dust for the duration of the project. Watering on public streets shall not occur. Streets shall be cleaned by street sweepers or by hand as often as deemed necessary by the Town Engineer, or at least once a day. Watering associated with on-site construction activity shall take place between the hours of 8 a.m. and 5 p.m. and shall include at least one (1) late-afternoon watering to minimize the effects of blowing dust. All public streets soiled or littered due to this construction activity shall be cleaned and swept on a daily basis during the workweek to the satisfaction of the Town. Demolition or earthwork activities shall be halted when wind speeds (instantaneous gusts) exceed twenty (20) miles per hour (MPH). All trucks hauling soil, sand, or other loose debris shall be covered.
72. **AIR QUALITY:** To limit the project's construction-related dust and criteria pollutant emissions, the following the Bay Area Air Quality Management District (BAAQMD)-recommended basic construction measures shall be included in the project's grading plan, building plans, and contract specifications:
- a. All exposed surfaces (e.g., parking areas, staging areas, soil piles, graded areas, and unpaved access roads) shall be watered two times per day, or otherwise kept dust-free.
  - b. All haul trucks designated for removal of excavated soil and demolition debris from site shall be staged off-site until materials are ready for immediate loading and removal from site.
  - c. All haul trucks transporting soil, sand, debris, or other loose material off-site shall be covered.
  - d. As practicable, all haul trucks and other large construction equipment shall be staged in areas away from the adjacent residential homes.
  - e. All visible mud or dirt track-out onto adjacent public roads shall be removed using wet power vacuum street sweepers at least once per day, or as deemed appropriate by Town Engineer. The use of dry power sweeping is prohibited. An on-site track-out control device is also recommended to minimize mud and dirt-track-out onto adjacent public roads.
  - f. All vehicle speeds on unpaved surfaces shall be limited to fifteen (15) miles per hour.
  - g. All driveways and sidewalks to be paved shall be completed as soon as possible. Building pads shall be laid as soon as possible after grading unless seeding or soil binders are used.
  - h. Post a publicly visible sign with the telephone number and person to contact at the lead agency regarding dust complaints. This person shall respond and take corrective action within forty-eight (48) hours. The Air District's phone number shall also be visible to ensure compliance with applicable regulations. Please provide the BAAQMD's complaint number on the sign: 24-hour toll-free hotline at 1-800-334-ODOR (6367).

- i. All excavation, grading, and/or demolition activities shall be suspended when average wind speeds exceed twenty (20) miles per hour.
  - j. Vegetative ground cover (e.g., fast-germinating native grass seed) shall be planted in disturbed areas as soon as possible and watered appropriately until vegetation is established.
73. DETAILING OF STORMWATER MANAGEMENT FACILITIES: Prior to the issuance of any grading or building permits, all pertinent details of any and all proposed stormwater management facilities, including, but not limited to, ditches, swales, pipes, bubble-ups, dry wells, outfalls, infiltration trenches, detention basins and energy dissipaters, shall be provided on submitted plans, reviewed by the Engineering Division of the Parks and Public Works Department, and approved for implementation.
74. CONSTRUCTION ACTIVITIES: All construction shall conform to the latest requirements of the CASQA Stormwater Best Management Practices Handbooks for Construction Activities and New Development and Redevelopment, the Town's grading and erosion control ordinance, and other generally accepted engineering practices for erosion control as required by the Town Engineer when undertaking construction activities.
75. SITE DRAINAGE: Rainwater leaders shall be discharged to splash blocks. No through curb drains will be allowed. On-site drainage systems for all projects shall include one of the alternatives included in section C.3.i of the Municipal Regional NPDES Permit. These include storm water reuse via cisterns or rain barrels, directing runoff from impervious surfaces to vegetated areas and use of permeable surfaces. No improvements shall obstruct or divert runoff to the detriment of an adjacent, downstream or down slope property.
76. SILT AND MUD IN PUBLIC RIGHT-OF-WAY: It is the responsibility of Contractor and homeowner to make sure that all dirt tracked into the public right-of-way is cleaned up on a daily basis. Mud, silt, concrete and other construction debris SHALL NOT be washed into the Town's storm drains.
77. GOOD HOUSEKEEPING: Good housekeeping practices shall be observed at all times during the course of construction. All construction shall be diligently supervised by a person or persons authorized to do so at all times during working hours. The Owner and/or Applicant's representative in charge shall be at the job site during all working hours. Failure to maintain the public right-of-way according to this condition may result in penalties and/or the Town performing the required maintenance at the Owner and/or Applicant's expense.
78. COVERED TRUCKS: All trucks transporting materials to and from the site shall be covered.

TO THE SATISFACTION OF THE SANTA CLARA COUNTY FIRE DEPARTMENT:

2. GENERAL: Review of this Developmental proposal is limited to acceptability of site access, water supply and may include specific additional requirements as they pertain to fire department operations, and shall not be construed as a substitute for formal plan review to determine compliance with adopted model codes. Prior to performing any work, the applicant shall make application to, and receive from, the Building Department all applicable construction permits.

3. FIRE SPRINKLERS REQUIRED: (As Noted on A1.0) An automatic residential fire sprinkler system shall be installed in all new one- and two-family dwellings. Sprinklers are required for the new residence only unless additions are made to the existing residence being converted to an Accessory Dwelling Unit (ADU).
4. REQUIRED FIRE FLOW: The fire flow for this project is 2,000 GPM at 20 psi residual pressure. Since an automatic fire sprinkler system will be installed, the fire flow will be reduced by 50%, establishing a required adjusted fire flow of 1,000 GPM at 20 psi residual pressure. Note: The minimum required number and spacing of the hydrants shall be in accordance with CFC Table C102.1. Letter received. Hydrant is capable of meeting required fire flow.
5. ADDRESS IDENTIFICATION: New and existing buildings shall have approved address numbers, building numbers or approved building identification placed in a position that is plainly legible and visible from the street or road fronting the property. These numbers shall contrast with their background. Where required by the fire code official, address numbers shall be provided in additional approved locations to facilitate emergency response. Address numbers shall be Arabic numbers or alphabetical letters. Numbers shall be a minimum of 4 inches (101.6 mm) high with a minimum stroke width of 0.5 inch (12.7 mm). Where access is by means of a private road and the building cannot be viewed from the public way, a monument, pole or other sign or means shall be used to identify the structure. Address numbers shall be maintained. CFC Sec. 505.1.
6. CONSTRUCTION SITE FIRE SAFETY: All construction sites must comply with applicable provisions of the CFC Chapter 33 and our Standard Detail and Specification S1-7. Provide appropriate notations on subsequent plan submittals, as appropriate to the project. CFC Chp. 33.
7. WATER SUPPLY REQUIREMENTS: Potable water supplies shall be protected from contamination caused by fire protection water supplies. It is the responsibility of the applicant and any contractors and subcontractors to contact the water purveyor supplying the site of such project, and to comply with the requirements of that purveyor. Such requirements shall be incorporated into the design of any water-based fire protection systems, and/or fire suppression water supply systems or storage containers that may be physically connected in any manner to an appliance capable of causing contamination of the potable water supply of the purveyor of record. Final approval of the system(s) under consideration will not be granted by this office until compliance with the requirements of the water purveyor of record are documented by that purveyor as having been met by the applicant(s). 2019 CFC Sec. 903.3.5 and Health and Safety Code 13114.7.
8. GENERAL: This review shall not be construed to be an approval of a violation of the provisions of the California Fire Code or of other laws or regulations of the jurisdiction. A permit presuming to give authority to violate or cancel the provisions of the fire code or other such laws or regulations shall not be valid. Any addition to or alteration of approved construction documents shall be approved in advance. [CFC, Ch.1, 105.3.6]

***This Page  
Intentionally  
Left Blank***