



Town of Los Gatos
Planning Division
110 E. Main Street
Los Gatos, CA 95030

June 11, 2026

Re: 233 Forrester Road
Architecture & Site App.: S-26-010

Attn: Jocelyn Shoopman

Below is our response to the consulting architect's comments & recommendations dated April 9, 2026.

Issues & Concerns:

1. The windows are now shown with a 2" minimum recess. The windows are now labeled aluminum clad, wood framed. The grids on the windows may be hard to see in the color elevations; the glass has been lightened to make them more apparent. The elevation notes, now also call out the minimum mullion thickness. Wood trim would not be appropriate on a stucco finished house.
2. The thickness of the rafter tails and corbels is now labeled on the elevation callouts. This is what is pictured on the elevations and renderings on the cover sheet.

We thank you for your time and consideration.

Sincerely,

A handwritten signature in black ink, appearing to read "Jaclyn Greenmyer".

Jaclyn Greenmyer

This Page Intentionally Left Blank