

June 24, 2025

Ryan Safty
Community Development Department
110 E. Main Street
Los Gatos, CA 95030



Monarch Consulting Arborists

Richard Gessner
P.O. Box 1010 - Felton, CA 95018
1 831 331 8982
www.monarcharborists.com

I was asked to review the plans and the applicant's arborist report and provide findings and recommendations. The arborist's report was provided by Trees 360 Degrees dated April 25, 2025. The report is thorough, complete, and contains all the required information regarding the project.

During the site assessment the following questions came up:

1. Tree protection fence materials and potentially the locations and timing. The report states the following:

For larger extended areas or areas far enough away from construction impact, it is recommended that heavy-duty, plastic orange barrier construction fencing be used. LRCC would prefer to limit the use of chain link fencing to high-impact areas only if the orange netting is not suitable for adequate protection. The project arborist or Town consulting arborist will determine this on a case-by-case basis.

The ordinance states the following:

Sec. 29.10.1005. Protection of trees during construction.

(a) Protective tree fencing shall specify the following:

(1) Size and materials. Six (6) foot high chain link fencing, mounted on two-inch diameter galvanized iron posts, shall be driven into the ground to a depth of at least two (2) feet at no more than ten-foot spacing. For paving area that will not be demolished and when stipulated in a tree preservation plan, posts may be supported by a concrete base.

It may be possible to provide a scaled back tree protection material but this will need to be discussed and approved by planning. One option is to have regular monitoring of the fence in lieu of more sturdy fence. Again, since this is in conflict with the ordinance approval for the particular areas and materials will need to be reviewed and approved.



2. Tree removals and any bird or wildlife studies.

The contractor is responsible for any required biological surveys or reports prior to removing any trees. Nesting birds are protected both locally and through the federal Migratory Bird Treaty Act.

3. Tree removals outside the construction areas but recommended for removal by the consulting arborist (Trees 360 Degrees).

I am in agreement with these recommendations but if Trees 360 Degrees performs this work it could be construed as a conflict of interest.

The tables in the planning submittal TI-1, TI-2, TI-3, and TI-4 are different than those provided in the report (PDF Pages 34 through 101). The table from the report is more thorough and complete and should replace those in the planning submittal.

A proper T-1 sheet needs to be developed and should be broken down per area for all fence locations during each construction phase.

Richard J. Gessner



 **RCA #496**
Registered Consulting Arborist®

ASCA Registered Consulting Arborist® #496
ISA Board Certified Master Arborist® WE-4341B
Tree Risk Assessment Qualified to year 2029

