

Edge Analytical Test Results Summary

Contaminant	Raw Water Analysis		Finished Water Analysis		
	Test Results mg/L	Method Detection Limit (MDL) mg/L	Test Results mg/L	State Reporting Level (SRL) mg/L	Maximum Contaminant Level (MCL) mg/L
MERCURY	ND	1.90E-05	ND	0.0002	0.002
ARSENIC	0.0023	0.0005	ND	0.001	0.010
BARIUM	0.0440	0.00011	0.0092	0.001	2
CADMIUM	0.00013	9.00E-05	ND	0.001	0.005
CHROMIUM	0.0134	0.00036	ND	0.001	0.1
SELENIUM	0.00026	0.000222	ND	0.001	0.05
BERYLLIUM	0.00020	0.00012	ND	0.0003	0.004
ANTIMONY	0.0036	0.0004	ND	0.001	0.006
THALLIUM - EPA Regulated (Secondary)	0.00014	0.0001	ND	0.0001	0.002
LEAD ***	n/a	1.60E-05	ND	0.001	0.015
COPPER	0.0092	7.30E-05	ND	0.005	1.30

NOTES:

* SRL (State Reporting Level); indicates the minimum reporting level required by the Washington Department of Health (DOH).

**MCL (Maximum Contaminant Level) the maximum permissible level of a contaminant in water established by EPA; Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper. Sodium has a recommended limit of 20 mg/L.

*** From a 2021 Test Result