

The following devices are being proposed to be added to the nurse call scope to meet the State Health compliance for nurse call UL1069 code requirements.

Male Locker Room/Female Locker Room/Sterile Room/Dictation Room

SCS-5231 Staff Call Station

Patient Room 18 (being used as a staff lounge)

Patient Room 5 (Being used for Covid wing)

Device to be installed - SCS-5231



- This device will be able to call to the nurse’s station and will be able to be alerted of any emergency (Staff Emergency, Code Blue) calls in the unit.

PACU

Devices to be installed - SCS-5431/CDL-5006

- These devices will be used to call to the nurse’s station and can initiate Emergency and Code Blue alerts.

CDL-5006 Corridor Dome Lights - LED



STAFF LOCKER ROOM

EPS-5003/CDL-5003

- This is an emergency pull station and dome light that will be available to staff in the locker room by the shower room.

EPS-5003-1 Stand Alone Emergency Pull Switch

CDL-5003 Corridor Dome Lights - LED



SHOWER ROOM

CBS-5000

- This is a code blue pull station in the Shower Room.

CBS-5000 Code Blue Pull Switch



EMERGENCY DEPT. NURSE’S STATION

ZDL-5001

This a device located in the ceiling to enunciate General, Emergency, and Code Blue alerts (can be filtered for Emergency and Code Blue only) generated from other units in the facility at the Emergency Dept nurse’s station.

ZDL-5001 Zone Dome Light

