

## Storm Sirens, Inc.

---

3801 Harrogate Drive

Norman, Ok 73072

1-800-527-6375

stormsirens@aol.com

April 8, 2022

Mr. J. David Andren, City Manger  
City of Mangum  
201 North Oklahoma  
Mangum, Oklahoma 73554-4235

Regarding: Storm Warning System

Dear Mr. Andren:

At the Fire Department's request, Dan Chaney examined the City's 3 Model 16V1T-B storm warning sirens earlier this week. The sirens normally run from 220 VAC, single phase power and only switch to battery back-up if there is a power failure.

Currently the sirens are operational on 220 VAC but the battery back-up sides are down. The cost to repair the battery back-up half of the sirens would be \$6,685.00.

Please let me know how you wish to proceed.

If you have any questions, please contact us at our toll free number 1 (800) 527-6375 or by e-mail [stormsirens@aol.com](mailto:stormsirens@aol.com).

Sincerely,

*Cynthia E. Engelbrecht*

Cynthia E. Engelbrecht  
Vice President

CEE:st