



Texas Engineering Firm #4242

1500 County Road 269
Leander, TX 78641

PO Box 2029
Leander, TX 78646-2029

Date: Wednesday, August 4, 2021

PSCE Inc.
Professional StruCIVIL Engineers Inc
2205 W. Parmer LN Ste 201
Austin TX 78727
psce@psceinc.com

Permit Number 2021-P-1342-SF
Job Address: 13320 E U S HY 290, Manor, TX. 78653

Dear PSCE Inc.,

The first submittal of the Ryper Subdivision Short Form Final Plat (*Short Form Final Plat*) submitted by Professional StruCIVIL Engineers Inc and received on July 13, 2021, have been reviewed for compliance with the City of Manor Subdivision Ordinance 263B.

Engineer Review

The review of the submittal package has resulted in the following comments. Should you have any questions or require additional information regarding any of these comments, please contact Pauline Gray, P.E. by telephone at (512) 259-3882 or by email at pgray@gbateam.com.

1. Please provide the plat in the required eighteen inch by twenty-four inch (18"x24") format per City of Manor Subdivision Ordinance Article II Section 28(c).
2. The engineer and surveyor of record should affix their seals to the plat. per City of Manor Subdivision Ordinance Article II Section 28(c).
3. Please provide the required property owner, engineer and county certification blocks and notes as shown on the checklist and per City of Manor Subdivision Ordinance Article II Section 28(c).
4. Provide the true bearings and distances to the nearest established street lines, official monuments, or existing subdivision corner which shall be accurately described on the plat and rotated to the state plane coordinate system. Using said system X and Y coordinates shall be identified for four (4) property corners per City of Manor Subdivision Ordinance Article II Section 28(c).
5. Suitable primary control points to which all dimensions, bearings and similar data shall be referenced. At least one (1) corner of the subdivision shall be located with respect to a corner of the original survey of which it is part in accordance with City of Manor Subdivision Ordinance Article II Section 28(c).
6. Provide the location of sidewalks along all roadway frontages as required by the City per City of Manor Subdivision Ordinance Article II Section 28(c).
7. Right-of-way dedication is required along Bois D'arc. Bois D'arc is designated as a primary collector in the City's Transportation Plan which means it will have a 64' right-of-way. The current right-of-way of Bois D'arc is 50'. Therefore an additional 14' of right-of-way is required. This difference is split between property owners on each side of Bois D'arc. The proposed projects required right-of-way dedication is 7'.

Please revise the project plans to address the comments noted above. Following revision, please upload one full set of the revised drawings in PDF format. Please include a comment response narrative indicating how comments have been addressed with your plan resubmittal. To access your project online, please go to www.mygovernmentonline.org and use the online portal to upload your drawings in PDF format.

Additional comments may be generated as requested information is provided. Review of this submittal does not constitute verification that all data, information and calculations supplied by the applicant are accurate, complete, or adequate for the intended purpose. The engineer of record is solely responsible for the completeness, accuracy, and adequacy of his/her submittal, whether or not City Engineers review the application for Ordinance compliance.

Thank you,

A handwritten signature in blue ink that reads "Pauline M. Gray". The signature is written in a cursive, flowing style.

Pauline Gray, P.E.
Senior Engineer
Jay Engineering, a Division of GBA