

**ATTACHMENT NO.1**

**SUBDIVISION OVERVIEW:**

**APPLICANT:** Michael & Ellen Demson

**TYPE OF DEVELOPMENT:** Single Family Dwelling

**FIRE DEPARTMENT:** Marin County Fire Department

**FIRE MARSHALL:** Scott Alber

**FIRE FLOW REQUIRED:** 500gpm

**PIPING:** 160' of 6"

**HYDRANTS:** 1-6"

**Calculated Flow:** 1,200gpm

**Residual:** 20 psi

**SERVICES:** 1-1"

**SYSTEM:** Tomahawk Tank

**Elevation:** 506

**ELEVATION OF PROPERTY:** Min: 130'

Max: 216'

**PRESSURE:** Max: 160 psi Min: 120 psi

**ESTIMATED ANNUAL CONSUMPTION:** 0.30 acre-feet for the single family dwelling

**EXISTING HISTORICAL ENTITLEMENT:** 0.0

**LEAD AGENCY:** County of Marin

**CEQA:** Categorical Exemption per Section 15303, Class 3