

## ATTACHMENT NO.1

### SUBDIVISION OVERVIEW:

**APPLICANT:** Michael & Ellen Demson

**TYPE OF DEVELOPMENT:** Single Family Dwelling

**FIRE DEPARTMENT:** Marin County Fire Department

**FIRE MARSHALL:** Scott Alber

**FIRE FLOW REQUIRED:** 500gpm

**PIPING:** 160' of 6"

**HYDRANTS:** 1-6"                      **Calculated Flow:** 1,200gpm                      **Residual:** 20 psi

**SERVICES:** 1-1"

**SYSTEM:** Tomahawk Tank                      **Elevation:** 506

**ELEVATION OF PROPERTY:**              Min: 130'                      Max: 216'

**PRESSURE:** Max: 160 psi              Min: 120 psi

**ESTIMATED ANNUAL CONSUMPTION:** 0.30 acre-feet for the single family dwelling

**EXISTING HISTORICAL ENTITLEMENT:** 0.0

**LEAD AGENCY:** County of Marin

**CEQA:** Categorical Exemption per Section 15303, Class 3