

Remove existing membrane, top layer of plywood, vapor barrier, and insulation all the way down to 2nd layer of plywood. Install new polyiso insulation of the same thickness, cover board, and new 60 mil fully adhered EPDM membrane.

4

SLOPE

60 MIL EPDM FULLY ADHERED

GRAVEL STOP

FLASHING

6" METAL STUD SUPPORTS

SOUND INSUL.  
VAPOR BARRIER  
ACOUSTICAL DECK

12"

BLOCKING AS REQUIRED

1/2" EXT. SHEATHING  
6" METAL STUDS  
6" BATT INSULATION  
VAPOR BARRIER  
5/8" GYP. BD.

GRAVEL STOP

DRIP

12"

STEEL BEAM - TAPERED  
SEE STRUCTURAL

ALUMINUM SOFFIT  
ON FURRING CHANNELS

BACKER ROD &  
SEALANT

4"

STEEL BEAM  
SEE STRUCTURAL

3"

2'-10"

4" CURTAINWALL SYSTEM -  
BUTT-GLAZED - VERTICALLY  
W/3" EXTENSION CAP

CLERESTORY DETAIL AT ROOF

1 1/2" = 1'-0"

