



CITY OF MARSHALL AGENDA ITEM REPORT

Presenter:	Jason Anderson
Meeting Date:	Tuesday, March 24, 2026
Category:	AWARD OF QUOTES
Type:	ACTION
Subject:	Consider Approval of Manhole Lining Quotes - 1) Collection System Manholes; 2) WWTF Manholes
Background Information:	<p>The Wastewater Department continues to have some of our worst sanitary manholes lined to stop hydrogen sulfide corrosion and the infiltration of ground water into the sanitary system. City staff has been lining corroded manholes annually since 2018. The quotes received are from Hiperline, a subsidiary of R&H Painting, LLC. Hiperline is the exclusive authorized and licensed Spectrashield Liner System applicator for Minnesota, North Dakota, and South Dakota. City staff has been very impressed with the workmanship and warranty coverage that is provided by Hiperline.</p> <p>The manhole lining has most typically focused on the trunk sewer main that serves the MN 23 lift station. This year is no different, as staff is proposing to line five manholes that are located along the 1993 trunk sewer main. Manholes 3SE35, 3SE34, 2SW15 are located on the gravel portion of E. Lyon Street by the Walnut Grove Mercantile and manholes 9SE43 and 10SW19 are located along Canoga Park Drive. The total quoted work for the collection system manhole lining is \$77,032.40.</p> <p>Additionally for 2026, staff is proposing to line seven structures at the Wastewater Treatment Facility. The bulk of the cost for this work is located at the equalization basin pump station and weir structure. The total quoted work is \$108,407.60.</p>
Fiscal Impact:	<p>The Wastewater Department has \$110,000 in the 2026 budget for the collection system lining.</p> <p>The Wastewater Department has \$145,000 in the 2026 budget for the Wastewater Treatment Facility lining work.</p>
Alternative/Variations:	No alternative actions recommended.
Recommendations:	<p>Recommendation No. 1 that the Council approve the lining quote for the specified manholes in the collection system to Hiperline of Cokato, Minnesota, in the amount of \$77,032.40, per the attached quote.</p> <p>Recommendation No. 2 that the Council approve the lining quote for the specified manholes at the WWTF to Hiperline of Cokato, Minnesota, in the amount of \$108,407.60.</p>