

# Compliance Maintenance Annual Report

Mauston Wastewater Treatment Facility

Last Updated: Reporting For:

6/2/2025

2024

## Influent Flow and Loading

### 1. Monthly Average Flows and BOD Loadings

#### 1.1 Verify the following monthly flows and BOD loadings to your facility.

Influent No. 701	Influent Monthly Average Flow, MGD	x	Influent Monthly Average BOD Concentration mg/L	x	8.34	=	Influent Monthly Average BOD Loading, lbs/day
January	0.4132	x	203	x	8.34	=	701
February	0.3671	x	250	x	8.34	=	765
March	0.3959	x	276	x	8.34	=	911
April	0.4997	x	237	x	8.34	=	986
May	0.7473	x	202	x	8.34	=	1,257
June	0.7446	x	179	x	8.34	=	1,113
July	1.0347	x	187	x	8.34	=	1,609
August	0.6771	x	233	x	8.34	=	1,318
September	0.5418	x	247	x	8.34	=	1,115
October	0.5440	x	264	x	8.34	=	1,199
November	0.5988	x	253	x	8.34	=	1,265
December	0.5664	x	248	x	8.34	=	1,169

### 2. Maximum Monthly Design Flow and Design BOD Loading

#### 2.1 Verify the design flow and loading for your facility.

Design	Design Factor	x	%	=	% of Design
Max Month Design Flow, MGD	1.5	x	90	=	1.35
		x	100	=	1.5
Design BOD, lbs/day	2480	x	90	=	2232
		x	100	=	2480

#### 2.2 Verify the number of times the flow and BOD exceeded 90% or 100% of design, points earned, and score:

	Months of Influent	Number of times flow was greater than 90% of	Number of times flow was greater than 100% of	Number of times BOD was greater than 90% of design	Number of times BOD was greater than 100% of design
January	1	0	0	0	0
February	1	0	0	0	0
March	1	0	0	0	0
April	1	0	0	0	0
May	1	0	0	0	0
June	1	0	0	0	0
July	1	0	0	0	0
August	1	0	0	0	0
September	1	0	0	0	0
October	1	0	0	0	0
November	1	0	0	0	0
December	1	0	0	0	0
Points per each		2	1	3	2
Exceedances		0	0	0	0
Points		0	0	0	0
<b>Total Number of Points</b>					<b>0</b>

0

# Compliance Maintenance Annual Report

Mauston Wastewater Treatment Facility

Last Updated: Reporting For:

6/2/2025

2024

## 3. Flow Meter

3.1 Was the influent flow meter calibrated in the last year?

- ☒ Yes Enter last calibration date (MM/DD/YYYY)

2025-03-11

☐ No

If No, please explain:

## 4. Sewer Use Ordinance

4.1 Did your community have a sewer use ordinance that limited or prohibited the discharge of excessive conventional pollutants ((C)BOD, SS, or pH) or toxic substances to the sewer from industries, commercial users, hauled waste, or residences?

☒ Yes

☐ No

If No, please explain:

4.2 Was it necessary to enforce the ordinance?

☐ Yes

☒ No

If Yes, please explain:

## 5. Septage Receiving

5.1 Did you have requests to receive septage at your facility?

Septic Tanks

Holding Tanks

Grease Traps

☐ Yes

☐ Yes

☐ Yes

☒ No

☒ No

☒ No

5.2 Did you receive septage at your facility? If yes, indicate volume in gallons.

Septic Tanks

☐ Yes

gallons

☒ No

Holding Tanks

☐ Yes

gallons

☒ No

Grease Traps

☐ Yes

gallons

☒ No

5.2.1 If yes to any of the above, please explain if plant performance is affected when receiving any of these wastes.

## 6. Pretreatment

6.1 Did your facility experience operational problems, permit violations, biosolids quality concerns, or hazardous situations in the sewer system or treatment plant that were attributable to commercial or industrial discharges in the last year?

☐ Yes

☒ No

If yes, describe the situation and your community's response.

6.2 Did your facility accept hauled industrial wastes, landfill leachate, etc.?

# Compliance Maintenance Annual Report

Mauston Wastewater Treatment Facility

Last Updated: Reporting For:  
6/2/2025 2024

<div><div><input type="radio"/> Yes</div><div><input checked="" type="radio"/> No</div></div> <div>If yes, describe the types of wastes received and any procedures or other restrictions that were in place to protect the facility from the discharge of hauled industrial wastes.</div> <div></div>	
--	--

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

# Compliance Maintenance Annual Report

Mauston Wastewater Treatment Facility

Last Updated: Reporting For:  
6/2/2025 **2024**

## Effluent Quality and Plant Performance (BOD/CBOD)

### 1. Effluent (C)BOD Results

1.1 Verify the following monthly average effluent values, exceedances, and points for BOD or CBOD

Outfall No. 001	Monthly Average Limit (mg/L)	90% of Permit Limit > 10 (mg/L)	Effluent Monthly Average (mg/L)	Months of Discharge with a Limit	Permit Limit Exceedance	90% Permit Limit Exceedance
January	30	27	6	1	0	0
February	30	27	10	1	0	0
March	30	27	17	1	0	0
April	30	27	16	1	0	0
May	30	27	8	1	0	0
June	30	27	4	1	0	0
July	30	27	4	1	0	0
August	30	27	7	1	0	0
September	30	27	12	1	0	0
October	30	27				
November	30	27	6	1	0	0
December	30	27	7	1	0	0

\* Equals limit if limit is  $\leq 10$

Months of discharge/yr	11		
Points per each exceedance with 11 months of discharge		8	3
Exceedances		0	0
Points		0	0
<b>Total number of points</b>			<b>0</b>

NOTE: For systems that discharge intermittently to state waters, the points per monthly exceedance for this section shall be based upon a multiplication factor of 12 months divided by the number of months of discharge. Example: For a wastewater facility discharging only 6 months of the year, the multiplication factor is  $12/6 = 2.0$

1.2 If any violations occurred, what action was taken to regain compliance?

No violations

### 2. Flow Meter Calibration

2.1 Was the effluent flow meter calibrated in the last year?

- ☒ Yes Enter last calibration date (MM/DD/YYYY)

2025-03-11

- ☐ No

If No, please explain:

### 3. Treatment Problems

3.1 What problems, if any, were experienced over the last year that threatened treatment?

None

### 4. Other Monitoring and Limits

4.1 At any time in the past year was there an exceedance of a permit limit for any other pollutants such as chlorides, pH, residual chlorine, fecal coliform, or metals?

- ☐ Yes

- ☒ No

# Compliance Maintenance Annual Report

Mauston Wastewater Treatment Facility

Last Updated: Reporting For:  
6/2/2025 2024

<p>If Yes, please explain:</p> <div></div> <p>4.2 At any time in the past year was there a failure of an effluent acute or chronic whole effluent toxicity (WET) test?</p> <p><input type="radio"/> Yes</p> <p><input checked="" type="radio"/> No</p> <p>If Yes, please explain:</p> <div></div> <p>4.3 If the biomonitoring (WET) test did not pass, were steps taken to identify and/or reduce source(s) of toxicity?</p> <p><input type="radio"/> Yes</p> <p><input type="radio"/> No</p> <p><input checked="" type="radio"/> N/A</p> <p>Please explain unless not applicable:</p> <div></div>	
--	--

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

# Compliance Maintenance Annual Report

Mauston Wastewater Treatment Facility

Last Updated: Reporting For:  
6/2/2025 2024

## Effluent Quality and Plant Performance (Total Suspended Solids)

1. Effluent Total Suspended Solids Results

1.1 Verify the following monthly average effluent values, exceedances, and points for TSS:

Outfall No. 001	Monthly Average Limit (mg/L)	90% of Permit Limit >10 (mg/L)	Effluent Monthly Average (mg/L)	Months of Discharge with a Limit	Permit Limit Exceedance	90% Permit Limit Exceedance
January	30	27	7	1	0	0
February	30	27	9	1	0	0
March	30	27	14	1	0	0
April	30	27	18	1	0	0
May	30	27	6	1	0	0
June	30	27	2	1	0	0
July	30	27	5	1	0	0
August	30	27	17	1	0	0
September	30	27	15	1	0	0
October	30	27				
November	30	27	2	1	0	0
December	30	27	1	1	0	0
* Equals limit if limit is <= 10						
Months of Discharge/yr				11		
Points per each exceedance with 11 months of discharge:					8	3
Exceedances					0	0
Points					0	0
Total Number of Points						0
NOTE: For systems that discharge intermittently to state waters, the points per monthly exceedance for this section shall be based upon a multiplication factor of 12 months divided by the number of months of discharge. Example: For a wastewater facility discharging only 6 months of the year, the multiplication factor is 12/6 = 2.0						
1.2 If any violations occurred, what action was taken to regain compliance?						
No violations						

0

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

# Compliance Maintenance Annual Report

Mauston Wastewater Treatment Facility

Last Updated: Reporting For:  
6/2/2025 2024

## Effluent Quality and Plant Performance (Ammonia - NH3)

1. Effluent Ammonia Results									
1.1 Verify the following monthly and weekly average effluent values, exceedances and points for ammonia									
Outfall No. 001	Monthly Average NH3 Limit (mg/L)	Weekly Average NH3 Limit (mg/L)	Effluent Monthly Average NH3 (mg/L)	Monthly Permit Limit Exceed ance	Effluent Weekly Average for Week 1	Effluent Weekly Average for Week 2	Effluent Weekly Average for Week 3	Effluent Weekly Average for Week 4	Weekly Permit Limit Exceed ance
January	55	108	5.8	0	3.5	4.2	6.7	8.8	0
February	55	108	12.5	0	12	12	13	13	0
March	55	108	13.25	0	12	13	14	14	0
April	102	108	12.5	0	13	13	13	11	0
May	102	108	7.5	0	9.3	8.6	7.7	4.4	0
June	75	108	.92	0	1.9	.8	.55	.43	0
July	75	108	0	0	0	0	0	0	0
August	75	108	.405	0	.23		.58		0
September	75	108	3.2	0			3.7	2.7	0
October	58	108		0					0
November	58	108	.675	0	1.2	.56	0	.94	0
December	58	108	3.45	0	1.2	2.7	4.2	5.7	0
Points per each exceedance of Monthly average:									10
Exceedances, Monthly:									0
Points:									0
Points per each exceedance of weekly average (when there is no monthly average):									2.5
Exceedances, Weekly:									0
Points:									0
Total Number of Points									0
NOTE: Limit exceedances are considered for monthly OR weekly averages but not both. When a monthly average limit exists it will be used to determine exceedances and generate points. This will be true even if a weekly limit also exists. When a weekly average limit exists and a monthly limit does not exist, the weekly limit will be used to determine exceedances and generate points.									
1.2 If any violations occurred, what action was taken to regain compliance?									
No violations									

0

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

# Compliance Maintenance Annual Report

Mauston Wastewater Treatment Facility

Last Updated: Reporting For:  
6/2/2025 2024

## Effluent Quality and Plant Performance (Phosphorus)

1. Effluent Phosphorus Results

1.1 Verify the following monthly average effluent values, exceedances, and points for Phosphorus

Outfall No. 001	Monthly Average phosphorus Limit (mg/L)	Effluent Monthly Average phosphorus (mg/L)	Months of Discharge with a Limit	Permit Limit Exceedance
January	1	0.448	1	0
February	1	0.476	1	0
March	1	0.563	1	0
April	1	0.574	1	0
May	1	0.568	1	0
June	1	0.354	1	0
July	1	0.485	1	0
August	1	0.280	1	0
September	1	0.368	1	0
October	1			
November	1	0.875	1	0
December	1	0.321	1	0
Months of Discharge/yr			11	
Points per each exceedance with 11 months of discharge:				11
Exceedances				0
Total Number of Points				0

NOTE: For systems that discharge intermittently to waters of the state, the points per monthly exceedance for this section shall be based upon a multiplication factor of 12 months divided by the number of months of discharge.  
Example: For a wastewater facility discharging only 6 months of the year, the multiplication factor is  $12/6 = 2.0$

1.2 If any violations occurred, what action was taken to regain compliance?

No violations

0

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A



# Compliance Maintenance Annual Report

Mauston Wastewater Treatment Facility

Last Updated: Reporting For:  
6/2/2025 2024

## Ponds And Lagoon Leakage

1. Pond Lining

1.1 What material was used to line your ponds?

PVC sheeting liner

2. Flow Measurements

2.1 Did you measure influent flow to your wastewater ponds or lagoons?

● Yes (0 points)

☐

○ No (40 points) (Go to question 6)

☐

2.1.1 Method of influent flow measurement:

Ultrasonic flow

2.2 Did you measure effluent flow discharged from your wastewater system either to the land disposal system or to the receiving stream?

● Yes (0 points)

☐

○ No (40 points) (Go to question 6)

☐

○ No Discharge (0 points)

2.2.1 Method of effluent flow measurement:

9-inch Parshall flume and overhead transducer.

3. Total Flow Volumes

3.1 Total monthly influent and effluent flow volumes from the pond/lagoon system during the last calendar year.

Total Monthly Influent Volume		Total Monthly Effluent Volume
12.81	JANUARY	13.197
10.647	FEBRUARY	11.712
12.274	MARCH	12.924
14.992	APRIL	16.401
23.165	MAY	21.511
22.338	JUNE	22.124
32.075	JULY	33.592
20.989	AUGUST	20.262
16.254	SEPTEMBER	9.556
16.865	OCTOBER	3.514
17.964	NOVEMBER	22.148
17.559	DECEMBER	13.291
217.9320	YEARLY TOTAL	200.2320

3.2 From the Yearly Total influent and effluent volumes above, total effluent is divided by total influent and converted to a percent of volume loss.

Total effluent, MG => 200.2320

-----

Total influent, MG => 217.9320

-----

= 0.919 <= effl / infl ratio

Conversion to a percent of volume loss:

(1-effl/infl ratio) \* 100 = 8.1 % of influent lost and not discharged with effluent

0

# Compliance Maintenance Annual Report

Mauston Wastewater Treatment Facility

Last Updated: Reporting For:

6/2/2025

2024

## 4. Surface Area

4.1 What was the total wastewater surface area of the ponds/lagoons at operating level (do not include seepage cells)?

27 Acres

## 5. Leakage Rate Estimation

5.1 Total influent volume (in MG) minus total effluent volume (in MG) plus or minus the change in pond/lagoon storage (in MG) is the net wastewater loss. The net loss divided by 0.000365 equals the estimated leakage amount in gpd.

Total Annual Influent (MG)	217.9320	
Total Annual Effluent (MG)	200.2320	
Estimated Net Loss (MG)	17.7000	
Estimated Leakage Amount (gpd)		48493

If you have a \*Department approved\* method for determining a change in storage volume, enter the storage change last year in MG below.

o Storage Increase: Enter amount in MG ->

o Storage Decrease: Enter amount in MG ->

5.2 CMAR Estimated Leakage Rate in gallons per acre per day (gpad): The CMAR Estimated Leakage Rate in gpad is the leakage amount in gpd (from part 5.1) divided by the total pond surface area (from question 4).

Leakage Amount (gpd)		Acres		CMAR Estimated Leakage Rate
48493	divided by	27	=	1796

## 6. On Site Leakage Testing

6.1 Did you conduct an on-site, field water balance/leakage test on your ponds or lagoons that was approved by the Department and is still valid?

o Yes Year

● No

If yes, what was the field Test Calculated Leakage Rate for your ponds/lagoons?

gpad

NOTE: if 6.1 is answered Yes, the value entered above in gpad will be used in 7.1 to compute points generated.

6.2 Leakage Rate Comments:

## 7. Estimated Leakage Rate and Points

7.1 The CMAR Estimated Leakage Rate (from 5) is used to determine the points generated in the table below.

If an approved field test was conducted and the results are still valid and accepted by the Department, the Field Calculated Leakage rate (from 5.2) is used to determine the points earned from the table below

gpad	points
0 - 1,000	0
1,001 - 2,000	10
2,001 - 4,000	20
4,001 - 7,000	30
> 7,000	40

# Compliance Maintenance Annual Report

Mauston Wastewater Treatment Facility

Last Updated: Reporting For:  
6/2/2025 2024

Based on the leakage rate in gpad, the points earned are:	10
---	----

Total Points Generated	10
Score (100 - Total Points Generated)	90
Section Grade	B

# Compliance Maintenance Annual Report

Mauston Wastewater Treatment Facility

Last Updated: Reporting For:  
6/2/2025 2024

## Biosolids Quality and Management

1. Biosolids Use/Disposal

1.1 How did you use or dispose of your biosolids? (Check all that apply)

☐ Land applied under your permit

☐ Publicly Distributed Exceptional Quality Biosolids

☐ Hauled to another permitted facility

☐ Landfilled

☐ Incinerated

☒ Other

NOTE: If you did not remove biosolids from your system, please describe your system type such as lagoons, reed beds, recirculating sand filters, etc.

1.1.1 If you checked Other, please describe:

Lagoons

2. Land Application Site

2.1 Last Year's Approved and Active Land Application Sites

2.1.1 How many acres did you have?

572.4 acres

2.1.2 How many acres did you use?

239.2 acres

2.2 If you did not have enough acres for your land application needs, what action was taken?

2.3 Did you overapply nitrogen on any of your approved land application sites you used last year?

☐ Yes (30 points)

☒ No

2.4 Have all the sites you used last year for land application been soil tested in the previous 4 years?

☒ Yes

☐ No (10 points)

☐ N/A

3. Biosolids Metals

Number of biosolids outfalls in your WPDES permit:

3.1 For each outfall tested, verify the biosolids metal quality values for your facility during the last calendar year.

Outfall No. 002 - Lagoon Sludge

Parameter	80% of Limit	H.Q. Limit	Ceiling Limit	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	80% Value	High Quality	Ceiling
Arsenic		41	75						<6.1								0	0
Cadmium		39	85						1.6								0	0
Copper		1500	4300						680								0	0
Lead		300	840						44								0	0
Mercury		17	57						<.021								0	0
Molybdenum	60		75						<.82							0		0
Nickel	336		420						<.44							0		0
Selenium	80		100						<1.7							0		0
Zinc		2800	7500						12								0	0

3.1.1 Number of times any of the metals exceeded the high quality limits OR 80% of the limit for molybdenum, nickel, or selenium = 0

Exceedence Points

☒ 0 (0 Points)

0

# Compliance Maintenance Annual Report

Mauston Wastewater Treatment Facility

Last Updated: Reporting For:

6/2/2025

2024

- ☐ 1-2 (10 Points)
- ☐ > 2 (15 Points)
- 3.1.2 If you exceeded the high quality limits, did you cumulatively track the metals loading at each land application site? (check applicable box)
  - ☐ Yes
  - ☐ No (10 points)
  - N/A - Did not exceed limits or no HQ limit applies (0 points)
  - ☐ N/A - Did not land apply biosolids until limit was met (0 points)
- 3.1.3 Number of times any of the metals exceeded the ceiling limits = 0  
Exceedence Points
  - 0 (0 Points)
  - ☐ 1 (10 Points)
  - ☐ > 1 (15 Points)
- 3.1.4 Were biosolids land applied which exceeded the ceiling limit?
  - ☐ Yes (20 Points)
  - No (0 Points)
- 3.1.5 If any metal limit (high quality or ceiling) was exceeded at any time, what action was taken?  
Has the source of the metals been identified?

None exceeded the limit.

0

## 4. Pathogen Control (per outfall):

4.1 Verify the following information. If any information is incorrect, use the Report Issue button under the Options header in the left-side menu.

Outfall Number:	002
Biosolids Class:	B
Bacteria Type and Limit:	Fecal Coliform
Sample Dates:	01/01/2024 - 12/31/2024
Density:	0
Sample Concentration Amount:	CFU/G TS
Requirement Met:	Yes
Land Applied:	Yes
Process:	
Process Description:	From lagoon 5

Outfall Number:	002
Biosolids Class:	B
Bacteria Type and Limit:	Fecal Coliform
Sample Dates:	01/01/2024 - 12/31/2024
Density:	52,200
Sample Concentration Amount:	CFU/G TS
Requirement Met:	Yes
Land Applied:	Yes
Process:	
Process Description:	From lagoon 1

4.2 If exceeded Class B limit or did not meet the process criteria at the time of land application.

4.2.1 Was the limit exceeded or the process criteria not met at the time of land application?

- ☐ Yes (40 Points)
- No

# Compliance Maintenance Annual Report

Mauston Wastewater Treatment Facility

Last Updated: Reporting For:  
6/2/2025 2024

If yes, what action was taken?		0
5. Vector Attraction Reduction (per outfall): 5.1 Verify the following information. If any of the information is incorrect, use the Report Issue button under the Options header in the left-side menu.		0
Outfall Number:	002	
Method Date:	12/31/2024	
Option Used To Satisfy Requirement:	Incorporation when land apply	
Requirement Met:	Yes	
Land Applied:	Yes	
Limit (if applicable):		
Results (if applicable):		
5.2 Was the limit exceeded or the process criteria not met at the time of land application?		
<div><div></div> Yes (40 Points)</div> <div><div></div> No</div> <div>If yes, what action was taken?</div>		
6. Biosolids Storage 6.1 How many days of actual, current biosolids storage capacity did your wastewater treatment facility have either on-site or off-site?		0
<div><div></div> &gt;= 180 days (0 Points)</div> <div><div></div> 150 - 179 days (10 Points)</div> <div><div></div> 120 - 149 days (20 Points)</div> <div><div></div> 90 - 119 days (30 Points)</div> <div><div></div> &lt; 90 days (40 Points)</div> <div><div></div> N/A (0 Points)</div>		
6.2 If you checked N/A above, explain why.		
7. Issues 7.1 Describe any outstanding biosolids issues with treatment, use or overall management:		

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

# Compliance Maintenance Annual Report

Mauston Wastewater Treatment Facility

Last Updated: Reporting For:

6/2/2025

2024

## Staffing and Preventative Maintenance (All Treatment Plants)

<p>1. Plant Staffing</p> <p>1.1 Was your wastewater treatment plant adequately staffed last year?</p> <ul style="list-style-type: none"><li>● Yes</li><li>○ No</li></ul> <p>If No, please explain:</p> <div></div> <p>Could use more help/staff for:</p> <div></div> <p>1.2 Did your wastewater staff have adequate time to properly operate and maintain the plant and fulfill all wastewater management tasks including recordkeeping?</p> <ul style="list-style-type: none"><li>● Yes</li><li>○ No</li></ul> <p>If No, please explain:</p> <div></div>	
<p>2. Preventative Maintenance</p> <p>2.1 Did your plant have a documented AND implemented plan for preventative maintenance on major equipment items?</p> <ul style="list-style-type: none"><li>● Yes (Continue with question 2) <input type="checkbox"/><input type="checkbox"/></li><li>○ No (40 points)<input type="checkbox"/><input type="checkbox"/></li></ul> <p>If No, please explain, then go to question 3:</p> <div></div> <p>2.2 Did this preventative maintenance program depict frequency of intervals, types of lubrication, and other tasks necessary for each piece of equipment?</p> <ul style="list-style-type: none"><li>● Yes</li><li>○ No (10 points)</li></ul> <p>2.3 Were these preventative maintenance tasks, as well as major equipment repairs, recorded and filed so future maintenance problems can be assessed properly?</p> <ul style="list-style-type: none"><li>● Yes<ul style="list-style-type: none"><li>● Paper file system</li><li>○ Computer system</li><li>○ Both paper and computer system</li></ul></li><li>○ No (10 points)</li></ul>	0
<p>3. O&amp;M Manual</p> <p>3.1 Does your plant have a detailed O&amp;M and Manufacturer Equipment Manuals that can be used as a reference when needed?</p> <ul style="list-style-type: none"><li>● Yes</li><li>○ No</li></ul>	
<p>4. Overall Maintenance /Repairs</p> <p>4.1 Rate the overall maintenance of your wastewater plant.</p> <ul style="list-style-type: none"><li>○ Excellent</li><li>○ Very good</li><li>● Good</li><li>○ Fair</li><li>○ Poor</li></ul> <p>Describe your rating:</p> <div>Trained staff to perform maintenance needs.</div>	

# Compliance Maintenance Annual Report

Mauston Wastewater Treatment Facility

Last Updated: Reporting For:  
6/2/2025 2024

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A



# Compliance Maintenance Annual Report

Mauston Wastewater Treatment Facility

Last Updated: Reporting For:  
6/2/2025 **2024**

## Operator Certification and Education

### 1. Operator-In-Charge

1.1 Did you have a designated operator-in-charge during the report year?

- Yes (0 points)
- No (20 points)

Name:

ROBERT A NELSON

Certification No:

20512

0

### 2. Certification Requirements

2.1 In accordance with Chapter NR 114.56 and 114.57, Wisconsin Administrative Code, what level and subclass(es) were required for the operator-in-charge (OIC) to operate the wastewater treatment plant and what level and subclass(es) were held by the operator-in-charge?

Sub Class	SubClass Description	WWTP	OIC		
		Basic	OIT	Basic	Advanced
A1	Suspended Growth Processes				X
A2	Attached Growth Processes				X
A3	Recirculating Media Filters				
A4	Ponds, Lagoons and Natural	X			X
A5	Anaerobic Treatment Of Liquid				
B	Solids Separation				X
C	Biological Solids/Sludges				X
P	Total Phosphorus	X			X
N	Total Nitrogen				
D	Disinfection				X
L	Laboratory				X
U	Unique Treatment Systems				
SS	Sanitary Sewage Collection	X	NA	NA	NA

0

2.2 Was the operator-in-charge certified at the appropriate level and subclass(es) to operate this plant? (Note: Certification in subclass SS is required 5 years after permit reissuance.)

- Yes (0 points)
- No (20 points)

2.3 For wastewater treatment facilities with a registered or certified laboratory, is at least one operator that works in the laboratory certified at the basic level in the laboratory (L) subclass?

- Yes
- No

● N/A – Wastewater treatment facility does not have a registered or certified laboratory

2.4 For wastewater treatment facilities that own and operate a sanitary sewage collection system, has at least one operator been designated the OIC for sanitary sewage collection system and certified at the basic level in the sanitary sewage collection system (SS) subclass?

- Yes
- No

○ N/A – Owner of the Wastewater treatment facility does not own and operate a sanitary sewage collection system

### 3. Succession Planning

3.1 In the event of the loss of your designated operator-in-charge, did you have a contingency plan to ensure the continued proper operation and maintenance of the plant that includes one or more of the following options (check all that apply)?

- ☒ One or more additional certified operators on staff

# Compliance Maintenance Annual Report

Mauston Wastewater Treatment Facility

Last Updated: Reporting For:  
6/2/2025 2024

<div><input type="checkbox"/> An arrangement with another certified operator</div> <div><input type="checkbox"/> An arrangement with another community with a certified operator</div> <div><input type="checkbox"/> An operator on staff who has an operator-in-training certificate for your plant and is expected to be certified within one year</div> <div><input type="checkbox"/> A consultant to serve as your certified operator</div> <div><input type="checkbox"/> None of the above (20 points)</div> <div>If "None of the above" is selected, please explain:</div> <div></div>	0
<div>4. Continuing Education Credits</div> <div>4.1 If you had a designated operator-in-charge, was the operator-in-charge earning Continuing Education Credits at the following rates?</div> <div>OIT and Basic Certification:</div> <div><div><input type="radio"/> Averaging 6 or more CECs per year.</div><div><input type="radio"/> Averaging less than 6 CECs per year.</div></div> <div>Advanced Certification:</div> <div><div><input checked="" type="radio"/> Averaging 8 or more CECs per year.</div><div><input type="radio"/> Averaging less than 8 CECs per year.</div></div>	

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

# Compliance Maintenance Annual Report

Mauston Wastewater Treatment Facility

Last Updated: Reporting For:  
6/2/2025 2024

## Financial Management

1. Provider of Financial Information			
Name:	<div>Daron Haugh</div>		
Telephone:	<div>608-747-2704</div>	(XXX) XXX-XXXX	
E-Mail Address (optional):	<div>dhaugh@mauston.com</div>		
2. Treatment Works Operating Revenues			
2.1 Are User Charges or other revenues sufficient to cover O&M expenses for your wastewater treatment plant AND/OR collection system ?			
● Yes (0 points) <input type="checkbox"/>			
○ No (40 points)			
If No, please explain:			
<div></div>			
2.2 When was the User Charge System or other revenue source(s) last reviewed and/or revised?			
Year:	<div>2023</div>		0
● 0-2 years ago (0 points) <input type="checkbox"/>			
○ 3 or more years ago (20 points) <input type="checkbox"/>			
○ N/A (private facility)			
2.3 Did you have a special account (e.g., CWFP required segregated Replacement Fund, etc.) or financial resources available for repairing or replacing equipment for your wastewater treatment plant and/or collection system?			
● Yes (0 points)			
○ No (40 points)			
REPLACEMENT FUNDS [PUBLIC MUNICIPAL FACILITIES SHALL COMPLETE QUESTION 3]			
3. Equipment Replacement Funds			
3.1 When was the Equipment Replacement Fund last reviewed and/or revised?			
Year:	<div>2023</div>		
● 1-2 years ago (0 points) <input type="checkbox"/>			
○ 3 or more years ago (20 points) <input type="checkbox"/>			
○ N/A			
If N/A, please explain:			
<div></div>			
3.2 Equipment Replacement Fund Activity			
3.2.1 Ending Balance Reported on Last Year's CMAR		\$	<div>603,219.43</div>
3.2.2 Adjustments - if necessary (e.g. earned interest, audit correction, withdrawal of excess funds, increase making up previous shortfall, etc.)		+	\$ <div>18,456.39</div>
3.2.3 Adjusted January 1st Beginning Balance		\$	<div>621,675.82</div>
3.2.4 Additions to Fund (e.g. portion of User Fee, earned interest, etc.)		+	\$ <div>0.00</div>

# Compliance Maintenance Annual Report

Mauston Wastewater Treatment Facility

Last Updated: Reporting For:  
6/2/2025 2024

3.2.5 Subtractions from Fund (e.g., equipment replacement, major repairs - use description box 3.2.6.1 below*)		-	\$	0.00
3.2.6 Ending Balance as of December 31st for CMAR Reporting Year			\$	621,675.82
All Sources: This ending balance should include all Equipment Replacement Funds whether held in a bank account(s), certificate(s) of deposit, etc.				
3.2.6.1 Indicate adjustments, equipment purchases, and/or major repairs from 3.2.5 above.				
3.3 What amount should be in your Replacement Fund?			\$	602,828.57
Please note: If you had a CWWFP loan, this amount was originally based on the Financial Assistance Agreement (FAA) and should be regularly updated as needed. Further calculation instructions and an example can be found by clicking the SectionInstructions link under Info header in the left-side menu.				
3.3.1 Is the December 31 Ending Balance in your Replacement Fund above, (#3.2.6) equal to, or greater than the amount that should be in it (#3.3)?				
<input checked="" type="radio"/> Yes				
<input type="radio"/> No				
If No, please explain.				

4. Future Planning			
4.1 During the next ten years, will you be involved in formal planning for upgrading, rehabilitating, or new construction of your treatment facility or collection system?			
<input checked="" type="radio"/> Yes - If Yes, please provide major project information, if not already listed below. <input type="checkbox"/> <input type="checkbox"/>			
<input type="radio"/> No			
Project #	Project Description	Estimated Cost	Approximate Construction Year
1	Sewer equipment upgrades and replacement, SCADA update, Lift Station generator,	\$9,000,000	2024

5. Financial Management General Comments	
None	

ENERGY EFFICIENCY AND USE	
6. Collection System	
6.1 Energy Usage	
6.1.1 Enter the monthly energy usage from the different energy sources:	
<b>COLLECTION SYSTEM PUMPAGE: Total Power Consumed</b>	
Number of Municipally Owned Pump/Lift Stations:	12

# Compliance Maintenance Annual Report

Mauston Wastewater Treatment Facility

Last Updated: Reporting For:  
6/2/2025 **2024**

	Electricity Consumed (kWh)	Natural Gas Consumed (therms)
January	27,959	
February	25,565	
March	27,122	
April	24,047	
May	23,954	
June	20,668	
July	20,578	
August	16,597	
September	13,633	
October	21,879	
November	30,734	
December	35,886	
Total	<b>288,622</b>	<b>0</b>
Average	<b>24,052</b>	<b>0</b>

6.1.2 Comments:

## 6.2 Energy Related Processes and Equipment

6.2.1 Indicate equipment and practices utilized at your pump/lift stations (Check all that apply):

- ☒ Comminution or Screening
- ☐ Extended Shaft Pumps
- ☒ Flow Metering and Recording
- ☐ Pneumatic Pumping
- ☒ SCADA System
- ☒ Self-Priming Pumps
- ☒ Submersible Pumps
- ☒ Variable Speed Drives
- ☐ Other:

6.2.2 Comments:

6.3 Has an Energy Study been performed for your pump/lift stations?

☐ No

☒ Yes

Year:

2022

By Whom:

WRWA

Describe and Comment:

Dan Wundrow completed an energy audit in the facility and made recommendations.

# Compliance Maintenance Annual Report

Mauston Wastewater Treatment Facility

Last Updated: Reporting For:  
6/2/2025 2024

## 6.4 Future Energy Related Equipment

6.4.1 What energy efficient equipment or practices do you have planned for the future for your pump/lift stations?

Installing new pumps at the main lift station. New air raiders in the lagoons.

## 7. Treatment Facility

### 7.1 Energy Usage

7.1.1 Enter the monthly energy usage from the different energy sources:

#### TREATMENT PLANT: Total Power Consumed/Month

	Electricity Consumed (kWh)	Total Influent Flow (MG)	Electricity Consumed/ Flow (kWh/MG)	Total Influent BOD (1000 lbs)	Electricity Consumed/ Total Influent BOD (kWh/1000lbs)	Natural Gas Consumed (therms)
January	71,509	12.81	5,582	21.73	3,291	
February	64,162	10.65	6,025	22.19	2,891	
March	68,854	12.27	5,612	28.24	2,438	
April	66,141	14.99	4,412	29.58	2,236	
May	69,508	23.17	3,000	38.97	1,784	
June	61,577	22.34	2,756	33.39	1,844	
July	65,135	32.08	2,030	49.88	1,306	
August	76,560	20.99	3,647	40.86	1,874	
September	61,960	16.25	3,813	33.45	1,852	
October	73,585	16.86	4,364	37.17	1,980	
November	73,333	17.96	4,083	37.95	1,932	
December	77,127	17.56	4,392	36.24	2,128	
Total	829,451	217.93		409.65		0
Average	69,121	18.16	4,143	34.14	2,130	0

#### 7.1.2 Comments:

## 7.2 Energy Related Processes and Equipment

7.2.1 Indicate equipment and practices utilized at your treatment facility (Check all that apply):

- ☐ Aerobic Digestion
- ☐ Anaerobic Digestion
- ☐ Biological Phosphorus Removal
- ☒ Coarse Bubble Diffusers
- ☐ Dissolved O2 Monitoring and Aeration Control
- ☐ Effluent Pumping
- ☒ Fine Bubble Diffusers
- ☒ Influent Pumping
- ☐ Mechanical Sludge Processing
- ☐ Nitrification
- ☒ SCADA System
- ☐ UV Disinfection
- ☐ Variable Speed Drives
- ☐ Other:

# Compliance Maintenance Annual Report

Mauston Wastewater Treatment Facility

Last Updated: Reporting For:  
6/2/2025 2024

<div></div> <div>7.2.2 Comments:</div> <div>None</div> <div>7.3 Future Energy Related Equipment</div> <div>7.3.1 What energy efficient equipment or practices do you have planned for the future for your treatment facility?</div> <div>Installing new pumps at the main lift station. New air raiders in the lagoons.</div>	
<div>8. Biogas Generation</div> <div>8.1 Do you generate/produce biogas at your facility?</div> <div><div><input checked="" type="radio"/> No</div><div><input type="radio"/> Yes</div></div> <div>If Yes, how is the biogas used (Check all that apply):</div> <div><div><input type="checkbox"/> Flared Off</div><div><input type="checkbox"/> Building Heat</div><div><input type="checkbox"/> Process Heat</div><div><input type="checkbox"/> Generate Electricity</div><div><input type="checkbox"/> Other:</div></div> <div></div>	
<div>9. Energy Efficiency Study</div> <div>9.1 Has an Energy Study been performed for your treatment facility?</div> <div><div><input type="radio"/> No</div><div><input checked="" type="radio"/> Yes</div></div> <div><div><input checked="" type="checkbox"/> Entire facility</div><div>Year: 2022</div><div>By Whom: Dan Wundrow</div><div>Describe and Comment:</div><div>We utilized WRWA circuit rider for an energy audit to make recommendations.</div></div> <div><div><input type="checkbox"/> Part of the facility</div><div>Year:</div><div>By Whom:</div><div>Describe and Comment:</div></div>	

# Compliance Maintenance Annual Report

Mauston Wastewater Treatment Facility

Last Updated: Reporting For:  
6/2/2025 2024

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A



# Compliance Maintenance Annual Report

Mauston Wastewater Treatment Facility

Last Updated: Reporting For:

6/2/2025

2024

## Sanitary Sewer Collection Systems

### 1. Capacity, Management, Operation, and Maintenance (CMOM) Program

#### 1.1 Do you have a CMOM program that is being implemented?

☒ Yes

☐ No

If No, explain:

#### 1.2 Do you have a CMOM program that contains all the applicable components and items according to Wisc. Adm Code NR 210.23 (4)?

☒ Yes

☐ No (30 points)

☐ N/A

If No or N/A, explain:

#### 1.3 Does your CMOM program contain the following components and items? (check the components and items that apply)

☒ Goals [NR 210.23 (4)(a)]

Describe the major goals you had for your collection system last year:

Continue collection system replacement  
Lift station improvement

Did you accomplish them?

☒ Yes

☐ No

If No, explain:

☒ Organization [NR 210.23 (4) (b)] ☐ ☐

Does this chapter of your CMOM include:

☒ Organizational structure and positions (eg. organizational chart and position descriptions)

☒ Internal and external lines of communication responsibilities

☒ Person(s) responsible for reporting overflow events to the department and the public

☒ Legal Authority [NR 210.23 (4) (c)]

What is the legally binding document that regulates the use of your sewer system?

City sewer use ordinance

If you have a Sewer Use Ordinance or other similar document, when was it last reviewed and revised? (MM/DD/YYYY) 2017-01-01

Does your sewer use ordinance or other legally binding document address the following:

☒ Private property inflow and infiltration

☒ New sewer and building sewer design, construction, installation, testing and inspection

☐ Rehabilitated sewer and lift station installation, testing and inspection

☒ Sewage flows satellite system and large private users are monitored and controlled, as necessary

☒ Fat, oil and grease control

☒ Enforcement procedures for sewer use non-compliance

☒ Operation and Maintenance [NR 210.23 (4) (d)]

Does your operation and maintenance program and equipment include the following:

☐ Equipment and replacement part inventories

☒ Up-to-date sewer system map

# Compliance Maintenance Annual Report

Mauston Wastewater Treatment Facility

Last Updated: Reporting For:  
6/2/2025 2024

☐ A management system (computer database and/or file system) for collection system information for O&M activities, investigation and rehabilitation

☒ A description of routine operation and maintenance activities (see question 2 below)

☐ Capacity assessment program

☐ Basement back assessment and correction

☐ Regular O&M training

☒ Design and Performance Provisions [NR 210.23 (4) (e)] ☐ ☐

What standards and procedures are established for the design, construction, and inspection of the sewer collection system, including building sewers and interceptor sewers on private property?

☒ State Plumbing Code, DNR NR 110 Standards and/or local Municipal Code Requirements

☒ Construction, Inspection, and Testing

☐ Others:

☒ Overflow Emergency Response Plan [NR 210.23 (4) (f)] ☐ ☐

Does your emergency response capability include:

☒ Responsible personnel communication procedures

☐ Response order, timing and clean-up

☒ Public notification protocols

☐ Training

☒ Emergency operation protocols and implementation procedures

☐ Annual Self-Auditing of your CMOM Program [NR 210.23 (5)] ☐ ☐

☐ Special Studies Last Year (check only those that apply):

☐ Infiltration/Inflow (I/I) Analysis

☐ Sewer System Evaluation Survey (SSES)

☐ Sewer Evaluation and Capacity Management Plan (SECAP)

☐ Lift Station Evaluation Report

☐ Others:

0

## 2. Operation and Maintenance

2.1 Did your sanitary sewer collection system maintenance program include the following maintenance activities? Complete all that apply and indicate the amount maintained.

Cleaning  % of system/year

Root removal  % of system/year

Flow monitoring  % of system/year

Smoke testing  % of system/year

Sewer line televising  % of system/year

Manhole inspections  % of system/year

Lift station O&M  # per L.S./year

Manhole rehabilitation  % of manholes rehabbed

Mainline rehabilitation  % of sewer lines rehabbed

Private sewer inspections  % of system/year

# Compliance Maintenance Annual Report

Mauston Wastewater Treatment Facility

Last Updated: Reporting For:

6/2/2025

2024

Private sewer I/I removal  % of private services

River or water crossings  % of pipe crossings evaluated or maintained

Please include additional comments about your sanitary sewer collection system below:

## 3. Performance Indicators

3.1 Provide the following collection system and flow information for the past year.

<input type="text" value="44.26"/>	Total actual amount of precipitation last year in inches
<input type="text" value="34"/>	Annual average precipitation (for your location)
<input type="text" value="27"/>	Miles of sanitary sewer
<input type="text" value="12"/>	Number of lift stations
<input type="text" value="0"/>	Number of lift station failures
<input type="text" value="0"/>	Number of sewer pipe failures
<input type="text" value="0"/>	Number of basement backup occurrences
<input type="text" value="0"/>	Number of complaints
<input type="text" value=".593"/>	Average daily flow in MGD (if available)
<input type="text" value="31.93"/>	Peak monthly flow in MGD (if available)
<input type="text" value="0"/>	Peak hourly flow in MGD (if available)

3.2 Performance ratios for the past year:

<input type="text" value="0.00"/>	Lift station failures (failures/year)
<input type="text" value="0.00"/>	Sewer pipe failures (pipe failures/sewer mile/yr)
<input type="text" value="0.00"/>	Sanitary sewer overflows (number/sewer mile/yr)
<input type="text" value="0.00"/>	Basement backups (number/sewer mile)
<input type="text" value="0.00"/>	Complaints (number/sewer mile)
<input type="text" value="53.8"/>	Peaking factor ratio (Peak Monthly:Annual Daily Avg)
<input type="text" value="0.0"/>	Peaking factor ratio (Peak Hourly:Annual Daily Avg)

## 4. Overflows

### LIST OF SANITARY SEWER (SSO) AND TREATMENT FACILITY (TFO) OVERFLOWS REPORTED \*\*

Date	Location	Cause	Estimated Volume
------	----------	-------	------------------

None reported

\*\* If there were any SSOs or TFOs that are not listed above, please contact the DNR and stop work on this section until corrected.

## 5. Infiltration / Inflow (I/I)

5.1 Was infiltration/inflow (I/I) significant in your community last year?

☐ Yes

☒ No

If Yes, please describe:

5.2 Has infiltration/inflow and resultant high flows affected performance or created problems in your collection system, lift stations, or treatment plant at any time in the past year?

☐ Yes

# Compliance Maintenance Annual Report

Mauston Wastewater Treatment Facility

Last Updated: Reporting For:  
6/2/2025 2024

<ul style="list-style-type: none"><li>● No</li></ul> <p>If Yes, please describe:</p> <div></div> <p>5.3 Explain any infiltration/inflow (I/I) changes this year from previous years:</p> <div>sewer manhole cover inlet repairs found during inspections.</div> <p>5.4 What is being done to address infiltration/inflow in your collection system?</p> <div>collection system upgrade and sump pump connection locations</div>	
---	--

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

# Compliance Maintenance Annual Report

Mauston Wastewater Treatment Facility

Last Updated: Reporting For:  
6/2/2025 2024

## Grading Summary

WPDES No: 0024635

SECTIONS	LETTER GRADE	GRADE POINTS	WEIGHTING FACTORS	SECTION POINTS
Influent	A	4	3	12
BOD/CBOD	A	4	10	40
TSS	A	4	5	20
Ammonia	A	4	5	20
Phosphorus	A	4	3	12
Ponds	B	3	7	21
Biosolids	A	4	5	20
Staffing/PM	A	4	1	4
OpCert	A	4	1	4
Financial	A	4	1	4
Collection	A	4	3	12
TOTALS			44	169
GRADE POINT AVERAGE (GPA) = 3.84				

Notes:

- A = Voluntary Range (Response Optional)
- B = Voluntary Range (Response Optional)
- C = Recommendation Range (Response Required)
- D = Action Range (Response Required)
- F = Action Range (Response Required)

# Compliance Maintenance Annual Report

Mauston Wastewater Treatment Facility

Last Updated:    Reporting For:  
6/2/2025                      **2024**

## Resolution or Owner's Statement

Name of Governing Body or Owner:	<div></div>
Date of Resolution or Action Taken:	<div></div>
Resolution Number:	<div></div>
Date of Submittal:	

**ACTIONS SET FORTH BY THE GOVERNING BODY OR OWNER RELATING TO SPECIFIC CMAR SECTIONS (Optional for grade A or B. Required for grade C, D, or F):**

Influent Flow and Loadings: Grade = A

Effluent Quality: BOD: Grade = A

Effluent Quality: TSS: Grade = A

Effluent Quality: Ammonia: Grade = A

Effluent Quality: Phosphorus: Grade = A

Ponds: Grade = B

Biosolids Quality and Management: Grade = A

Staffing: Grade = A

Operator Certification: Grade = A

Financial Management: Grade = A

Collection Systems: Grade = A  
(Regardless of grade, response required for Collection Systems if SSOs were reported)

**ACTIONS SET FORTH BY THE GOVERNING BODY OR OWNER RELATING TO THE OVERALL GRADE POINT AVERAGE AND ANY GENERAL COMMENTS**  
(Optional for G.P.A. greater than or equal to 3.00, required for G.P.A. less than 3.00)  
**G.P.A. = 3.84**