



Calculation Summary							
Label	CalcType	Units	Avg	Max	Min	Avg/Min	Max/Min
SIGN_Face	Illuminance	Fc	3.51	4.2	2.7	1.30	1.56
SITE	Illuminance	Fc	0.52	8.0	0.0	N.A.	N.A.

Luminaire Schedule								
Symbol	Qty	Label	Manufacturer	Description	Arrangement	Lum. Lumens	Lum. Watts	LLF
	13	OD	PRESCOLITE	LBRST-6RD-M-LSML-CS9-WH	Single	1227	13.33	0.900
	4	OF	EXO	LSP-LSCS (1000LM, 4000K)	Single	1015	7.92	0.900
	5	OP1	EXO	ASL1-160L-135-4K7-4W-UNV	Single	17568	133.1	0.900
	2	OW1	BEACON	RWL2-160L-115-4K7-3-UNV	Single	15281	109.8	0.900
	3	OW2	BEACON	RWL1-48L-25-4K7-4W-UNV	Single	3679	28	0.900

1. Lighting Reflectance of 80/50/20 used unless noted otherwise
2. Interior calc points shown at 30° A.F.F. unless noted otherwise
3. Exterior calc points shown at grade unless noted otherwise
4. Emergency egress calc points shown at 0° A.F.F.
5. Photometric drawings are for Design purposes only,
not for Construction documents