City of McCleary

STAFF REPORT

To:	Mayor and Council
From:	Joe Pittman
Date:	10/21/2026
Department:	WWTP/WTP

Both water and wastewater plants are running smoothly. We did get a hit on the 18th of high flows out of nowhere. A normal day now is 100k gallons a day, on the 18th ,19th and 20th we received over 700K gallons of influent. Which puts the plant in a bit of turmoil but is recovering.

The new depth sensor was installed in the Water reservoir and is working fine. The change over from radio signal to hard wire is taking longer than anticipated due to TSI scheduling techs to come out and do the job.