



1/18/2024

City of McCleary
ATTN: Kevin Trehwella
700 W. Maple St.
McCleary, WA 98557

GENERATOR MAINTENACE PROPOSAL

SCOPE:

SEMI ANNUAL

- Verify fuel supply/level
- Visual inspection for oil, coolant or fuel leaks
- Inspect all hoses, clamps and drive belts for cracking or wear
- Inspect exhaust system for leaks/corrosion
- Test coolant and adjust level if necessary; parts included
- Test coolant system and check for leaks
- Check engine block heater operation
- Check battery charger operation and charging rate
- Load test batteries, check specific gravity and clean and treat terminals
- Check generator voltage and adjust as necessary to match utility voltage
- Check emergency system without load
- Check frequency and governor operation adjusting as necessary
- Check engine alternator and charge rate
- Check gauges and meters for proper operation and reading levels
- Check generator auto shutdown and alarms
- Inspect automatic transfer switch
- With managerial approval, interrupt utility power and test transfer switches and generator for full building load functionality.
- Inspect for any rodent issues and make recommendations
- Provide detailed summary of maintenance performed noting any issues

ANNUAL

Semiannual maintenance in addition to:

- Oil and filters change; parts included
- Service or replace air filters if necessary; parts not included
- Replace fuel filters (when applicable); parts included
- Replace coolant filters (when applicable); parts included

LOAD BANK

- Legacy provided portable resistive load bank
- All cabling and connections required
- Standard load bank test of 80% name plate capacity unless otherwise noted/requested
- Reporting in 15-minute intervals
- Complete load bank test report provided



LEGACY
POWER SYSTEMS

EQUIPEMENT:

1. UNIT ID: Wastewater Treatment Plant
KW: 350KW MQ Power
Model: KD350
Serial: 16120 1-1

Total for annual preventative maintenance.....\$1,325.00
Total for semiannual preventative maintenance.....\$ 450.00
2 Hour Load Bank.....\$1,250.00
Fuel Sampling and Testing.....\$ 475.00

2. UNIT ID: Water Treatment Plant
KW: 150KW Kohler
Model: 150REOZJF
Serial: 3379GMKD0004

Total for annual preventative maintenance.....\$1,100.00
Total for semiannual preventative maintenance.....\$ 450.00
2 Hour Load Bank.....\$1,000.00
Fuel Sampling and Testing.....\$ 475.00

3. UNIT ID: City Hall
KW: 60KW Kohler
Model: 60REOZK
Serial: 33HMGMKC0008

Total for annual preventative maintenance.....\$ 875.00
Total for semiannual preventative maintenance.....\$ 450.00
2 Hour Load Bank.....\$ 925.00
Fuel Sampling and Testing.....\$ 475.00

4. UNIT ID: Public Works
KW: 50KW Kohler
Model: 50REOZK
Serial: 33H3GMKD0008

Total for annual preventative maintenance.....\$ 875.00
Total for semiannual preventative maintenance.....\$ 450.00
2 Hour Load Bank.....\$ 925.00
Fuel Sampling and Testing.....\$ 475.00



LEGACY
POWER SYSTEMS

- All work is assumed to be completed during regular business hours.
- Washington state requires a licensed electrician to make connections and disconnections of the cables for load banking. Pricing includes the cost of the electrician and the permit.
- Fuel can be provided at an additional cost.

Payment/Default: Upon Credit Approval, Applicant agrees: To pay invoices in full within 30 days from invoice date. If any amount owed to Legacy Power Systems is not paid when due, Legacy Power Systems may at its option: place the account on C.O.D., terminate any unfilled orders, or discontinue any service until the account is current.

Signed:

Chad Bedlington

Printed:

Chad Bedlington

Date:

2/1/24

AP contact information required:

Name *Kevin Trewbella*

Phone *360-521-2058*

Email *Kevin.t@cityofmccleary.com*

Thank you for the opportunity to provide a quote for your power generation needs.

Sam Bergstrom

O: (253) 858-0214 | **24Hr:** (253) 686-3050 | **C:** (253)225-0783

Legacy Power Systems | www.LegacyPower.com