



City of McCleary

STAFF REPORT

To:	Mayor Miller and City Council
From:	Kevin Trehwella
Date:	June, 2025
Department:	Water and Wastewater

Wastewater

On June 5, USC brought their boom truck and installed Effluent Pump #3. They also helped us by lifting the repaired piping and manifold back into place so that we can put the grit system back together. Both these systems work like they're supposed to.

The internal heater for the UV controls stopped working. The heater was ordered and installed on Friday, June 27.

The replacement pump for the influent has arrived and will be installed soon. There is some concrete work to be done at the splitter box on SBR #2. Mid July when the flows are at their lowest, we will begin that project.

Currently, work on the control panel at the Simpson lift station is ongoing.

Water

The Variable Frequency Drives (VFD's) that were installed, last year, out at the wells, are saving the city of McCleary about 1000 kilowatts a month.

Kevin Trehwella