

UTILITIES SERVICE CO., INC.
12608 E MARGINAL WAY S
SEATTLE, WA 98168

PHONE: 206-246-5674
FAX: 206-248-3410
EMAIL: usci4@comcast.net

Date: 10/6/2026

Attn: Joe Pittman
City of McCleary
Re: Effluent Pump

We are pleased to submit the following information for your review:

Service call to remove effluent pump and deliver to our shop for inspection. Disassembled motor, checked all bearing housing and shaft fits. Cleaned and revarnished stator windings, supplied and installed new bearings, assembled and tested.

Dissembled pump and found broken seal. Removed impellers from bowl assembly and found severe wear in the bowl castings.

Findings: Pump cannot be repaired, we would supply new bowl assembly and reassemble unit, deliver to site, install and connect electrically, set impellers to proper specs and test for proper operations.

Total materials & labor: \$34,000.

This estimate is good for 30 days and does not include taxes, permits, or shipping and handling if needed. This job is bid as close to actual requirements as possible; however, due to the nature of this particular job, additional work may be needed for unforeseen circumstances. Customer will be notified when additional work is identified and estimated for approval. Additional work will be billed at our current labor rates and additional materials at cost plus 15%.

Thank you.

Ed Mola
Estimator

Please indicate acceptance by completing the information requested below and faxing or emailing estimate back to us. Thank you.

Date _____ Accepted By _____

PO # _____ Title _____