

Charter Township of Madison
Department of Public works
April 2025

- Water usage for the month of April was 9.2 million gallons.
- Sewer usage for the month of April was 12.0 million gallons.
- Water usage for Fairfield Twp. for the month of April was 1.3 million gallons.

Operations

- Work orders for the month of April were (26).
- Miss Digs for the month of April was (68). All Miss Digs were reviewed and serviced as needed.
- Water meters were read, and all work orders were completed.
- All sewer reads for the month of April were submitted to the City of Adrian.
- Lift stations and generators were inspected for the month of April.
- Monthly operating report submitted to EGLE.
- Backwashing of iron filter as necessary.
- Monthly Drinking water sampling has been completed.
- Wastewater discharge sampling at water treatment plant.
- The Annual Drinking Water Sampling has been completed.

Communications

- The DPW had a watermain break on Monday April 5th on Parr Hwy Between Fairlawn and Drexel Blvd. the water main was excavated and repaired the same day with minimal service disruptions.
- On April 2nd heavy rainfall contributed to a sanitary sewer backup on Cadmus Road, between Baldwin Hwy and US 223 an unknown partial obstruction was cleaned from the line after Jetting the sewer main.
- Hydrant and water main Flushing is scheduled for April 28th -May 30th, 2025, this includes Madison and Fairfield townships.
- The Madison township water tower is scheduled to be cleaned and painted, a date official date has not been determined but most likely will be in May or early June.

Submitted by Tim Watterson
Department of public works Superintendent