



Charter Township of Madison

Department of Public works

June 2025

Water and Sewer Usage

- Water usage for the month of June was 10.0 million gallons.
- Sewer usage for the month of June was 9.9 million gallons.
- Water usage for Fairfield Twp. for the month of June was 1.3 million gallons.

Operations

- Work orders for the month of June were (38).
- Miss Digs for the month of June was (56). All Miss Digs were reviewed and serviced as needed.
- Water meters were read, and all work orders were completed.
- All sewer reads for the month of June were submitted to the City of Adrian.
- Lift stations and generators were inspected for the month of June.
- Monthly operating report submitted to EGLE.
- Backwashing of iron filter as necessary.
- Monthly Drinking water sampling has been completed.
- Wastewater discharge sampling at water treatment plant.

Communications

- The Madison township Water tower was taken out of service on June 13th for maintenance and painting. The tower was drained, the inside of the tank was cleaned and inspected, the exterior was cleaned and repainted. The township logo was painted on the exterior of the tank replacing the old block lettering that was in place.
- The Dpw is working on updating pricing for the capital improvement plan for the water and sewer system. while we already have pricing and estimates from previous years but would like to have them updated.
- The Dpw collected routine water samples in June in accordance with our 2025 Monitoring schedule issued annually by the EGLE, more sampling is scheduled in July and will continue until the end of September.
- The Dpw published the annual water quality report for 2024 in the Adrian daily telegram newspaper on 6/20/2025.

Submitted by Tim Watterson
Department of public works Superintendent