

Charter Township of Madison

Department of Public works

February 2025

- Water usage for the month of February was 10.1 million gallons.
- Sewer usage for the month of February was 9.8 million gallons.
- Water usage for Fairfield Twp. for the month of February was 1.9 million gallons.

Operations

- Work orders for the month of February were (33).
- Miss Digs for the month of February was (94). All Miss Digs were reviewed and serviced as needed.
- Water meters were read, and all work orders were completed.
- All sewer reads for the month of February were submitted to the City of Adrian.
- Lift stations and generators were inspected for the month of February.
- Monthly operating report submitted to EGLE.
- Backwashing of iron filter as necessary.
- Monthly Drinking water sampling has been completed.
- Wastewater discharge sampling at water treatment plant.
- The Annual Drinking Water Sampling has been completed.

Communications

- The Dpw had a water main break in Jasper on M-52 in Jasper across the street from the post office. The main was excavated and repaired.
- The Dpw responded to a water main break at the intersection of Balwin Hwy and Eunice Circle. The Break was isolated, and water re-routed while the main awaits repair next week.
- DPW employees participated in a online briefing from the EPA and FBI regarding cybersecurity related to water systems throughout the US.
- The replacement water meter for Fairfield Township has been ordered, we should receive it by the end of April.

Submitted by Tim Watterson
Department of public works Superintendent