



Charter Township of Madison

Department of Public works

May 2026

Water and Sewer Usage

- Water usage for the month of was May 8.4 million gallons.
- Sewer usage for the month of was May 9.8 million gallons.
- Water usage for Fairfield Twp. for the month of May was 1.3 million gallons.

Operations

- Work orders for the month of May were (44)
- Miss Digs for the month of May was (96) All Miss Digs were reviewed and serviced as needed.
- Water meters were read, and all work orders were completed.
- All sewer reads for the month of May were submitted to the City of Adrian.
- Lift stations and generators were inspected for the month of May.
- Monthly operating report submitted to EGLE.
- Backwashing of iron filter as necessary.
- Monthly Drinking water sampling has been completed.
- Wastewater discharge sampling at water treatment plant.

Communications

- New water filter at the WTP was put into service and is working well, we have closely monitored the new the filters operation and performance and have already saw a reduction of Iron being removed by the filter, work continues as the removal of the old filter is underway in preparation for the installation of the second new filter we are hoping to see the work completed by the end of June or early July.
- Watermain and Hydrant flushing is underway and will continue until June 26th, 2026. The schedule includes both Madison and Fairfield Townships.
- J&K from Jackson Mi, Continues annual preventative maintenance inspections at each of the townships sewer lift stations, this includes pulling and inspections of sewer pumps and a long list of annual check list items we will receive a report on after its completion.