

**Charter Township of Madison**  
**Department of Public works**  
**May 2025**

- Water usage for the month of May was 10.6 million gallons.
- Sewer usage for the month of May was 11.3 million gallons.
- Water usage for Fairfield Twp. for the month of May was 1.4 million gallons.

**Operations**

- Work orders for the month of May were (35).
- Miss Digs for the month of May was (74). All Miss Digs were reviewed and serviced as needed.
- Water meters were read, and all work orders were completed.
- All sewer reads for the month of May were submitted to the City of Adrian.
- Lift stations and generators were inspected for the month of May.
- Monthly operating report submitted to EGLE.
- Backwashing of iron filter as necessary.
- Monthly Drinking water sampling has been completed.
- Wastewater discharge sampling at water treatment plant.
- The Annual Drinking Water Sampling has been completed.

**Communications**

- Hydrant and water main flushing has been completed for Madison and Fairfield Townships.
- The Public Works Department had a Watermain Break on Taylor Dr off Baldwin Hwy in May that occurred in the overnight hours. The Break was isolated and related repairs were made the following morning.
- A sanitary sewer manhole off Taylor drive in a wooded area was repaired and was brought up to grade to prevent any groundwater infiltration that may have been occurring.
- Water Tower cleaning and painting will begin on June 12<sup>th</sup>, 2025. The Water tower will most likely be taken out of service the beginning on the 16<sup>th</sup>.

**Submitted by Tim Watterson**  
**Department of public works Superintendent**