



MEMO TO CITY COUNCIL

Request to Include Topic on the City Council Agenda

From: Keith Watts **Meeting Date:** 1/6/2026
Presenter: Consent **Estimated Time:** N/A
Topic: Approval of Sole Source for Raedlinger Primus Liner Products

Recommended Council Action:

Approval of Sole Source equipment to be included in a construction bid for Radlinger Primus Line and related equipment and associated parts and fittings, accessories and installation services from Raedlinger Primus Line, Inc. Competitive solicitation is impractical, disadvantageous or unreasonable under the circumstances.

Background:

The City is in need of a water main liner to be pulled inside an existing water main with several bends. The City has identified only one supplier that can provide a PVC and Kevlar liner that can be pulled inside the existing water mains with several bends and still maintain full water system pressure of 60-150 PSI without excavating across Eagle Road. For this reason, Primus Liner has been integrated into the plans and specifications of the Eagle Road Water Crossing project.

This equipment will be purchased by the City's Contractor for the Eagle Water Crossings Project.