

STAFF REPORT
COMMUNITY DEVELOPMENT DEPARTMENT




HEARING DATE: 10/11/2022

TO: Mayor & City Council

FROM: Joseph Dodson, Associate Planner
208-884-5533

SUBJECT: FP-2022-0027
Alamar Subdivision FP

LOCATION: 4380 W. Franklin Road, approximately
1/4 east of N. Black Cat on the north side
of Franklin, in the SE 1/4 of the SW 1/4
of Section 10, Township 3N, Range 1W.



I. PROJECT DESCRIPTION

Final Plat request for Phase 1 development to include 17 single-family detached building lots, 10 single-family attached building lots, and 4 common lots on approximately 3.71 acres of land in the TN-R zoning district, by Jeff Wrede, Noble Rock Development Inc.

II. APPLICANT INFORMATION

A. Owner/Applicant:

Jeff Wrede, Noble Rock Development Inc – 13601 W. McMillan Road, Ste. 102-162, Meridian, ID 83642


B. Design Professional:

Derritt Kerner, Rock Solid Civil – 270 N. 27th Street, Boise, ID 83702


III. STAFF ANALYSIS

Staff has reviewed the proposed final plat for substantial compliance with the approved preliminary plat (H-2022-0005) as required by UDC 11-6B-3C.2. The submitted plat includes the same number of buildable lots permitted for phase 1 as outlined in the conditions of approval for the preliminary plat. Furthermore, the submitted final plat depicts the required street buffer to Franklin, parkways, temporary access to Franklin, and the correct amount of common open space as previously approved for this phase.

Staff finds the proposed final plat is in substantial compliance with the approved preliminary plat as required.



B. Final Plat (date: 8/5/2022)



C. Landscape Plans (date: 8/8/2022)



VI. CITY/AGENCY COMMENTS & CONDITIONS

A. Planning Division

Site Specific Conditions:

1. Applicant shall comply with all previous conditions of approval associated with this development: H-2022-0004 (AZ, PP, DA Inst. #2022-065010).
2. The applicant shall obtain the City Engineer's signature on the final plat by June 21, 2024, within two (2) years of the date of approval of the preliminary plat findings (June 21, 2022), in accord with UDC 11-6B-7, in order for the preliminary plat to remain valid or a time extension may be requested.
3. Prior to submittal for the City Engineer's signature, have the Certificate of Owners and the accompanying acknowledgement signed and notarized.
4. Prior to building permit submittal, Administrative Design Review approval is required for the single-family attached lots within this phase of development (Lots 14-17, Block 1, & Lots 1-6, Block 3).
5. The final plat shown in Section V.B, prepared by Engerbritson Land Surveys, stamped on 8/5/22 by Michael R. Engerbritson, is approved with the following conditions to be completed at the time of Final Plat Signature:
 - a. Revise plat note #11 referencing the Development Agreement to start with: "The Lots in this subdivision are subject to provisions contained within...";
 - b. Plat note #6: add recorded instrument number.
 - c. Plat note #7: add recorded instrument number.
 - d. Plat note #12: add recorded instrument number.
6. The submitted landscape plans, as shown in Section V.C, prepared by Rock Solid Civil, dated 8/8/22, is approved with the following conditions to be completed at the time of Final Plat Signature:
 - a. Add a note or calculation table line item depicting the linear feet of parkway and the required and proposed number of trees showing compliance with UDC 11-3B-7C.
7. Staff's failure to cite specific ordinance provisions or conditions from the preliminary plat and/or development agreement does not relieve the Applicant of responsibility for compliance.

B. PUBLIC WORKS

Site Specific Conditions of Approval

1. Existing water main into site has a blow-off valve. Callout removal of the blow-off.
2. Make sure there are no gaps between the utility easement and the ROW.
3. Blow-off at north and east end of phase (page 6 and 7) must be per standard drawing W13.
4. City would prefer SSMH-A2 to tie-in directly to existing manhole on Franklin Rd.
5. Sewer easement varies depending on sewer depth. Sewer 0-15 ft deep require a 20 ft easement, 16-20 ft a 30 ft easement, and 21-30 ft a 40 ft easement. Adjust easements accordingly. Sewer must be centered along easement.

6. Ensure no permanent structures (trees, bushes, buildings, carports, trash receptacle walls, fences, infiltration trenches, light poles, etc.) are built within the utility easement.
7. Ensure no sewer services pass through infiltration trenches.
8. As noted in the Geotechnical Engineering Report prepared by Atlas Materials Testing & Inspection, there are shallow cemented soils across the site. Particular attention needs to be focused on ensuring that all residences constructed with crawl spaces should be designed in a manner that will inhibit water in crawl spaces. This may include the installation of foundation drains, and the installation of rain gutters and roof drains that will carry storm water at least 10-feet away from all residences. Foundation drains are not allowed to drain into the sanitary sewer system, nor the trench backfill for the sewer and/or water service lines.

General Conditions of Approval

1. Applicant shall coordinate water and sewer main size and routing with the Public Works Department, and execute standard forms of easements for any mains that are required to provide service outside of a public right-of-way. Minimum cover over sewer mains is three feet, if cover from top of pipe to sub-grade is less than three feet then alternate materials shall be used in conformance of City of Meridian Public Works Departments Standard Specifications.
2. Per Meridian City Code (MCC), the applicant shall be responsible to install sewer and water mains to and through this development. Applicant may be eligible for a reimbursement agreement for infrastructure enhancement per MCC 8-6-5.
3. The applicant shall provide easement(s) for all public water/sewer mains outside of public right of way (include all water services and hydrants). The easement widths shall be 20-feet wide for a single utility, or 30-feet wide for two. The easements shall not be dedicated via the plat, but rather dedicated outside the plat process using the City of Meridian's standard forms. The easement shall be graphically depicted on the plat for reference purposes. Submit an executed easement (on the form available from Public Works), a legal description prepared by an Idaho Licensed Professional Land Surveyor, which must include the area of the easement (marked EXHIBIT A) and an 8 1/2" x 11" map with bearings and distances (marked EXHIBIT B) for review. Both exhibits must be sealed, signed and dated by a Professional Land Surveyor. DO NOT RECORD. Add a note to the plat referencing this document. All easements must be submitted, reviewed, and approved prior to development plan approval.
4. The City of Meridian requires that pressurized irrigation systems be supplied by a year-round source of water (UDC 11-3B-6). The applicant should be required to use any existing surface or well water for the primary source. If a surface or well source is not available, a single-point connection to the culinary water system shall be required. If a single-point connection is utilized, the developer will be responsible for the payment of assessments for the common areas prior to receiving development plan approval.
5. All existing structures that are required to be removed shall be prior to signature on the final plat by the City Engineer. Any structures that are allowed to remain shall be subject to evaluation and possible reassignment of street addressing to be in compliance with MCC.
6. All irrigation ditches, canals, laterals, or drains, exclusive of natural waterways, intersecting, crossing or laying adjacent and contiguous to the area being subdivided shall be addressed per UDC 11-3A-6. In performing such work, the applicant shall comply with Idaho Code 42-1207 and any other applicable law or regulation.
7. Any wells that will not continue to be used must be properly abandoned according to Idaho Well Construction Standards Rules administered by the Idaho Department of Water Resources. The Developer's Engineer shall provide a statement addressing whether there are any existing wells in the development, and if so, how they will continue to be used, or provide record of their abandonment.

8. Any existing septic systems within this project shall be removed from service per City Ordinance Section 9-1-4 and 9 4 8. Contact Central District Health for abandonment procedures and inspections (208)375-5211.
9. Street signs are to be in place, sanitary sewer and water system shall be approved and activated, road base approved by the Ada County Highway District and the Final Plat for this subdivision shall be recorded, prior to applying for building permits.
10. A letter of credit or cash surety in the amount of 110% will be required for all uncompleted fencing, landscaping, amenities, etc., prior to signature on the final plat.
11. All improvements related to public life, safety and health shall be completed prior to occupancy of the structures. Where approved by the City Engineer, an owner may post a performance surety for such improvements in order to obtain City Engineer signature on the final plat as set forth in UDC 11-5C-3B.
12. Applicant shall be required to pay Public Works development plan review, and construction inspection fees, as determined during the plan review process, prior to the issuance of a plan approval letter.
13. It shall be the responsibility of the applicant to ensure that all development features comply with the Americans with Disabilities Act and the Fair Housing Act.
14. Applicant shall be responsible for application and compliance with any Section 404 Permitting that may be required by the Army Corps of Engineers.
15. Developer shall coordinate mailbox locations with the Meridian Post Office.
16. Compaction test results shall be submitted to the Meridian Building Department for all building pads receiving engineered backfill, where footing would sit atop fill material.
17. The design engineer shall be required to certify that the street centerline elevations are set a minimum of 3-feet above the highest established peak groundwater elevation. This is to ensure that the bottom elevation of the crawl spaces of homes is at least 1-foot above.
18. The applicants design engineer shall be responsible for inspection of all irrigation and/or drainage facility within this project that do not fall under the jurisdiction of an irrigation district or ACHD. The design engineer shall provide certification that the facilities have been installed in accordance with the approved design plans. This certification will be required before a certificate of occupancy is issued for any structures within the project.
19. At the completion of the project, the applicant shall be responsible to submit record drawings per the City of Meridian AutoCAD standards. These record drawings must be received and approved prior to the issuance of a certification of occupancy for any structures within the project.
20. A street light plan will need to be included in the civil construction plans. Street light plan requirements are listed in section 6-5 of the Improvement Standards for Street Lighting. A copy of the standards can be found at http://www.meridiancity.org/public_works.aspx?id=272.
21. The City of Meridian requires that the owner post to the City a performance surety in the amount of 125% of the total construction cost for all incomplete sewer, water and reuse infrastructure prior to final plat signature. This surety will be verified by a line item cost estimate provided by the owner to the City. The surety can be posted in the form of an irrevocable letter of credit, cash deposit or bond. Applicant must file an application for surety, which can be found on the Community Development Department website. Please contact Land Development Service for more information at 887-2211.
22. The City of Meridian requires that the owner post to the City a warranty surety in the amount of 20% of the total construction cost for all completed sewer, water and reuse infrastructure for duration of two years. This surety will be verified by a line item cost estimate provided by the owner to the City. The surety can be posted in the form of an irrevocable letter of credit, cash deposit or bond. Applicant must file an application for surety, which can be found on the Community Development Department website. Please contact Land Development Service for more information at 887-2211.