


STAFF REPORT
COMMUNITY DEVELOPMENT DEPARTMENT



HEARING DATE: 4/26/2022
TO: Mayor & City Council
FROM: Alan Tiefenbach, Associate Planner
208-498-0573
SUBJECT: SHP-2022-0005
Katsura Subdivision Short Plat
LOCATION: Lot 2, Block 2 of the Medimont Subdivision No. 1, and 225 and 335 S. Locust Grove Rd.



I. PROJECT DESCRIPTION

The Applicant proposes a Short Plat to create one buildable lot and two common lots on approximately 3.8 acres in the I-L zoning district.

II. APPLICANT INFORMATION

A. Applicant / Representative:

Kent Brown Planning Services – 3161 E. Springwood Dr, Meridian, ID 83642

B. Owner:

Banks Group, LC – PO Box 65970, Salt Lake City, UT, 84165

III. NOTICING

	City Council Posting Date
Newspaper Notification	04/10/2022
Radius notification mailed to properties within 500 feet	04/11/2022

IV. STAFF ANALYSIS

In November of 2021, the City Council approved the annexation of 3.5 acres of unplatted property with the I-L zoning district. The purpose of this annexation was for the construction of a 67,000 sq. ft. warehouse as an expansion of the existing Intermountain Wood Products business at 300 and 330 S. Adkins Way (directly to the west).

The existing Intermountain Wood Products buildings are within the Medimont Subdivision Development Agreement, which was approved in 1997 (Inst. 97072405). Provision 4d requires a permanent 20-foot-wide landscaped planting strip along the east boundary landscaped with 6-8-foot-high scotch pines at a maximum distance of 15 ft. each. This was to provide a screen for the adjacent residential properties. The landscape buffer was platted into Common Lot 2, Block 2 of the Medimont Subdivision No 1 and is owned and maintained by the Stonebridge Owners Association.

In February of 2021, the portion of the common lot between the existing business and the parcels that were to be annexed were deeded to the applicant, and the applicant removed all the required trees within this area in anticipation of the expansion. After being informed this was not in compliance with the approved DA, the applicant requested a modification to the development agreement to allow the merging of this portion of the landscape buffer into the warehouse property. The Council approved the DA Mod with a condition of approval that required replacement of the trees that were removed as part of the subsequent warehouse CZC. A short plat to complete this merger was a condition of approval of the annexation. This will result in one buildable lot, and two remaining portions of the common lot still owned by the Stonebridge Owners Association for a buffer between the remaining properties. The Certificate of Zoning Compliance was recently completed (CZC A-2022-0040) and an updated landscape plan was addressed as part of the CZC.

Staff has reviewed the requested short plat proposal and has determined that it meets the criteria for approval per UDC 11-6B-5.


V. DECISION

A. Staff:

Staff recommends approval of the proposed short plat with the conditions noted in Section VII of this report.

VI. EXHIBITS

A. Existing Medimont Subdivision No 1 Plat Showing Common Lot



KATSURA SUBDIVISION

A RESUBDIVISION OF LOT 2, BLOCK 2, MEDMONT SUBDIVISION NO. 1 &
A PORTION OF THE NE 1/4 OF THE NE 1/4 OF SECTION 18,
TOWNSHIP 3 NORTH, RANGE 1 EAST, BOISE MERIDIAN,
CITY OF MERIDIAN - COUNTY OF ADA - STATE OF IDAHO
2022

UNPLATTED

E. FRANKLIN RD.

P.L.S. 5291
INST. NO. 10416995

NOTES:

- 1) A TEN (10) DRAINAGE LINES, UNL. PUBLIC UTILITY
- 2) ANY RE-SURVEY REGULATION
- 3) IRRIGATION DISTRICT IN SUBDIVISION OBLIGATED DISTRICT
- 4) A TWENTY MERIDIAN
- 5) A TWENTY INST. NO. 10416995
- 6) ALL LOTS POWER EAS. COUNTY, ID
- 7) A CROSS A RECORDED
- 8) LOT 2, BLK. RECORDED

E. KALISPELL ST.

RECORD OF SURVEY NO. 7075
BOOK 105, PAGES 1408B-1408D
WELLAROCK SUBDIVISION
BOOK 105, PAGES 1408B-1408D

S. LOCUST GROVE RD.

1116 CORNER
P.L.S. 5083
INST. NO. 105337704

SECTION 18

LOT 1
BLOCK 2

LOT 2
BLOCK 2

LOT 3
BLOCK 2

LOT 4
BLOCK 2

LOT 5
BLOCK 2

LOT 6
BLOCK 2

LOT 7
BLOCK 2

LOT 8
BLOCK 2

LOT 9
BLOCK 2

LOT 10
BLOCK 2

LOT 11
BLOCK 2

LOT 12
BLOCK 2

LOT 13
BLOCK 2

LOT 14
BLOCK 2

LOT 15
BLOCK 2

LOT 16
BLOCK 2

LOT 17
BLOCK 2

LOT 18
BLOCK 2

LOT 19
BLOCK 2

LOT 20
BLOCK 2

LOT 21
BLOCK 2

LOT 22
BLOCK 2

LOT 23
BLOCK 2

LOT 24
BLOCK 2

LOT 25
BLOCK 2

LOT 26
BLOCK 2

LOT 27
BLOCK 2

LOT 28
BLOCK 2

LOT 29
BLOCK 2

LOT 30
BLOCK 2

LOT 31
BLOCK 2

LOT 32
BLOCK 2

LOT 33
BLOCK 2

LOT 34
BLOCK 2

LOT 35
BLOCK 2

LOT 36
BLOCK 2

LOT 37
BLOCK 2

LOT 38
BLOCK 2

LOT 39
BLOCK 2

LOT 40
BLOCK 2

LOT 41
BLOCK 2

LOT 42
BLOCK 2

LOT 43
BLOCK 2

LOT 44
BLOCK 2

LOT 45
BLOCK 2

LOT 46
BLOCK 2

LOT 47
BLOCK 2

LOT 48
BLOCK 2

LOT 49
BLOCK 2

LOT 50
BLOCK 2

LOT 51
BLOCK 2

LOT 52
BLOCK 2

LOT 53
BLOCK 2

LOT 54
BLOCK 2

LOT 55
BLOCK 2

LOT 56
BLOCK 2

LOT 57
BLOCK 2

LOT 58
BLOCK 2

LOT 59
BLOCK 2

LOT 60
BLOCK 2

LOT 61
BLOCK 2

LOT 62
BLOCK 2

LOT 63
BLOCK 2

LOT 64
BLOCK 2

LOT 65
BLOCK 2

LOT 66
BLOCK 2

LOT 67
BLOCK 2

LOT 68
BLOCK 2

LOT 69
BLOCK 2

LOT 70
BLOCK 2

LOT 71
BLOCK 2

LOT 72
BLOCK 2

LOT 73
BLOCK 2

LOT 74
BLOCK 2

LOT 75
BLOCK 2

LOT 76
BLOCK 2

LOT 77
BLOCK 2

LOT 78
BLOCK 2

LOT 79
BLOCK 2

LOT 80
BLOCK 2

LOT 81
BLOCK 2

LOT 82
BLOCK 2

LOT 83
BLOCK 2

LOT 84
BLOCK 2

LOT 85
BLOCK 2

LOT 86
BLOCK 2

LOT 87
BLOCK 2

LOT 88
BLOCK 2

LOT 89
BLOCK 2

LOT 90
BLOCK 2

LOT 91
BLOCK 2

LOT 92
BLOCK 2

LOT 93
BLOCK 2

LOT 94
BLOCK 2

LOT 95
BLOCK 2

LOT 96
BLOCK 2

LOT 97
BLOCK 2

LOT 98
BLOCK 2

LOT 99
BLOCK 2

LOT 100
BLOCK 2

LOT 101
BLOCK 2

LOT 102
BLOCK 2

LOT 103
BLOCK 2

LOT 104
BLOCK 2

LOT 105
BLOCK 2

LOT 106
BLOCK 2

LOT 107
BLOCK 2

LOT 108
BLOCK 2

LOT 109
BLOCK 2

LOT 110
BLOCK 2

LOT 111
BLOCK 2

LOT 112
BLOCK 2

LOT 113
BLOCK 2

LOT 114
BLOCK 2

LOT 115
BLOCK 2

LOT 116
BLOCK 2

LOT 117
BLOCK 2

LOT 118
BLOCK 2

LOT 119
BLOCK 2

LOT 120
BLOCK 2

LOT 121
BLOCK 2

LOT 122
BLOCK 2

LOT 123
BLOCK 2

LOT 124
BLOCK 2

LOT 125
BLOCK 2

LOT 126
BLOCK 2

LOT 127
BLOCK 2

LOT 128
BLOCK 2

LOT 129
BLOCK 2

LOT 130
BLOCK 2

LOT 131
BLOCK 2

LOT 132
BLOCK 2

LOT 133
BLOCK 2

LOT 134
BLOCK 2

LOT 135
BLOCK 2

LOT 136
BLOCK 2

LOT 137
BLOCK 2

LOT 138
BLOCK 2

LOT 139
BLOCK 2

LOT 140
BLOCK 2

LOT 141
BLOCK 2

LOT 142
BLOCK 2

LOT 143
BLOCK 2

LOT 144
BLOCK 2

LOT 145
BLOCK 2

LOT 146
BLOCK 2

LOT 147
BLOCK 2

LOT 148
BLOCK 2

LOT 149
BLOCK 2

LOT 150
BLOCK 2

LOT 151
BLOCK 2

LOT 152
BLOCK 2

LOT 153
BLOCK 2

LOT 154
BLOCK 2

LOT 155
BLOCK 2

LOT 156
BLOCK 2

LOT 157
BLOCK 2

LOT 158
BLOCK 2

LOT 159
BLOCK 2

LOT 160
BLOCK 2

LOT 161
BLOCK 2

LOT 162
BLOCK 2

LOT 163
BLOCK 2

LOT 164
BLOCK 2

LOT 165
BLOCK 2

LOT 166
BLOCK 2

LOT 167
BLOCK 2

LOT 168
BLOCK 2

LOT 169
BLOCK 2

LOT 170
BLOCK 2

LOT 171
BLOCK 2

LOT 172
BLOCK 2

LOT 173
BLOCK 2

LOT 174
BLOCK 2

LOT 175
BLOCK 2

LOT 176
BLOCK 2

LOT 177
BLOCK 2

LOT 178
BLOCK 2

LOT 179
BLOCK 2

LOT 180
BLOCK 2

LOT 181
BLOCK 2

LOT 182
BLOCK 2

LOT 183
BLOCK 2

LOT 184
BLOCK 2

LOT 185
BLOCK 2

LOT 186
BLOCK 2

LOT 187
BLOCK 2

LOT 188
BLOCK 2

LOT 189
BLOCK 2

LOT 190
BLOCK 2

LOT 191
BLOCK 2

LOT 192
BLOCK 2

LOT 193
BLOCK 2

LOT 194
BLOCK 2

LOT 195
BLOCK 2

LOT 196
BLOCK 2

LOT 197
BLOCK 2

LOT 198
BLOCK 2

LOT 199
BLOCK 2

LOT 200
BLOCK 2

LOT 201
BLOCK 2

LOT 202
BLOCK 2

LOT 203
BLOCK 2

LOT 204
BLOCK 2

LOT 205
BLOCK 2

LOT 206
BLOCK 2

LOT 207
BLOCK 2

LOT 208
BLOCK 2

LOT 209
BLOCK 2

LOT 210
BLOCK 2

LOT 211
BLOCK 2

LOT 212
BLOCK 2

LOT 213
BLOCK 2

LOT 214
BLOCK 2

LOT 215
BLOCK 2

LOT 216
BLOCK 2

LOT 217
BLOCK 2

LOT 218
BLOCK 2

LOT 219
BLOCK 2

LOT 220
BLOCK 2

LOT 221
BLOCK 2

LOT 222
BLOCK 2

LOT 223
BLOCK 2

LOT 224
BLOCK 2

LOT 225
BLOCK 2

LOT 226
BLOCK 2

LOT 227
BLOCK 2

LOT 228
BLOCK 2

LOT 229
BLOCK 2

LOT 230
BLOCK 2

LOT 231
BLOCK 2

LOT 232
BLOCK 2

LOT 233
BLOCK 2

LOT 234
BLOCK 2

LOT 235
BLOCK 2

LOT 236
BLOCK 2

LOT 237
BLOCK 2

LOT 238
BLOCK 2

LOT 239
BLOCK 2

LOT 240
BLOCK 2

LOT 241
BLOCK 2

LOT 242
BLOCK 2

LOT 243
BLOCK 2

LOT 244
BLOCK 2

LOT 245
BLOCK 2


LOT 246
BLOCK 2

LOT 247
BLOCK 2

LOT 248
BLOCK 2


LOT 249
BLOCK 2

LOT 250
BLOCK



[illegible]

E. Approved CZC Landscape Plan (date: 4/12/22)



VII. CITY/AGENCY COMMENTS & CONDITIONS

A. Planning Division

Site Specific Conditions:

1. The short plat prepared by Kerry Albright of Forsgreen Associates Inc included in Section VI.B shall be revised as follows:
 - a) Add a note to the plat that specifies the shared access between Lot 2 Block 1 of the Katsura Subdivision and Lots 7 and 8 Block 2 of the Medimont Subdivision No 2. or graphically depict a cross-access/ingress-egress easement in accord with the provisions of UDC 11-3A-3A2.
 - b) Note 5: add instrument number.
2. Applicant shall comply with all previous conditions of approval associated with this development (H-2021-0042, DA Instr. 2022-001274).
3. If the City Engineer's signature has not been obtained within two (2) years of the City Council's approval of the short plat, the short plat shall become null and void unless a time extension is obtained, per UDC 11-6B-7.
4. Development of any lot shall require submission of Certificate of Zoning Compliance and Design Review per UDC-11-5B-1 and shall meet all applicable requirements of City of Meridian code.
5. Staff's failure to cite specific ordinance provisions or conditions from the previous approvals as noted in condition 3. above, does not relieve the Applicant of responsibility for compliance.

B. Public Works

Site Specific Conditions:

1. A streetlight plan has not been submitted or approved. Streetlights are required on the S. Ten Mile Road frontage per the City of Meridian standards. The streetlights will need to be installed and operational, with approved record drawings submitted, before any form of occupancy will be granted.
2. If the existing sewer main into the site will not be used, it must be abandoned at the manhole.
3. If the existing water main into the site will not be used, it must be abandoned at the main.
4. Water should be serviced from Locust Grove.

General Conditions:

1. Sanitary sewer service to this development is available via extension of existing mains adjacent to the development. The applicant shall install mains to and through this subdivision; applicant shall coordinate main size and routing with the Public Works Department, and execute standard forms of easements for any mains that are required to provide service. Minimum cover over sewer mains is three feet, if cover from top of pipe to sub-grade is less than three feet than alternate materials shall be used in conformance of City of Meridian Public Works Departments Standard Specifications.
2. Water service to this site is available via extension of existing mains adjacent to the development. The applicant shall be responsible to install water mains to and through this development, coordinate main size and routing with Public Works.

3. All improvements related to public life, safety and health shall be completed prior to occupancy of the structures. Where approved by the City Engineer, an owner may post a performance surety for such improvements in order to obtain City Engineer signature on the final plat as set forth in UDC 11-5C-3B.
4. Upon installation of the landscaping and prior to inspection by Planning Department staff, the applicant shall provide a written certificate of completion as set forth in UDC 11-3B-14A.
5. A letter of credit or cash surety in the amount of 110% will be required for all incomplete fencing, landscaping, amenities, pressurized irrigation, prior to signature on the final plat.
6. The City of Meridian requires that the owner post with the City a performance surety in the amount of 125% of the total construction cost for all incomplete sewer, water infrastructure prior to final plat signature. This surety will be verified by a line item cost estimate provided by the owner to the City. The applicant shall be required to enter into a Development Surety Agreement with the City of Meridian. The surety can be posted in the form of an irrevocable letter of credit, cash deposit or bond. Applicant must file an application for surety, which can be found on the Community Development Department website. Please contact Land Development Service for more information at 887-2211.
7. The City of Meridian requires that the owner post to the City a warranty surety in the amount of 20% of the total construction cost for all completed sewer, and water infrastructure for a duration of two years. This surety amount will be verified by a line item final cost invoicing provided by the owner to the City. The surety can be posted in the form of an irrevocable letter of credit, cash deposit or bond. Applicant must file an application for surety, which can be found on the Community Development Department website. Please contact Land Development Service for more information at 887-2211.
8. In the event that an applicant and/or owner cannot complete non-life, non-safety and non-health improvements, prior to City Engineer signature on the final plat and/or prior to occupancy, a surety agreement may be approved as set forth in UDC 11-5C-3C.
9. Applicant shall be required to pay Public Works development plan review, and construction inspection fees, as determined during the plan review process, prior to the issuance of a plan approval letter.
10. It shall be the responsibility of the applicant to ensure that all development features comply with the Americans with Disabilities Act and the Fair Housing Act.
11. Applicant shall be responsible for application and compliance with any Section 404 Permitting that may be required by the Army Corps of Engineers.
12. Developer shall coordinate mailbox locations with the Meridian Post Office.
13. All grading of the site shall be performed in conformance with MCC 11-1-4B.
14. Compaction test results shall be submitted to the Meridian Building Department for all building pads receiving engineered backfill, where footing would sit atop fill material.
15. The engineer shall be required to certify that the street centerline elevations are set a minimum of 3-feet above the highest established peak groundwater elevation. This is to ensure that the bottom elevation of the crawl spaces of homes is at least 1-foot above.
16. The applicants design engineer shall be responsible for inspection of all irrigation and/or drainage facility within this project that do not fall under the jurisdiction of an irrigation district or ACHD. The design engineer shall provide certification that the facilities have been installed in accordance with the approved design plans. This certification will be required before a

certificate of occupancy is issued for any structures within the project.

17. At the completion of the project, the applicant shall be responsible to submit record drawings per the City of Meridian AutoCAD standards. These record drawings must be received and approved prior to the issuance of a certification of occupancy for any structures within the project.
18. Street light plan requirements are listed in section 6-7 of the Improvement Standards for Street Lighting (http://www.meridiancity.org/public_works.aspx?id=272). All street lights shall be installed at developer's expense. Final design shall be submitted as part of the development plan set for approval, which must include the location of any existing street lights. The contractor's work and materials shall conform to the ISPWC and the City of Meridian Supplemental Specifications to the ISPWC. Contact the City of Meridian Transportation and Utility Coordinator at 898-5500 for information on the locations of existing street lighting.
19. The applicant shall provide easement(s) for all public water/sewer mains outside of public right of way (include all water services and hydrants). The easement widths shall be 20-feet wide for a single utility, or 30-feet wide for two. The easements shall not be dedicated via the plat, but rather dedicated outside the plat process using the City of Meridian's standard forms. The easement shall be graphically depicted on the plat for reference purposes. Submit an executed easement (on the form available from Public Works), a legal description prepared by an Idaho Licensed Professional Land Surveyor, which must include the area of the easement (marked EXHIBIT A) and an 8 1/2" x 11" map with bearings and distances (marked EXHIBIT B) for review. Both exhibits must be sealed, signed and dated by a Professional Land Surveyor. DO NOT RECORD. Add a note to the plat referencing this document. All easements must be submitted, reviewed, and approved prior to signature of the final plat by the City Engineer.
20. Applicant shall be responsible for application and compliance with and NPDES permitting that may be required by the Environmental Protection Agency.
21. Any wells that will not continue to be used must be properly abandoned according to Idaho Well Construction Standards Rules administered by the Idaho Department of Water Resources. The Developer's Engineer shall provide a statement addressing whether there are any existing wells in the development, and if so, how they will continue to be used, or provide record of their abandonment.
22. Any existing septic systems within this project shall be removed from service per City Ordinance Section 9-1-4 and 9 4 8. Contact the Central District Health Department for abandonment procedures and inspections.
23. The City of Meridian requires that pressurized irrigation systems be supplied by a year-round source of water (MCC 9-1-28.C.1). The applicant should be required to use any existing surface or well water for the primary source. If a surface or well source is not available, a single-point connection to the culinary water system shall be required. If a single-point connection is utilized, the developer will be responsible for the payment of assessments for the common areas prior to development plan approval.
24. All irrigation ditches, canals, laterals, or drains, exclusive of natural waterways, intersecting, crossing or laying adjacent and contiguous to the area being subdivided shall be addressed per UDC 11-3A-6. In performing such work, the applicant shall comply with Idaho Code 42-1207 and any other applicable law or regulation.

VIII. REQUIRED FINDINGS FROM THE UNIFIED DEVELOPMENT CODE

In consideration of a short plat, the decision-making body shall make the following findings:

A. The plat is in conformance with the Comprehensive Plan and is consistent with the Unified Development Code;

The Comprehensive Plan designates the future land use of this property as Industrial. The current zoning district of the site is I-L. The proposed short plat complies with the Comprehensive Plan and is developed in accord with UDC standards.

B. Public services are available or can be made available and are adequate to accommodate the proposed development;

Staff finds that public services are adequate to serve the site.

C. The plat is in conformance with scheduled public improvements in accord with the City's capital improvements program;

Staff finds that the development will not require the expenditure of capital improvement funds. All required utilities are being provided with the development of the property at the developer's expense.

D. There is public financial capability of supporting services for the proposed development;

Staff finds that the development will not require major expenditures for providing supporting services. The developer and/or future lot owner(s) will finance improvements for sewer, water, utilities and pressurized irrigation to serve the project.

E. The development will not be detrimental to the public health, safety or general welfare; and

Staff finds the proposed short plat will not be detrimental to the public health, safety or general welfare.

F. The development preserves significant natural, scenic or historic features.

Staff is not aware of any significant natural, scenic or historic features associated with the development of this site.