

# Council Meeting August 27, 2024

## NEW BUSINESS LICENSES

	<b>BUSINESS NAME</b>	<b>FIRE INSPECTION</b>	<b>INSURANCE</b>
1	Rival Downhole Tools	Yes	NA
2	The Oregon Trail Bar	Yes	NA
3	Wyoming Bearing & Supply, LLC.	Yes	NA
	Wyoming Tree Service, LLC.	Yes	NA

## RENEWAL BUSINESS LICENSES

	<b>BUSINESS NAME</b>	<b>FIRE INSPECTION</b>	<b>INSURANCE</b>
1	Belzona Rocky Mountain, Inc.	Yes	NA
2	Bonander Properties	Yes	NA
3	Casper Discount Storage	Yes	NA
4	EJO Rink, LLC/ Wagon Wheel	Yes	NA
5	JTeam Custom Engines	Yes	NA
6	Millview Laundromat	Yes	NA
7	National Oilwell Varco, LP	Yes	NA
8	USA Trucking, LLC.	Yes	NA

Blank rows for additional business license entries.



**CITY OF MILLS**  
EST. 1921

**APPLICATION FOR  
Business License**

**A Business License is required for ANY business to operate within the City of Mills, a Business License Application must be completed. Incomplete applications shall be returned.**

License #: 9901

Date: 6/12/24

- New Business
- Change of Ownership
- Change of Location
- Renewal
- Expired

GENERAL INFORMATION

Name of Business: Rival Downhole Tools

Physical Address: 1088 N Robertson rd                          Mills                          WY                          82604  
Street    City    State    Zip

Mailing Address: Same    City    State    Zip  
Street    City    State    Zip

Business Phone Number: 307-265-7867                          WY Tax ID Number: 30-0144542

Email Address: MStoneking@RivalDT.com                          Website: \_\_\_\_\_


Description of Business: Oilfield Service (mud motors)

APPLICANT INFORMATION

Applicant Name: Matthew Stoneking                          Phone Number: 307-258-2022

Mailing Address: See above    City    State    Zip  
Street    City    State    Zip

**I certify that the above information is correct and true to the best of my knowledge.**

Applicants Signature:                           6/12/24

**There will be a fire inspection fee to be paid at the time the License is issued.**

Businesses that qualify for a Self-Assessment Fire Inspection	\$45.00
Businesses between 1-5,000 Sq. Feet	\$75.00
Businesses between 5,001-10,000 Sq. Feet	\$125.00
Businesses greater than 10,000 Sq. Feet	\$250.00
Businesses with Fire Alarm, Sprinkler System or Hood Suppression	+ \$50.00

**PAID**  
JUN 17 2024

Return completed form to:  
Mills City Hall  
720 4<sup>th</sup> Street  
307-234-6679

**RECEIVED**  
JUN 17 2024

OFFICE USE ONLY

This license was / was not  
Granted at a meeting of the Mills  
City Council on the \_\_\_\_\_

Attest \_\_\_\_\_

## Raelyn Stoneking

---

**From:** no-reply@livsafe.com  
**Sent:** Friday, August 16, 2024 9:45 AM  
**To:** mstoneking@rivaldt.com; Raelyn Stoneking; info  
**Cc:** info@livsafe.com  
**Subject:** Inspection Report has been submitted

EXTERNAL EMAIL: This email originated from outside of the City of Mills. Do not click any links or open any attachments unless you trust the sender and know the content is safe.



**Mills Fire Department (WY)**

c/o LIVSafe  
445 E Chubbuck Rd, Ste A  
Chubbuck, ID 83202

300 Lakeview Dr  
Mills, Wyoming 82604

### **FIRE INSPECTION REPORT COMPLIANCE**

August 16, 2024

**Rival Downhole Tools  
1088 North Robertson Road  
Casper, Wyoming 82604**

Mills Fire Department (WY) has completed a Fire & Life Safety Inspection on this Premise. During the Inspection, **NO FIRE CODE VIOLATIONS** were observed.

We appreciate your efforts in keeping the business safe for employees and patrons.

Sincerely,

Wil Gay  
Mills Fire Department (WY)



**APPLICATION FOR  
Business License**

A Business License is required for ANY business to operate within the City of Mills, a Business License Application must be completed. Incomplete applications shall be returned.

License #: 9904

Date: 6-21-24

New Business     Change of Ownership     Change of Location     Renewal     Expired

GENERAL INFORMATION

Name of Business: Klaus W. Conrad Jr  
DBA The Oregon Trail Bar

Physical Address: 4618 W. Yellowstone Hwy Mills WY 82604  
Street City State Zip

Mailing Address: 19 S. 4th Ave Mills WY 82604  
Street City State Zip

Business Phone Number: 307-253-0479 WY Tax ID Number: 88-2084067

Email Address: theoregontrailbar@outlook.com Website: \_\_\_\_\_

Description of Business: Bar & Package liquor

APPLICANT INFORMATION

Applicant Name: Klaus W. Conrad Jr. Phone Number: 307-253-0479

Mailing Address: 19 S. 4th Ave Mills WY 82604  
Street City State Zip

I certify that the above information is correct and true to the best of my knowledge.

Applicants Signature: [Signature]

There will be a fire inspection fee to be paid at the time the License is issued.

Businesses that qualify for a Self-Assessment Fire Inspection	\$45.00
Businesses between 1-5,000 Sq. Feet	<del>\$75.00</del>
Businesses between 5,001-10,000 Sq. Feet	\$125.00
Businesses greater than 10,000 Sq. Feet	\$250.00
Businesses with Fire Alarm, Sprinkler System or Hood Suppression	+ \$50.00

Return completed form to:  
Mills City Hall  
720 4th Street  
307-234-6679

<p><b>OFFICE USE ONLY</b> This license was / was not Granted at a meeting of the Mills City Council on the _____ Attest _____</p>
---

## Raelyn Stoneking

---

**From:** no-reply@livsafe.com  
**Sent:** Tuesday, August 20, 2024 4:42 PM  
**To:** theoregontrailbar@outlook.com; Raelyn Stoneking; info  
**Cc:** info@livsafe.com  
**Subject:** Inspection Report has been submitted

EXTERNAL EMAIL: This email originated from outside of the City of Mills. Do not click any links or open any attachments unless you trust the sender and know the content is safe.



### Mills Fire Department (WY)

c/o LIVSafe  
445 E Chubbuck Rd, Ste A  
Chubbuck, ID 83202

300 Lakeview Dr  
Mills, Wyoming 82604

## FIRE INSPECTION REPORT COMPLIANCE

August 20, 2024

**The Oregon Trail bar**  
**4618 West Yellowstone Highway**  
**Casper, Wyoming 82604**

Mills Fire Department (WY) has completed a Fire & Life Safety Inspection on this Premise. During the Inspection, **NO FIRE CODE VIOLATIONS** were observed.

We appreciate your efforts in keeping the business safe for employees and patrons.

Sincerely,

Wil Gay  
Mills Fire Department (WY)

RECEIVED

AUG 02 2024



CITY OF MILLS  
EST. 1991

**APPLICATION FOR  
Business License**

*A Business License is required for ANY business to operate within the City of Mills, a Business License Application must be completed. Incomplete applications shall be returned.*

License #: 9921

Date: 07/30/2024

New Business     Change of Ownership     Change of Location     Renewal     Expired

GENERAL INFORMATION

Name of Business: Wyoming Bearing & Supply, LLC

Physical Address: 3416 Mid Way Road Mills, WY 82601  
Street City State Zip

Mailing Address: 206 S. College Dr., Cheyenne, WY 82007  
Street City State Zip

Business Phone Number: 307-462-4300 WY Tax ID Number: 25003352 EIN 27-0757880

Email Address: stephanie@wyobs.com Website: www.wyobs.com

Description of Business: Industrial Parts & Supply Sales based in Cheyenne, WY with locations in  
Nebraska & Colorado

APPLICANT INFORMATION

Applicant Name: Wyoming Bearing & Supply, LLC Phone Number: 307-634-9000

Mailing Address: 206 S. College Dr., Cheyenne, WY 82007  
Street City State Zip

I certify that the above information is correct and true to the best of my knowledge.

Applicants Signature: Stephanie M. Standen

There will be a fire inspection fee to be paid at the time the License is issued.

Businesses that qualify for a Self-Assessment Fire Inspection	\$45.00
Businesses between 1-5,000 Sq. Feet	\$75.00
Businesses between 5,001-10,000 Sq. Feet	\$125.00
Businesses greater than 10,000 Sq. Feet	\$250.00
Businesses with Fire Alarm, Sprinkler System or Hood Suppression	+ \$50.00

PAID

AUG 02 2024

Return completed form to:  
Mills City Hall  
704 4<sup>th</sup> Street  
PO Box 789  
Mills, WY 82644  
307-234-6679

<p><b>OFFICE USE ONLY</b> This license was / was not Granted at a meeting of the Mills City Council on the _____ Attest _____</p>
---

## Raelyn Stoneking

---

**From:** no-reply@livsafe.com  
**Sent:** Thursday, August 22, 2024 10:28 AM  
**To:** Stephanie@wyobs.com; Mason@wyobs.com; info; Raelyn Stoneking  
**Cc:** info@livsafe.com  
**Subject:** Inspection Report has been submitted

EXTERNAL EMAIL: This email originated from outside of the City of Mills. Do not click any links or open any attachments unless you trust the sender and know the content is safe.



**Mills Fire Department (WY)**

c/o LIVSafe  
445 E Chubbuck Rd, Ste A  
Chubbuck, ID 83202

300 Lakeview Dr  
Mills, Wyoming 82604

### **FIRE INSPECTION REPORT COMPLIANCE**

August 22, 2024

**Wyoming Bearing and Supply LLC**  
**3416 Mid Way Road**  
**Casper, Wyoming 82601**

Mills Fire Department (WY) has completed a Fire & Life Safety Inspection on this Premise. During the Inspection, **NO FIRE CODE VIOLATIONS** were observed.

We appreciate your efforts in keeping the business safe for employees and patrons.

Sincerely,

Wil Gay  
Mills Fire Department (WY)

RECEIVED

AUG 05 2024

APPLICATION FOR Business License



A Business License is required for ANY business to operate within the City of Mills, a Business License Application must be completed. Incomplete applications shall be returned.

License #: 9903

Date: 7-1-24

- Checked: New Business; Unchecked: Change of Ownership, Change of Location, Renewal, Expired

GENERAL INFORMATION

Name of Business: Wyoming Tree Service, LLC

Physical Address: 5585 Poison Spider Street, Mills, WY 82644

Mailing Address: PO Box 3034, Mills, WY 82644

Business Phone Number: 307-333-5227; WY Tax ID Number: 99-3775486

Email Address: WyomingTreeServiceLLC@gmail.com; Website:

Description of Business: Tree Service, (tree removal, tree pruning)

APPLICANT INFORMATION

Applicant Name: Jim Sullivan; Phone Number: 307-262-1814

Mailing Address: PO Box 3034; 5585 Poison Spider Rd, Mills, WY 82644

I certify that the above information is correct and true to the best of my knowledge.

Applicants Signature: [Signature]

There will be a fire inspection fee to be paid at the time the License is issued.

Table with 2 columns: Business type and Fee amount. Includes categories like Self-Assessment Fire Inspection, 1-5,000 Sq. Feet, etc.

Co-located with Sullivan Trucking, Inc. The premises already has a fire inspection.

Return completed form to: Mills City Hall, 720 4th Street, 307-234-6679

OFFICE USE ONLY. This license was / was not Granted at a meeting of the Mills City Council on the ... Attest





# Mills Fire Department

\$45<sup>00</sup>

Occupancy: **Sullivan Trucking**  
Occupancy ID: **107**  
Address: **5585 Poison Spider RD Mills WY 82604**

Inspection Type: **Yearly inspection**  
Inspection Date: **1/29/2024** By: **2023, SAFI (44)**  
Time In: **15:30** Time Out: **15:50**  
Authorized Date: **01/31/2024** By: **Gay, Wil (29)**

Form: SAFI Annual Inspection

## Inspection Description:

Self-Assessment Fire Inspection

## Inspection Topics:

### Building Access and Outdoor Premises

The building address can be clearly seen from the street (4" high numbers, minimum Responders and passerby's need to be able to read an address from the street, preferably high enough to be seen over the tops of parked vehicles.  
**Status:** PASS  
**Notes:**

The exterior access is not blocked or inaccessible  
Firefighters and equipment need to be able to get to the building in a safe and efficient manner  
**Status:** PASS  
**Notes:**

The fire hydrants are easy to find and not blocked off  
Minimum of three feet of clearance around hydrants. Snow must be kept clear by property owner as well.  
**Status:** PASS  
**Notes:**

Dumpsters must be kept a minimum of five feet from the building and overhangs  
Dumpster fires can lead to building fires if they are stored too close to a building.  
**Status:** PASS  
**Notes:**

### Check Exits and Escape Routes

The exit doors are easy to identify, access and they work  
Means of egress out of a building is mandatory and critical to life safety.  
**Status:** PASS  
**Notes:**

The exit doors all open from the inside without keys or specialist knowledge  
Doors must remain unlocked during business hours.  
**Status:** PASS  
**Notes:**

There are no obstructions in exits, aisles corridors or stairways  
A clear means of egress is critical in an emergency situation. Do not store anything in the pathways leading to an emergency exit.  
**Status:** PASS  
**Notes:**

There is no storage of any kind beneath the exit stairs  
Stairways leading to an exit must remain free of combustible material.  
**Status:** PASS  
**Notes:**

The exit signs have a minimum of 6" high letters with a contrasting background and reflect/glow in the dark or are lighted.  
Lighted exit signs must work.  
Exit signs must be visible in the dark to aid in egress from the building.  
**Status:** PASS  
**Notes:**

### Assess the Electrical System

The electrical receptacles all have covers. Plugs, switches, junction boxes.  
The terminals must be protected from accidental contact.  
**Status:** PASS  
**Notes:**

The circuits are all properly labelled on all panels  
Knowing which breaker leads to what area will protect occupants and firefighters in the event of an electrical emergency.  
**Status:** PASS  
**Notes:**

There is 30" wide, 36" deep and 78" high access/clearance in front of each electrical panel.  
In the event of an emergency crews need immediate access to the electrical panel  
**Status:** PASS  
**Notes:**

Extension cords are not used to power permanent fixtures  
Extension cords are for temporary use only  
**Status:** PASS  
**Notes:**

The extension cords are all grounded  
Carrying a ground conductor on portable equipment, if so equipped, offers protection for the end user.  
**Status:** PASS  
**Notes:**

All power strips in use have a built-in circuit breaker and are rated for such use.  
Power strips can be easily overloaded  
**Status:** PASS  
**Notes:**

All wiring is properly maintained in good condition and protected from damage.  
Wiring should be free from defects.  
**Status:** PASS  
**Notes:**

## Heat Producing Devices and Appliances

Only UL listed heaters should be used, and not permanently

UL verifies that equipment is rated for its intended use

**Status:** PASS

**Notes:**

Electrical portable heaters should have 36" of space on either side

Air flow to the blower fan is critical to prevent overheating of the appliance

**Status:** PASS

**Notes:**

Gas-fired heat producing devices require a minimum of 36" clearance, or manufacturer recommended distance, whichever is greater, from combustibles

Too close to combustibles, things will catch on fire.

**Status:** PASS

**Notes:**

Gas-fired heat producing devices should have vents

Vents to the outside can help reduce/eliminate the build-up of carbon monoxide.

**Status:** PASS

**Notes:**

Light fixtures must be clear of any combustible materials

Combustibles too close to a light fixture can heat up and ultimately catch on fire.

**Status:** PASS

**Notes:**

## Inspect All Fire Extinguishers

There are fire extinguishers within 75' of all areas of the building

One should not have to travel more than 75' to reach a fire extinguisher

**Status:** PASS

**Notes:**

The extinguishers are visible and readily accessible

Where not readily seen, a fire extinguisher sign/sticker shall be placed high above the sticker to indicate its location.

**Status:** PASS

**Notes:**

The extinguishers meet the necessary standards and specialized ones are present also, if applicable (i.e., K for kitchen, CO2 for electronics)

Most facilities will have dry chem extinguishers, but specialized businesses might need specialized extinguishers to protect their assets.

**Status:** PASS

**Notes:**

The extinguishers are stored off the floor but no higher than 5' off the floor, unless otherwise approved

Extinguishers are to be mounted on a hanger or in a cabinet, that will indicate when an extinguisher is missing.

**Status:** PASS

**Notes:**

All extinguishers have been inspected in the last 12-months.  
Annual inspections are required on fire extinguishers.

**Status:** PASS  
**Notes:**

### Assess The Maintenance of Building Areas

Trash and waste should be taken out daily  
A collection of trash and waste inside a building have led to unwanted fires or tripping hazards.

**Status:** PASS  
**Notes:**

Oily rags or similar materials require disposal in approved metal containers  
Spontaneous combustion of mishandled oily rags can lead to fire

**Status:** PASS  
**Notes:**

Combustible materials need to be stored securely and orderly  
The more orderly the storage area, the reduced chance of hidden/unwanted fire.

**Status:** PASS  
**Notes:**

Exit paths do not have combustibles stored in their path  
A clean exit path is a safe exit path.

**Status:** PASS  
**Notes:**

Storage height must be a minimum of 2 feet below ceiling height  
This aids the fire department when they must perform vertical ventilation to remove smoke from a building, to not only cut the hole without hitting product, but leaves room for the smoke to travel up and out.

**Status:** PASS  
**Notes:**

Flammable liquids, greater than 5-gallons, are stored in an approved fire rated cabinet  
Protecting flammables will help prevent the unnecessary spread of fire, if one gets started.

**Status:** PASS  
**Notes:**

Post and enforce "no smoking" signs in combustible or flammable areas (white lettering 3" tall on red backing).  
No smoking is necessary in areas where combustible or flammables are present.

**Status:** PASS  
**Notes:**

Flammable liquids are all stored in approved containers  
There are specialized containers for flammable liquid storage.

**Status:** PASS  
**Notes:**

Compressed gas cylinders are secured, standing up right, with cap in place  
Cylinders must be protected from falling

**Status:** PASS  
**Notes:**

**Additional Time Spent on Inspection:**

Category	Start Date / Time	End Date / Time
Notes: No Additional time recorded		

**Total Additional Time: 0 minutes**  
**Inspection Time: 20 minutes**  
**Total Time: 20 minutes**

**Summary:**

**Overall Result: Pass**  
Passed all requirements

**Inspector Notes: SAFI eligible**

**Inspector:**

Name: 2023, SAFI  
Rank:  
Email(s): None on file



*A Business License is required for ANY business to operate within the City of Mills, a Business License Application must be completed. Incomplete applications shall be returned.*

License #: 1054

Date: 8-20-24

New Business     Change of Ownership     Change of Location     Renewal     Expired

GENERAL INFORMATION

Name of Business: Belzona Rocky Mountain Inc.

Physical Address: 4447 Chalmers Street Mills WY 82604  
Street City State Zip

Mailing Address: PO Box 3031 Mills WY 82644  
Street City State Zip

Business Phone Number: 307-266-3644 WY Tax ID Number: 1007327

Email Address: office@belzonarockymountain.com Website: belzonarockymountain.com

Description of Business: authorized distributor of Belzona  
Industrial coatings

APPLICANT INFORMATION

Applicant Name: Julie Grayson Phone Number: 307-266-3644

Mailing Address: 4447 Chalmers St. Mills WY 82604  
Street City State Zip

**I certify that the above information is correct and true to the best of my knowledge.**

Applicants Signature: Julie Grayson

**There will be a fire inspection fee to be paid at the time the License is issued.**

Businesses that qualify for a Self-Assessment Fire Inspection	\$45.00
Businesses between 1-5,000 Sq. Feet	\$75.00
Businesses between 5,001-10,000 Sq. Feet	\$125.00
Businesses greater than 10,000 Sq. Feet	\$250.00
Businesses with Fire Alarm, Sprinkler System or Hood Suppression	+ \$50.00

Return completed form to:  
Mills City Hall  
704 4<sup>th</sup> Street  
Po Box 789  
Mills, WY 82644  
307-234-6679

<p><b>OFFICE USE ONLY</b> This license was / was not Granted at a meeting of the Mills City Council on the _____ Attest _____</p>
---

**Raelyn Stoneking**

---

**From:** no-reply@livsafe.com  
**Sent:** Thursday, August 22, 2024 6:42 PM  
**To:** office@belzonarockymountain.com; Raelyn Stoneking; info  
**Cc:** info@livsafe.com  
**Subject:** Inspection Report has been submitted

EXTERNAL EMAIL: This email originated from outside of the City of Mills. Do not click any links or open any attachments unless you trust the sender and know the content is safe.



**Mills Fire Department (WY)**

c/o LIVSafe  
445 E Chubbuck Rd, Ste A  
Chubbuck, ID 83202

300 Lakeview Dr  
Mills, Wyoming 82604

## **FIRE INSPECTION REPORT COMPLIANCE**

August 23, 2024

**Belzona Rocky Mountain  
4447 Chalmers St  
Mills, Wyoming 82604**

Mills Fire Department (WY) has completed a Fire & Life Safety Inspection on this Premise. During the Inspection, **NO FIRE CODE VIOLATIONS** were observed.

We appreciate your efforts in keeping the business safe for employees and patrons.

Sincerely,

Wil Gay  
Mills Fire Department (WY)

RECEIVED

AUG 22 2024



CITY OF MILLS  
EST. 1921

**APPLICATION FOR  
Business License**

*A Business License is required for ANY business to operate within the City of Mills, a Business License Application must be completed. Incomplete applications shall be returned.*

License #: 9448

Date: 8/22/2024

New Business     Change of Ownership     Change of Location     Renewal     Expired

GENERAL INFORMATION

Name of Business: Bonander Properties

Physical Address: PO Box 1840 (935 Pendell Blvd - 2nd Floor) Mills, WY 82644  
Street City State Zip

Mailing Address: PO Box 1840, Mills, WY 82644  
Street City State Zip

Business Phone Number: 307-234-2058      WY Tax ID Number: 27-4079341

Email Address: accounting@inter-mountain.com      Website: \_\_\_\_\_

Description of Business: Property management

APPLICANT INFORMATION

Applicant Name: Traci Young      Phone Number: 307-234-2058

Mailing Address: PO Box 1840, Mills, WY 82644  
Street City State Zip

**I certify that the above information is correct and true to the best of my knowledge.**

Applicants Signature: *Traci Young*

**There will be a fire inspection fee to be paid at the time the License is issued.**

Businesses that qualify for a Self-Assessment Fire Inspection	\$45.00
Businesses between 1-5,000 Sq. Feet	\$75.00
Businesses between 5,001-10,000 Sq. Feet	\$125.00
Businesses greater than 10,000 Sq. Feet	\$250.00
Businesses with Fire Alarm, Sprinkler System or Hood Suppression	+ \$50.00

Return completed form to:  
Mills City Hall  
704 4<sup>th</sup> Street  
Po Box 789  
Mills, WY 82644  
307-234-6679

<p><b>OFFICE USE ONLY</b> This license was / was not Granted at a meeting of the Mills City Council on the _____ Attest _____</p>
---





# Mills Fire Department

Occupancy: **Inter-Mountain Pipe & Threading Company**  
Occupancy ID: **153**  
Address: **935 Pendell BLVD Mills WY 82604**

Form: 2022 Annual  
Inspection

Inspection Type: **Yearly inspection**  
Inspection Date: **4/18/2024** By: **Dierenfeldt, John B (10)**  
Time In: **13:30** Time Out: **13:50**  
Authorized Date: **04/18/2024** By: **Dierenfeldt, John B (10)**

## Inspection Description:

2022 Annual Inspection

## Inspection Topics:

### Exits

Repair or maintain exit doors and hardware to operate properly.  
Well maintained exit doors and panic hardware provide safe and easy egress from a building.

**Status: PASS**  
**Notes:**

Remove obstructions from exits, aisles, corridors, and stairways.  
Clear exit access is essential to prevent panic or accidental falling of occupants during evacuation.

**Status: PASS**  
**Notes:**

Remove storage from beneath exit stairs.  
Items stored beneath stairs present a fire risk that can endanger persons using that escape route.

**Status: PASS**  
**Notes:**

Unlock all exit doors during business hours.  
Locked exit doors make it impossible for occupants to escape safely and quickly.

**Status: PASS**  
**Notes:**

Provide exit signs with letters at least 6 inches high on a contrasting background.  
Clearly identified exits enable persons to quickly and safely leave the building in an emergency.

**Status: PASS**  
**Notes:**

Remove unapproved locks or latches from exit doors.  
Exit doors must be free to open without delay in the event of an emergency.

**Status: PASS**  
**Notes:**

### Exit Lighting

Repair lighted exit signs or emergency lighting.  
Exit signs and emergency illumination are essential during evacuations. The exit sign will indicate to occupants the correct door to reach safely.

**Status: PASS**  
**Notes:**

Provide lighting for exits, aisles, corridors, and stairways. Table 1006.3.3(2) and occupancy classification  
Well lighted exit ways prevent panic, and provide safer egress for occupants.

**Status:** PASS  
**Notes:**

### Fire Extinguishers

Mount extinguishers where readily available, not more than 5 feet above floor.  
Extinguishers must be easily within reach of all occupants, but not where they will be subject to damage.

**Status:** PASS  
**Notes:**

Post signs indicating location where extinguishers are not readily visible.  
Where extinguishers are not clearly visible, signs help occupants find the equipment in a hurry.

**Status:** PASS  
**Notes:**

Portable fire extinguishers are due for annual maintenance on:  
Annual maintenance will provide for properly charge and serviced extinguishing devices, and assure proper operation if needed to fight a small fire.

**Status:** PASS  
**Notes:**

Provide \_\_\_ extinguisher(s), minimum size of \_\_\_\_\_ at \_\_\_\_\_  
location(s).

Extinguishers provided need to be appropriate to the type of hazard.

**Status:** PASS  
**Notes:**

### Fire Protection Access and Equipment

KNOX Box verification  
Use KNOX key to open box and verify there is a key and it works

**Status:** PASS  
**Notes:**

Install approved protective covers on fire department hose connection.  
Protective covers must be installed on the supply connection to prevent accumulations of debris that might inhibit the system feets effectiveness.

**Status:** PASS  
**Notes:**

Provide and maintain smoke detectors in proper operating condition.  
The proper installation and maintenance of smoke detectors is of the utmost importance. In the event of a fire, they will notify occupants, and, in some cases, may automatically notify the Fire Department.

**Status:** PASS  
**Notes:**

The X system(s) is/are due for confidence testing and certification. Please see the attached report.  
Life safety and fire protection equipment must be properly inspected and tested from time to time to assure its effective operation.

**Status:** PASS  
**Notes:**

Maintain access to and operation of standpipes, fire hose, sprinkler valves, fire hydrants, fire extinguishers, and other fire protection equipment

Fire protection equipment must have clear access and be operational at all times to be effective in an emergency.

**Status:** PASS

**Notes:**

Provided minimum 4 inches high address numbers so they are visible from the street.

Address numbers are critical to help emergency personnel find people who may need some sort of aid. The numbers must contrast with their background for greatest visibility.

**Status:** PASS

**Notes:**

Remove obstructions and provide access in fire lanes.

Large fire apparatus need room to effectively maneuver in the event of an emergency.

**Status:** PASS

**Notes:**

### Fire Separations

Keep attic and scuttle covers closed, and ceiling tiles in place.

Ceilings are an integral part of the building fire protection. If kept in place, the ceiling will protect roof structures from premature collapse.

**Status:** PASS

**Notes:**

Remove obstructions from fire doors and maintain to operate properly.

Fire and smoke doors should not be blocked open or obstructed or fire and smoke will easily travel through the opening and cause excessive risk to life and property.

**Status:** PASS

**Notes:**

Seal unapproved openings with approved material.

Flame, smoke, and hot gases can easily travel through holes and pipe chases, thus creating more damage and a hazard to occupants.

**Status:** PASS

**Notes:**

### Housekeeping

6 month inspection record for hood/duct suppression system

Need to provide the inspection sticker for having the hood maintained every 6 months.

**Status:** PASS

**Notes:**

Arrange storage in orderly manner to provide for exiting and fire department access.

Good housekeeping makes an area safer for occupants and contributes less fuel to a fire. When storage is orderly, fire fighters can get fast access to minimize fire damage.

**Status:** PASS

**Notes:**

Remove or store rubbish, waste material, oily rags in closed metal containers.

Safety containers for oily and greasy rags are designed to prevent spontaneous ignition of their contents. Other highly flammable wastes must be separated from sources of ignition.

**Status:** PASS

**Notes:**

Clean grease filters and hood/duct system over cooking equipment.

Regular cleaning of the hood, duct, and filters will eliminate flammable grease build-up and provide proper ventilation of hood through the exhaust outlet.

**Status:** PASS

**Notes:**

Provide approved waste containers for combustible waste.

Heavy duty or metal containers are necessary to confine a fire in the receptacle to prevent it spreading to the building.

**Status:** PASS

**Notes:**

Remove storage to at least 18 inches below level of sprinklers (36 inches for storage piled over 12 feet high)

Storage too close to a sprinkler will not allow the water spray to properly penetrate the fire and extinguish it.

**Status:** PASS

**Notes:**

Chain all compressed gas cylinders in an upright position and provide protective caps.

Compressed gas cylinders, empty or full, can take off like a rocket in any direction if they fail and rupture. Nesting is allowed in certain occupancies

**Status:** PASS

**Notes:**

Boiler, mechanical, and electrical panel rooms shall not be used for storage.

Combustible materials in these equipment rooms often get put too close to sources of heat and a fire will likely result.

**Status:** PASS

**Notes:**

Post and enforce "No Smoking" signs.

"No Smoking" areas are designated because the use of smoking materials in those areas could cause a fire.

**Status:** PASS

**Notes:**

Reduce storage height to at least 2 feet below ceiling.

In the event of a fire, fire fighters may need to open a hole in the roof to let heat and smoke out. Storage and other obstructions will prevent rapid ventilation efforts.

**Status:** PASS

**Notes:**

Move the dumpster at least 5 feet from the building or overhangs.

Dumpsters are a common fire target of vandals. Moving the dumpster away will reduce the risk of a fire spreading to the building.

**Status:** PASS

**Notes:**

### Flammable Liquids

Discontinue use of Class 1 liquids (gasoline, etc.) for cleaning.

These liquids are highly volatile and can be easily ignited by sparks, pilot lights, or other sources of heat.

**Status:** PASS

**Notes:**

Storage in excess of 5 gallons shall be in an approved fire cabinet.

In the event of a fire, flammable liquids can readily accelerate its spread. Confining the stored liquids to secure cabinets will limit this fire exposure.

**Status:** PASS

**Notes:**

Discontinue pouring from containers exceeding 5 gallons or provide pump taking suction from top.

Larger flammable liquid containers are difficult to handle, and their contents are easily spilled. Pumps taking suction from the top restrict the amount likely to be discharged accidentally.

**Status:** PASS

**Notes:**

Store liquids away from exits, aisles, corridors, or stairways.

The accelerating effect of flammable liquids in a fire can quickly make safe exit impossible.

**Status:** PASS

**Notes:**

Use only approved safety can for portable dispensing of flammable liquids.

Safety containers for flammable or combustible liquids are designed to prevent flammable fumes from escaping or accidental spills.

**Status:** PASS

**Notes:**

### Electrical

Discontinue use of extension cords in lieu of permanent wiring.

Temporary wire does not afford the durability, safety, and protection from shock or fire that is found in the construction of an enclosed electrical system.

**Status:** PASS

**Notes:**

Maintain a minimum of 30 inches wide, 36 inches deep, and 78 inches high clearance in front of electrical panel.

Access to electrical panels must be cleared to allow for general inspection and emergency shutdown.

**Status:** PASS

**Notes:**

Each outlet box shall have a cover faceplate or fixture canopy.

Covers protect people from being shocked by exposed wires, prevent spread of electrical current, and heat and flame during short circuits.

**Status:** PASS

**Notes:**

Discontinue use of non-approved multi-plug adapters.

Multi-plug adapters invite the overuse of the circuit that can result in overheating and a fire.

**Status:** PASS

**Notes:**

Maintain wiring in good condition and protect from damage.

Worn or broken wires and plugs present a fire hazard and risk of electrical short circuit that can result in a fire.

**Status:** PASS

**Notes:**

### Additional Time Spent on Inspection:

Category	Start Date / Time	End Date / Time
<b>Notes:</b> No Additional time recorded		

**Total Additional Time: 0 minutes**

**Inspection Time: 20 minutes**

**Total Time: 20 minutes**

**Summary:**

**Overall Result:** Pass

Passed all requirements

**Inspector Notes:**

RECEIVED

AUG 14 2024

APPLICATION FOR Business License



A Business License is required for ANY business to operate within the City of Mills, a Business License Application must be completed. Incomplete applications shall be returned.

License #: 9605

Date: \_\_\_\_\_

- checkboxes for New Business, Change of Ownership, Change of Location, Renewal, Expired

GENERAL INFORMATION

Name of Business: CASPER DISCOUNT STORAGE

Physical Address: 620 SALT CREEK CASPER WY 82601

Mailing Address: SAME

Business Phone Number: (307) 267-2345 WY Tax ID Number: N/A

Email Address: cacor77ss@hotmail.com Website: CASPERDISCOUNTSTORAGE.COM

Description of Business: MINI STORAGE

APPLICANT INFORMATION

Applicant Name: MARVIN CHRISTOPHERSON Phone Number: \_\_\_\_\_

Mailing Address: 620 SALT CREEK CASPER WY 82601

I certify that the above information is correct and true to the best of my knowledge.

Applicants Signature: [Signature]

There will be a fire inspection fee to be paid at the time the License is issued.

Table with 2 columns: Business type and Fee amount.

PAID AUG 14 2024

Return completed form to: Mills City Hall, 720 4th Street, 307-234-6679

OFFICE USE ONLY This license was / was not Granted at a meeting of the Mills City Council on the \_\_\_\_\_ Attest \_\_\_\_\_

## Raelyn Stoneking

---

**From:** no-reply@livsafe.com  
**Sent:** Tuesday, August 20, 2024 4:05 PM  
**To:** racer77ss@hotmail.com; Raelyn Stoneking; info  
**Cc:** info@livsafe.com  
**Subject:** Inspection Report has been submitted

EXTERNAL EMAIL: This email originated from outside of the City of Mills. Do not click any links or open any attachments unless you trust the sender and know the content is safe.



**Mills Fire Department (WY)**

c/o LIVSafe  
445 E Chubbuck Rd, Ste A  
Chubbuck, ID 83202

300 Lakeview Dr  
Mills, Wyoming 82604

### **FIRE INSPECTION REPORT COMPLIANCE**

August 20, 2024

**Casper Discount Storage  
620 Salt Creek Highway  
Casper, Wyoming 82601**

Mills Fire Department (WY) has completed a Fire & Life Safety Inspection on this Premise. During the Inspection, **NO FIRE CODE VIOLATIONS** were observed.

We appreciate your efforts in keeping the business safe for employees and patrons.

Sincerely,

Wil Gay  
Mills Fire Department (WY)





**CITY OF MILLS**  
EST. 1921

RECEIVED

JUL 18 2024

**APPLICATION FOR  
Business License**

*A Business License is required for ANY business to operate within the City of Mills, a Business License Application must be completed. Incomplete applications shall be returned.*

License #: 9822

Date: 7/17/24

New Business     Change of Ownership     Change of Location     Renewal     Expired

GENERAL INFORMATION

Name of Business: EJO Rink LLC

Physical Address: 305 Van Horn Ave Mills WY 82644  
Street City State Zip

Mailing Address: PO Box 220 Mills WY 82644  
Street City State Zip

Business Phone Number: 307-265-4214 WY Tax ID Number: 92-1178639

Email Address: wagonwheel skate@gmail.com Website: ~~www~~ wwwskate.com

Description of Business: Roller skating rink

APPLICANT INFORMATION

Applicant Name: Elisa and Jon Odlin Phone Number: 307-267-9651

Mailing Address: PO Box 220 Mills WY 82644  
Street City State Zip

**I certify that the above information is correct and true to the best of my knowledge.**

Applicants Signature: Elisa Odlin

**There will be a fire inspection fee to be paid at the time the License is issued.**

Businesses that qualify for a Self-Assessment Fire Inspection	\$45.00
Businesses between 1-5,000 Sq. Feet	\$75.00
Businesses between 5,001-10,000 Sq. Feet	\$125.00
Businesses greater than 10,000 Sq. Feet	\$250.00
Businesses with Fire Alarm, Sprinkler System or Hood Suppression	+ \$50.00

PAID

JUL 18 2024

Return completed form to:  
Mills City Hall  
720 4<sup>th</sup> Street  
307-234-6679

<p><b>OFFICE USE ONLY</b> This license was / was not Granted at a meeting of the Mills City Council on the _____ Attest: _____</p>
--

**Raelyn Stoneking**

---

**From:** no-reply@livesafe.com  
**Sent:** Friday, August 16, 2024 3:12 PM  
**To:** info  
**Cc:** info@livesafe.com  
**Subject:** Inspection Report has been submitted

**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

EXTERNAL EMAIL: This email originated from outside of the City of Mills. Do not click any links or open any attachments unless you trust the sender and know the content is safe.



**Mills Fire Department (WY)**

c/o LIVSafe  
445 E Chubbuck Rd, Ste A  
Chubbuck, ID 83202

300 Lakeview Dr  
Mills, Wyoming 82604

## **FIRE INSPECTION REPORT COMPLIANCE**

August 16, 2024

**Wagon Wheel  
305 Van Horn Ave  
Mills, Wyoming 82604**

Mills Fire Department (WY) has completed a Fire & Life Safety Inspection on this Premise. During the Inspection, **NO FIRE CODE VIOLATIONS** were observed.

We appreciate your efforts in keeping the business safe for employees and patrons.

Sincerely,

Wil Gay  
Mills Fire Department (WY)

RECEIVED

JUL 23 2024

APPLICATION FOR Business License



CITY OF MILLS EST. 1921

A Business License is required for ANY business to operate within the City of Mills, a Business License Application must be completed. Incomplete applications shall be returned.

License #: 1039

Date: 7/23/24

- Checkboxes for New Business, Change of Ownership, Change of Location, Renewal (checked), Expired.

GENERAL INFORMATION

Name of Business: JTEAM CUSTOM ENGINES
Physical Address: 621 JOHNSON AVE MILLS WY 82644
Mailing Address: PO BOX 2526 MILLS WY 82644
Business Phone Number: 307 237 0939 WY Tax ID Number: 010016353
Email Address: J2GOOD707@GMAIL.COM Website: NA
Description of Business: ENGINE REBUILDING

APPLICANT INFORMATION

Applicant Name: JERRY WOOD Phone Number: 307 237 0939
Mailing Address: PO BOX 2526 MILLS WY 82644

I certify that the above information is correct and true to the best of my knowledge.

Applicants Signature: JWOOD

There will be a fire inspection fee to be paid at the time the License is issued.

Table with 2 columns: Business description and Fee amount.

PAID JUL 23 2024

Return completed form to: Mills City Hall, 720 4th Street, 307-234-6679

OFFICE USE ONLY
This license was / was not
Granted at a meeting of the Mills
City Council on the
Attest

## Raelyn Stoneking

---

**From:** no-reply@livesafe.com  
**Sent:** Friday, August 16, 2024 9:13 AM  
**To:** Raelyn Stoneking; info  
**Cc:** info@livesafe.com  
**Subject:** Inspection Report has been submitted

EXTERNAL EMAIL: This email originated from outside of the City of Mills. Do not click any links or open any attachments unless you trust the sender and know the content is safe.



**Mills Fire Department (WY)**

c/o LIVSafe  
445 E Chubbuck Rd, Ste A  
Chubbuck, ID 83202

300 Lakeview Dr  
Mills, Wyoming 82604

### **FIRE INSPECTION REPORT COMPLIANCE**

August 16, 2024

**J Team Custom Engines  
621 Johnson Avenue  
Mills, Wyoming 82604**

Mills Fire Department (WY) has completed a Fire & Life Safety Inspection on this Premise. During the Inspection, **NO FIRE CODE VIOLATIONS** were observed.

We appreciate your efforts in keeping the business safe for employees and patrons.

Sincerely,

Wil Gay  
Mills Fire Department (WY)



**CITY OF MILLS**  
EST. 1921

RECEIVED

JUL 16 2024

**APPLICATION FOR  
Business License**

A Business License is required for ANY business to operate within the City of Mills, a Business License Application must be completed. Incomplete applications shall be returned.

License #: 9798

Date: 7-15-24

New Business     Change of Ownership     Change of Location     Renewal     Expired

GENERAL INFORMATION

Name of Business: Millview Laundromat

Physical Address: 520 SW WY Blvd Mills WY 82644  
Street City State Zip

Mailing Address: Po Box 2633 Casper WY 82602  
Street City State Zip

Business Phone Number: 307.472.0117 WY Tax ID Number: 88-2968788

Email Address: Preshduds307@gmail Website: millviewlaundromat.com

Description of Business: Laundromat

APPLICANT INFORMATION

Applicant Name: Shawn Patten Phone Number: 258-5513

Mailing Address: Po Box 2633 Casper WY 82602  
Street City State Zip

I certify that the above information is correct and true to the best of my knowledge.

Applicants Signature: [Signature]

There will be a fire inspection fee to be paid at the time the License is issued.

Businesses that qualify for a Self-Assessment Fire Inspection	\$45.00
Businesses between 1-5,000 Sq. Feet	\$75.00
Businesses between 5,001-10,000 Sq. Feet	\$125.00
Businesses greater than 10,000 Sq. Feet	\$250.00
Businesses with Fire Alarm, Sprinkler System or Hood Suppression	+ \$50.00

PAID

JUL 16 2024

Return completed form to:  
Mills City Hall  
704 4<sup>th</sup> Street  
Po Box 789  
Mills, WY 82644  
307-234-6679

OFFICE USE ONLY  
This license was / was not  
Granted at a meeting of the Mills  
City Council on the \_\_\_\_\_  
Attest \_\_\_\_\_

## Raelyn Stoneking

---

**From:** no-reply@livesafe.com  
**Sent:** Monday, August 19, 2024 4:22 PM  
**To:** freshduds307@gmail.com; Raelyn Stoneking; info  
**Cc:** info@livesafe.com  
**Subject:** Inspection Report has been submitted

EXTERNAL EMAIL: This email originated from outside of the City of Mills. Do not click any links or open any attachments unless you trust the sender and know the content is safe.



### Mills Fire Department (WY)

c/o LIVSafe  
445 E Chubbuck Rd, Ste A  
Chubbuck, ID 83202

300 Lakeview Dr  
Mills, Wyoming 82604

## FIRE INSPECTION REPORT COMPLIANCE

August 19, 2024

**Millview Laundromat**  
**520 Wyoming Boulevard Southwest**  
**Mills, Wyoming 82644**

Mills Fire Department (WY) has completed a Fire & Life Safety Inspection on this Premise. During the Inspection, **NO FIRE CODE VIOLATIONS** were observed.

We appreciate your efforts in keeping the business safe for employees and patrons.

Sincerely,

Wil Gay  
Mills Fire Department (WY)



**CITY OF MILLS**  
EST. 1921

**APPLICATION FOR  
Business License**

*A Business License is required for ANY business to operate within the City of Mills, a Business License Application must be completed. Incomplete applications shall be returned.*

License #: 9902

Date: 06/17/2024

New Business    Change of Ownership    Change of Location    Renewal    Expired

**GENERAL INFORMATION**

Name of Business: National Oilwell Varco, LP

Physical Address: 1080 N Robertson Road     Casper, WY     82604-2105  
Street     City     State     Zip

Mailing Address: 10353 Richmond Ave.     Houston, TX     77042-4103  
Street     City     State     Zip

Business Phone Number: (307) 473-8888     WY Tax ID Number: 01012477

Email Address: NOVtax@nov.com     Website: www.nov.com

Description of Business: \_\_\_\_\_  
**NAICS 333131 - Mining Machinery and Equipment Manufacturing**  
**NAICS 333132 - Oil and Gas Field Machinery and Equipment Manufacturing**

**APPLICANT INFORMATION**

Applicant Name: Latonya S. Chase, Manager/Sales Tax     Phone Number: (713) 634-3149

Mailing Address: 10353 Richmond Ave.     Houston, TX     77042-4103  
Street     City     State     Zip

**I certify that the above information is correct and true to the best of my knowledge.**

Applicants Signature: Latonya S. Chase

**There will be a fire inspection fee to be paid at the time the License is issued.**

Businesses that qualify for a Self-Assessment Fire Inspection	\$45.00
Businesses between 1-5,000 Sq. Feet	\$75.00
Businesses between 5,001-10,000 Sq. Feet	\$125.00
Businesses greater than 10,000 Sq. Feet	\$250.00
Businesses with Fire Alarm, Sprinkler System or Hood Suppression	+ \$50.00

**PAID**  
AUG 1 2 2024

Return completed form to:  
Mills City Hall  
720 4<sup>th</sup> Street  
307-234-6679

**OFFICE USE ONLY**  
This license was / was not  
Granted at a meeting of the Mills  
City Council on the \_\_\_\_\_  
Attest \_\_\_\_\_

## Raelyn Stoneking

---

**From:** no-reply@livesafe.com  
**Sent:** Tuesday, July 9, 2024 1:19 PM  
**To:** Raelyn Stoneking; John.holbrook@nov.com  
**Cc:** info@livesafe.com  
**Subject:** Inspection Report has been submitted

**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

EXTERNAL EMAIL: This email originated from outside of the City of Mills. Do not click any links or open any attachments unless you trust the sender and know the content is safe.



### Mills Fire Department (WY)

c/o LIVSafe  
445 E Chubbuck Rd, Ste A  
Chubbuck, ID 83202

300 Lakeview Dr  
Mills, Wyoming 82604

## FIRE INSPECTION REPORT COMPLIANCE

July 9, 2024

**NOV Tuboscope**  
**1080 Robertson Road**  
**Casper, Wyoming 82604**

Mills Fire Department (WY) has completed a Fire & Life Safety Inspection on this Premise. During the Inspection, **NO FIRE CODE VIOLATIONS** were observed.

We appreciate your efforts in keeping the business safe for employees and patrons.

Sincerely,

Wil Gay  
Mills Fire Department (WY)





**CITY OF MILLS**  
EST. 1921

RECEIVED

AUG 06 2024

**APPLICATION FOR  
Business License**

**A Business License is required for ANY business to operate within the City of Mills, a Business License Application must be completed. Incomplete applications shall be returned.**

License #: 9849

Date: 7.17.2024

New Business     Change of Ownership     Change of Location     Renewal     Expired

GENERAL INFORMATION

Name of Business: USA Trucking, LLC

Physical Address: 5370 W. Poison Spider Rd Casper, WY 82604  
Street City State Zip

Mailing Address: PO Box 40 Mills WY 82644  
Street City State Zip

Business Phone Number: 307.266.3094 WY Tax ID Number: \_\_\_\_\_

Email Address: anita@usatruckingmills.com Website: N/A

Description of Business: Trucking & Warehousing of drilling mud products.

APPLICANT INFORMATION

Applicant Name: Deanna Hegeraki Phone Number 307.266.3094

Mailing Address: PO Box 40 Mills WY 82644  
Street City State Zip

**I certify that the above information is correct and true to the best of my knowledge.**

Applicants Signature: Deanna Hegeraki

**There will be a fire inspection fee to be paid at the time the License is issued.**

Businesses that qualify for a Self-Assessment Fire Inspection	\$45.00
Businesses between 1-5,000 Sq. Feet	\$75.00
Businesses between 5,001-10,000 Sq. Feet	\$125.00
Businesses greater than 10,000 Sq. Feet	\$250.00
Businesses with Fire Alarm, Sprinkler System or Hood Suppression	+ \$50.00

PAID

AUG 07 2024

Return completed form to:  
Mills City Hall  
704 4<sup>th</sup> Street  
Po-Box 789  
Mills, WY 82644  
307-234-6679

<p><b>OFFICE USE ONLY</b> This license was / was not Granted at a meeting of the Mills City Council on the _____ Attest _____</p>
---

## Raelyn Stoneking

---

**From:** no-reply@livsafe.com  
**Sent:** Friday, August 9, 2024 3:33 PM  
**To:** Raelyn Stoneking; Laramielegerski@gmail.com; info@livsafe.com  
**Cc:** info@livsafe.com  
**Subject:** Inspection Report has been submitted

EXTERNAL EMAIL: This email originated from outside of the City of Mills. Do not click any links or open any attachments unless you trust the sender and know the content is safe.



### Mills Fire Department (WY)

c/o LIVSafe  
445 E Chubbuck Rd, Ste A  
Chubbuck, ID 83202

300 Lakeview Dr  
Mills, Wyoming 82604

## FIRE INSPECTION REPORT COMPLIANCE

August 9, 2024

**USA Trucking**  
**5370 Poison Spider Road**  
**Casper, Wyoming 82604**

Mills Fire Department (WY) has completed a Fire & Life Safety Inspection on this Premise. During the Inspection, **NO FIRE CODE VIOLATIONS** were observed.

We appreciate your efforts in keeping the business safe for employees and patrons.

Sincerely,

Wil Gay  
Mills Fire Department (WY)