



MEETING DATE: June 23, 2025
PRESENTED BY: Juan Pablo "JP" Terrazas, P.E., Asst. City Manager
AGENDA ITEM: Approval of Interlocal Agreement between the City of Mission and Agua SUD relating to the Inspiration Road Sanitary Sewer - Lift Station 10 Flow Reroute - Terrazas

NATURE OF REQUEST:

The City of Mission sanitary sewer trunkline along Inspiration Road has reached maximum capacity during storm events due to infiltration. Lift Station Number 10 currently discharges over 2 MGD of wastewater into the Inspiration Road sanitary sewer trunkline and this flow is contributing to the trunkline reaching maximum capacity, by rerouting a portion, up to 500 thousand gallons (kgal) per day of the effluent flow coming from City of Mission Lift Station Number 10 to the Agua SUD P2 Lift Station located on La Homa Road will offset the flow from the trunkline and allow it to be more manageable to maintain.

Agua SUD has agreed to reroute the effluent flow from Lift Station Number 10 through their system and ultimately discharge at the City of Mission Wastewater Plant. Agua SUD approved the Interlocal Agreement at their June 17, 2025 meeting.

Agua SUD will charge the City for Wastewater reroute services at a set rate of \$1.089 per thousand gallons (\$1.089 per 1,000 gallons) on a monthly basis.

BUGETED: _____ **FUND:** _____ **ACCT. #:** _____

BUDGET: _____ **EST. COST:** _____ **CURRENT BUDGET BALANCE:** _____

STAFF RECOMMENDATION:

Approval

Departmental Approval: N/A

Advisory Board Recommendation: N/A

City Manager's Recommendation: Approval *MRP*

RECORD OF VOTE: **APPROVED:** _____

DISAPPROVED: _____

TABLED: _____

_____ AYES

_____ NAYS

_____ DISSENTING _____