

Utilities Council Report

April 8th 2025

WATER

- All water samples came back good this month.
- Bryce and I attended the SRC4 conference (water classes) at Whitworth University on March 27.
- Inspected a new water service at 2919 N. Dale by Roto Rooter.
- Installed a new 4" water meter for the park.
- Met with Ashley from Welch Comer regarding Water System Plan updates.
- 8819 E. Frederick had previously been concreted in the curb stop box due to meter tampering and unauthorized occupation of the property. The property was sold and a new curb stop box was installed.

SEWER

- One of the pumps at lift station #2 kept tripping; the pump was removed, disassembled, cleaned, reassembled and reinstalled. It appears to be operating correctly now.