



Water and Wastewater Operations and Management
375 Lake Meadows Drive, Montgomery, Texas 77356
Ph:936-588-1166

CITY OF MONTGOMERY

MONTHLY OPERATIONS REPORT

DATE
11/10/25

<u>METER COUNT</u>	
Total	1,447

<u>CONSUMPTION</u>		
<u>08/31/25</u>	<u>to</u>	<u>09/30/25</u>
Billed Consumption		19,393,429
Estimated Flushing		975,000
Total		20,368,429

Plant Pumpage 21,768,300

Accountability **93.57%**

	Well #2	Well #3	Well #4
Well Pumpage	N/A	12,991,300	8,777,000
Calculated Well GPM	N/A	497	1189
Avg Well Run Hours	N/A	14.5	4.1

CITY OF MONTGOMERY

DATE
11/10/25

MONTHLY OPERATIONS SUMMARY

WASTEWATER TREATMENT PLANT

September 2025

TPDES Permit # WQ0014737001

Expires: 06/01/2027

NPDES Permit # TX0128031

	Effluent Quality Data: Reported for		September-25	
	<u>Reported</u>	<u>Permitted</u>	<u>Annual Average</u>	<u>Excursion</u>
BOD 5 Average	2.43 mg/l	10.00 mg/l	2.51 mg/l	NO
TSS Average	5.18 mg/l	15.00 mg/l	5.22 mg/l	NO
NH3	0.06 mg/l	2.00 mg/l	0.05 mg/l	NO
CL2 Res Min	1.22 mg/l	1.00 mg/l	1.44 mg/l	NO
CL2 Res Max	3.92 mg/l	4.00 mg/l	3.57 mg/l	NO
Oxygen	7.44 mg/l	4.00 mg/l	7.48 mg/l	NO
Flow Average	0.224 mgd	0.400 mgd	0.239 mgd	NO

Effluent Quality Compliant with Discharge Permit ? YES

The plant was operated within all parameters of our permit.

No violation notices were received from any other local agency.

CITY OF MONTGOMERY
MONTHLY OPERATIONS SUMMARY
GROUND WATER PERMIT PUMPAGE
September 2025

LONE STAR GROUNDWATER CONSERVATION DISTRICT
PERMIT #OP-04072101D/HUP040 & 13012801B AWS - 01/01/25 - 12/31/25

"Gulf Coast Aquifer" - Jasper		Catahoula Aquifer	
Jan-25	6,094,300	6,240,000	
Feb-25	5,256,300	6,868,000	
Mar-25	7,347,100	8,224,000	
Apr-25	7,680,000	8,304,000	
May-25	9,852,600	8,637,000	
Jun-25	8,811,700	8,053,000	
Jul-25	9,068,100	9,493,000	
Aug-25	12,637,100	10,278,000	
Sep-25	12,991,300	8,777,000	
Oct-25			
Nov-25			
Dec-25			
Total Pumpage	79,738,500	41.73%	74,874,000
			39.15%

2025 Permitted Withdrawal: 191,081,000 191,250,000

Permit Summary Gulf Coast Aquifer

Historical Use Permit Amount:	92,930,000
2025 Permitted Withdrawal:	92,930,000

Alternative Water Summary

City of Montgomery - Alternate Water Source Permit:	90,000,000
Total 2025 GRP AWS Permitted Withdrawal:	90,000,000