

Montgomery City Council  
**AGENDA REPORT**

<b>Meeting Date: September 14, 2021</b>	<b>Budgeted Amount: N/A</b>
<b>Prepared By: Mike Muckleroy</b>	<b>Exhibits: Quote</b>

**Subject**

Consideration and possible action regarding the relocation of a Kohler 60KW generator to Lift Station 6.

**Description**

The city owns a Kohler 60KW generator that was previously onsite at the former location of Lift Station 1 (Chick-fil-A site). The generator was stored with the intent of placing it at another Lift Station in the future. We have determined that Lift Station 6 has the greatest need for permanent backup power. This is an all-inclusive quote that includes all work needed to move it onsite and hard wire it in place. The quote to move and wire it in is \$14,150.00 They also provided a quote of \$4,431.00 for replacement of the automatic transfer switch if it is needed which is a high probability.

**Recommendation**

Recommend approval of the proposals from GenSolutions, LLC.

**Approved By**

Director of Public Works	Mike Muckleroy	Date: 09/08/2021
City Administrator	Richard Tramm	Date: 09/08/2021



