

CITY COUNCIL AGENDA
Regular Meeting: April 8, 2025

AGENDA ITEM:

Consideration and Possible Action for the TPDES Permit Amendment for the Stewart Creek Wastewater Treatment Plant to 0.8MGD flow.

SUBMITTED BY: Ruby Beaven, City Secretary/Director of Administrative Services

APPROVED FOR AGENDA: Anthony Solomon, Interim City Administrator/Police Chief

BACKGROUND:

The Client Memo is attached.

WGA has prepared a client memo to expand the existing Stewart Creek WWTP permit capacity from the current 0.4MGD to include an ultimate phase of 0.8MGD flow. As a part of the 2023 WWTP Analysis, it was determined that the City would need to upsize the existing facilities to accommodate for proposed development within the City. This proposal will provide the City with the ultimate permit capacity to upsize the existing Stewart Creek plant in the future should wastewater capacity be needed. This does not change the current permit capacity of 0.4MGD but provides for an ultimate phase for future expansions. This is recommended at this time as we are experiencing significant delays at the TCEQ and do not want to be delayed in future design by the permit.

It should be noted that the scope of work only includes preparation and submission to the TCEQ for the permit amendment and does not include any design or construction services.

FISCAL ANALYSIS: \$25,000

RECOMMENDATION: WGA recommends Council authorization to begin the Stewart Creek TPDES permit amendment to 0.8MGD.