

Montgomery City Council
AGENDA REPORT

Meeting Date: January 14, 2025	Budgeted Amount: ARPA Funded
Department: Administration	Prepared By: WGA

Subject

Consideration and possible action on authorizing the City Engineer to begin work on the Water Plant No. 3 Booster Pump Addition project.

Recommendation

Approval of the item as presented.

Discussion

The engineer’s memo is attached.

This project includes the addition of a 4th booster pump at Water Plant No. 3. This project was previously designed and bid with the Water Plant No. 3 Improvements project but was ultimately removed due to budget constraints.

Upon completion of the project, the City’s booster pump capacity will be increased from 325,000 to 486,000 gpd. This will give the City an additional buffer on capacity while Water Plant No. 4 is in design and construction.

Approved By

City Staff	Ruby Beaven, City Secretary & Director of Administrative Services	Date: 01/10/2025
------------	--	------------------